



MME

CIVIL + STRUCTURAL ENGINEERING • SINCE 1987

BIDDER QUESTION #11

Engineer's Response to Request for Information

Project: San Lorenzo Valley Water District / Probation Tank Replacement
RFI No: B - 011
Requested by: Collins Electrical Company, Inc.
Date Received: April 24, 2018
Regarding: SCADA Photovoltaic Mounting & Emerson Offer WAM16 Equipment

Response

1. The contractor shall install the SCADA photovoltaic power and mount the SCADA RTU enclosure control box on the tank stair and top railing and all associated conduits and hardware as directed by SLVWD.
2. All SCADA equipment provided under Emerson Offer WAM16110048 will be furnished by owner. Contractor will supply all associated conduits, wire and hardware required by contract documents not included in Emerson Offer WAM16110048.

Signed By:

Date: 04/27/18