



BIDDER QUESTION #4

Revised Engineer's Response to Request for Information

Project: San Lorenzo Valley Water District / Probation Tank Replacement

RFI No: B - 004

Requested by: Crosno Construction Inc.

Date Received: April 9, 2018

Regarding: Tank Coating Contractor Qualifications

Revised Response

~~The tank coating contractor qualification for this project on sheet T3.0, Tank Coating in the Qualifications Section, Item 1: "Contractor engaged in surface preparation and coating application shall be certified according to SSPC-QP-1."~~

~~This qualification requirement will not be modified or waived.~~

The tank coating contractor qualification for this project has been revised in the Addendum #1 Plans on sheet T3.0, Tank Coating in the Qualifications Section, Item 1: "Contractor Contractor engaged in surface preparation and coating application shall be certified according to SSPC QP 1 or be licensed as a Painting and Decorating Contractor in the State of California (C-33) with a minimum of ten (10) years of practical experience and successful history in coating welded steel potable water storage tanks. Upon request, a written list of references shall be submitted to substantiate the experience requirement. For surface preparation, coating, and related work, Contractor shall coordinate with an independent, third-party SSPC QP 5 certified inspection company hired by SLVWD."

Signed By:

Date: 04/18/18