



MME

CIVIL + STRUCTURAL ENGINEERING • SINCE 1987

BIDDER QUESTION #9

Engineer's Response to Request for Information

Project: San Lorenzo Valley Water District / Probation Tank Replacement
RFI No: B - 009
Requested by: EXARO Technologies Corporation
Date Received: April 23, 2018
Regarding: Resistivity of the Water in the Tank and Cathodic Protection System Design Submittals

Response

1. The determination of the resistivity of the water in the tank for design will be coordinated with the apparent low bidder.
2. The design of the cathodic protection system requires just 100% submittal.

Signed By:

Date: 04/27/18