

M E M O

TO: District Manager

FROM: Director of Operations

SUBJECT: Operations Department Project Status Report
Week Ending May 11, 2007

DATE: May 11, 2007

RECOMMENDATION:

It is recommended that the District Manager review and file the Operations Department Project Status Report for the week ending May 11, 2007.

BACKGROUND:

Meter Change Over Program

During the reporting period staff spent the majority of time performing water meter change-outs in the North Boulder Creek. The meter change out program is behind schedule and it is intended to be on schedule by end of this fiscal year. Meters are changed out every fifteen years to ensure accuracy as water meter accuracy decreases with age.

Water Sampling Stations

As part of the District's water quality sampling program water sampling stations are being installed District wide. During the reporting period staff install four stations in the Brookdale/Ben Lomond areas.

Main Repairs Fremont Street

During the reporting period staff replaced a section of four-inch water line on Fremont Street in Ben Lomond. Staff replaced 20 lineal feet of four-inch water line, two water services and a tee section of piping.

Main Repairs Big Basin Way

Staffs repair a two-inch water line leak on Big Basin Way. Customer reported the water line had been leaking for approximately one month and believe the leak to be ground water. Staff estimated the leak to be 6 gallons per minute totaling 259,200 gallons of water.

Rick Rogers
Director of Operations

RR/