

M E M O

TO: District Manager

FROM: Director of Operations

SUBJECT: Operations Department Project Status Report
Week Ending January 26, 2007

DATE: January 26, 2007

RECOMMENDATION:

It is recommended that the District Manager review and file the Operations Department Project Status Report for the week ending January 27, 2007.

BACKGROUND:

Meter Change Over Program

During the reporting period staff spent the majority of time performing water meter change-outs. The meter change out program is behind schedule and it is intended to be on schedule by end of this fiscal year. Meters are changed out every fifteen years to ensure accuracy as water meter accuracy decreases with age.

Olympia Well 2 Maintenance

During the reporting period Olympia Well 2 was taken out of service for maintenance. Maintenance included replacing 42 lineal feet of six-inch pump column, submersible pump and motor. In addition the well casing was inspected with underwater video equipment. This maintenance is routine and done every two years.

Manana Woods Transition

Staff continued with improvements in the Manana Woods Water area during the reporting period. Float valves and assorted plumbing was performed at storage tanks for reverse flow water supply. This work will allow water from the Districts Upper Pasatiempo water tank to gravity flow into the Manana Woods area.

Rick Rogers
Director of Operations

RR/