

M E M O

TO: District Manager

FROM: Director of Operations

SUBJECT: Operations Department Project Status Report
Week Ending October 13, 2006

DATE: October 13, 2006

RECOMMENDATION:

It is recommended that the District Manager review and file the Operations Department Project Status Report for the week ending October 13, 2006.

BACKGROUND:

Whittier/Manzanita Ave Water Main Replacement

During the reporting period construction continued for the Whittier/Manzanita Water Main replacement project. Construction activities consisted of the installation of 500 lineal feet of eight-inch waterline and several water services. Several customers in this area are complaining of low water pressure and intermittence interruption of water service. Staff has identified that long undersized mainline in this area is responsible for pressure problems. Staff is installing 550 lineal feet of eight-inch water line to improve water service.

New Service Dana Court

Staff upgraded a water service in Dana Court, Scotts Valley to provide for fire sprinkler flow to a remodel home.

Upper Pasatiempo Tank Gate

During the reporting period staff install a gate across the driveway to the Districts Upper Pasatiempo Tank in Scotts Valley. The gate was installed to block access to the access road and tank.

Nina Tank Proposed New Location

The District received permission to enter property from the property owner of the proposed new location of the Nina Tank. Staff entered to brush for surveying and geotechnical review. In addition the District is in the process of obtaining property appraisal of the property.

Rick Rogers
Director of Operations

RR/