

SECTION 00901

ADDENDUM NO. 1

GENERAL

Scope

This addendum modifies the Contract Documents dated September 1, 2022, for the San Lorenzo Valley Water District Foreman Pipeline Access Trail Rehabilitation, and the work shall be accomplished in accordance with such modifications. This Addendum includes two (2) pages and no attachments.

Acknowledgment

Bidders must acknowledge this addendum as part of the bid submission by completing bidder's acknowledgment of addenda (Section 00300). Failure to acknowledge the addendum may constitute grounds for rejection of the bid.

BIDDER REQUESTS FOR INFORMATION

The District has received the following requests for information (RFI). District responses are provided immediately following each RFI, in *red italics* for clarity.

1. Grades: The current plans do not show any existing or design grades. Please provide CAD files that include existing and design grades in order to complete an earthwork takeoff. *The lack of specified grades is intentional. The Contractor shall coordinate with District Staff to determine appropriate final grades in the field. The project Schedule of Values, found in Volume II, Section 00301 of the Bid Documents, specifies an earthwork quantity of 2,000-CY. If the actual quantity differs from this value by more than 25%, the District and the Contractor shall negotiate a revised unit cost based on the actual quantity.*
2. Geotechnical Report: Please provide a copy of the geotechnical report referenced in the bid documents. *The project Geotechnical Report is provided on the District Website, at the url below:*

<https://www.slvwd.com/doing-business/pages/bid-opportunities>
3. Schedule: Please provide an estimated start date for construction. *The District desires to begin construction as quickly as possible after award of the project. Bidders may include a proposed schedule. If no schedule is provided, the District will assume that the Bidder is prepared to begin work within 30 days of the Notice of Award, which is expected to be issued not later than October 21, 2022.*
4. Site Inspection: Are contractors able to visit the site on their own to review existing conditions or does it need to be scheduled? *Please coordinate all site visits with either District Engineer Josh Wolff (JWolff@SLVWD.com) or Assistant Engineer Joel Scianna (JScianna@SLVWD.com).*

5. Will the District provide water for construction purposes? *The Contractor will need to obtain water at the District Admin Building, located at 13060 CA-9 Boulder Creek, CA 95006. District will not charge for bulk water obtained by the Contractor for use in the project.*
6. Will the Contractor be responsible for compaction testing? *No. Compaction testing will be performed by the Geotechnical Engineering Consultant for the project.*

END OF SECTION 00901