

**SECTION 00901**

**ADDENDUM NO. 1**

**1. GENERAL**

*Scope*

This addendum modifies the Contract Documents dated August 20, 2021, for the San Lorenzo Valley Water District Quail Hollow Pipeline Replacement Project, and the work shall be accomplished in accordance with such modifications. This Addendum includes two (2) pages and no attachments.

The Addenda includes Contractor Information Items, responses to questions, and Bid Opening Invitation.

Note: The Bid Date is September 30, 2021.

*Acknowledgment*

Bidders must acknowledge this addendum as part of the bid submission by completing bidder's acknowledgment of addenda (Section 00300). Failure to acknowledge the addendum may constitute grounds for rejection of the bid.

**2. CONTRACTOR INFORMATION ITEMS**

- A. The pre-bid meeting was held on September 2, 2021. The Responses to Questions below are from that pre-bid meeting.
- B. The District is working with Santa Cruz County Public Works to eliminate the requirement for Type II Slurry Seal on this project. As this has not yet been finalized, Bidders should include a unit cost bid item for Type II Slurry Seal application as required by County Standard Detail EP-1. Quantity is assumed to be approximately 8,250 square yards.
- C. The project area includes a quarry access road used by Granite Rock. Bidders shall be aware of, and provide for, traffic control related to this access and schedule coordination with Granite Rock in their bids.

**3. RESPONSES TO QUESTIONS**

- A. Will the District provide water for compaction at no charge?
  - a. Yes. Note that trench backfill is to be 2-sack slurry as shown on the Plans.
- B. What is the pipeline service pressure?
  - a. Pipeline service pressure ranges from 80-psi to 160-psi.
- C. Will the District allow use of the District-owned parcel at the intersection of Quail Hollow Road and East Zayante Drive for stockpiling/vehicle staging?

- a. Yes. Note that the project takes place within the Sand Hills environment; all parking, vehicle staging, material stockpiling, or excavation spoil stockpiling must be within paved areas.
- D. Materials pricing is changing rapidly due to current shortages. When will the District notify the successful Bidder and for how long must the Bidder hold the prices provided in the Bid?
  - a. The District will notify the successful bidder within 1 business day of the Award of this project by the Board of Directors, currently scheduled for Thursday October 7, 2021. Bid prices may not be adjusted after execution of the Agreement (Contract for Construction); the District will make every effort to finalize and execute the Agreement within 30 calendar days of Award.

**4. BID OPENING INVITATION**

- A. The Bid Opening for this project will be held virtually. Meeting will be held at 3pm on September 30, 2021, as specified in the Bid Documents. Meeting log-in location is below:
  - a. <https://global.gotomeeting.com/join/410137925>
  - b. To dial in using your phone:
    - i. United States (Toll Free): 1 877 309 2073 or (646) 749-3129
    - 1. Access Code: 410-137-925

**5. CHANGES TO VOLUME 1, CONTRACT DOCUMENTS AND TECHNICAL SPECIFICATIONS**

- A. None

**6. CHANGES TO VOLUME 2, BID FORMS**

- A. None

**7. CHANGES TO CONTRACT DRAWINGS**

- A. None

**END OF SECTION 00901**