

SECTION 00010

TITLE PAGE



SAN LORENZO VALLEY WATER DISTRICT
13060 CA-9
BOULDER CREEK, CALIFORNIA 95006

**Redwood Park Pipeline
Replacement**

December 2022

BID DOCUMENT VOLUME I OF II

BIDDING REQUIREMENTS, CONTRACT FORMS,
CONDITIONS OF THE CONTRACT AND
TECHNICAL SPECIFICATIONS

APPROVED

A handwritten signature in black ink, appearing to read "Richard Rogers". The signature is written in a cursive style with a horizontal line underneath it.

Rick Rogers
District Manager

SECTION 00015

CONTRACT DOCUMENTS TABLE OF CONTENTS

VOLUME I – CONTRACT DOCUMENTS

DIVISION 0 – BIDDING AND CONTRACT DOCUMENTS

Section	
00010	Title Page
00015	Contract Documents Table of Contents
00020	Invitation to Bidders
00100	Instruction to Bidders
00500	Contract Agreement
00600	Notice of Award
00610	Performance Bond
00620	Payment Bond
00630	Escrow Agreement for Security Deposit in Lieu of Retention
00640	Certificate of Contractor
00645	Contractor's Certification Regarding Worker's Compensation
00648	Information Pursuant to California Labor Code Section 2810
00650	Notice to Proceed
00652	Submittal Form
00654	Request for Information Form
00656	Authorization of Engineering Costs for Evaluation of Substitutes and Equals
00658	Authorization of Engineering Costs for Redesign due of Substitutes and Equals
00660	Contractor's Release
00686	Unconditional Release and Certificate of Final Payment
00687	Notice of Completion
00692	Conditional Waiver and Release Upon Progress Payment
00693	Unconditional Waiver and Release Upon Progress Payment
00694	Conditional Waiver and Release Upon Final Payment
00695	Unconditional Waiver and Release Upon Final Payment
00700	General Conditions
00700A	Cal Trans Standard Specifications Section 8-1.11
00800	Supplementary Conditions
00800CA	California State Requirements
0090_	Addendum No _

DIVISION 1 – GENERAL REQUIREMENTS

Section	
01 10 00	Summary of the Work
01 20 00	Measurement and Payment
01 30 00	Contractor Submittals
01 41 00	Reference Standards
01 42 00	Abbreviations of Institutions
01 53 00	Protection of Existing Facilities
01 55 00	Site Access and Storage

Section

01 56 00	Temporary Environmental Controls
01 57 00	Traffic Regulation
01 57 80	Control of Ground and Surface Water
01 60 00	Products, Materials, Equipment and Substitutions
01 70 00	Project Closeout
01 78 00	Operations and Maintenance Data

DIVISION 02 – EXISTING CONDITIONS

Section

02 01 00	Existing Facilities
----------	---------------------

DIVISION 3 – CONCRETE

Section

03 10 00	Concrete Forming and Accessories
03 20 00	Concrete Reinforcement
03 30 00	Cast-in-Place Concrete
03 60 00	Epoxy Grouts
03 63 00	Epoxies

DIVISION 4 – MASONRY (NOT USED)

DIVISION 5 – METALS

Section

05 50 00	Metal Fabrications
----------	--------------------

DIVISION 6 through DIVISION 21 (NOT USED)

DIVISION 22 – PLUMBING

Section

22 05 53	Underground Facilities Identification
22 11 13	Copper and Brass Pipe, Fittings and Appurtenances
22 11 19	Chlorination of Domestic Water Mains and Services

DIVISION 23 through DIVISION 28 (NOT USED)

DIVISION 31 – EARTHWORK

Section

31 05 16	Precast Construct Structures
31 05 19.13	Geotextile
31 23 00	Trenching, Backfilling and Compacting

DIVISION 32 – EXTERIOR IMPROVEMENTS

Section

32 12 16	Asphalt Paving and Seals
----------	--------------------------

DIVISION 33 – UTILITIES

Section

33 05 09.43	Hot Tap Connections
33 11 00	General Piping Requirements
33 11 13.15	Ductile Iron Pipe and Fittings
33 12 16	Manual Valves
33 12 19	Fire Hydrants

DIVISION 34 through DIVISION 35 (NOT USED)

DIVISION 40 – PROCESS INTEGRATION

Section

40 92 13	Automatic Valves
----------	------------------

DIVISION 41 through DIVISION 48 (NOT USED)

ATTACHMENTS

N/A

VOLUME II – CONSTRUCTION CONTRACT BID FORMS

Section

00010A	Title Page
00015A	Contract Bid Forms Table of Contents
00300	Bid Proposal
00404	List of Material and Equipment Manufacturers
00405	List of Subcontractors
00406	Contractor's Licensing Statement
00408	Contractor's Experience Statement
00410	Bid Security
00415	Bid Guaranty Bond
00420	Safety Compliance
00480	Noncollusion Affidavit
00485	Iran Contracting Act Certification

SECTION 00020

INVITATION TO BIDDERS

RECEIPT AND OPENING OF BIDS.

- A. Sealed Bids will be received by Holly Hossack at SLVWD, 13060 CA-9, Boulder Creek, California, 95006, Telephone (831) 338-2153 until 3:00 p.m. on January 19, 2023 for the construction of the Work entitled:

Redwood Park Pipeline Replacement

DESCRIPTION OF WORK: The project consists of providing new water mains and residential water services along Country Club Drive and Woodland Drive in Ben Lomond, CA with associated fittings and valves. Provide and install approximately 1260-LF of 8-inch ductile iron pipe water main, approximately 44-LF of 6-inch ductile iron pipe water main, approximately 31-LF of 4-inch ductile iron pipe water main, and reconnect 4 existing residential water services. Provide traffic control during the work.

SITE OF WORK: Unincorporated Santa Cruz County (Ben Lomond, CA).

- B. Bids will be publicly opened and read aloud at the place and time stated above. Bidders are invited to log on to the virtual bid opening at the following URL:
<https://meet.goto.com/563558589>
- C. The Owner shall not open any bids received after the time specified above and shall return the unopened Bids to the Bidder.

SECURING BID DOCUMENTS. Bidders may examine the Contract Documents on the District website. Prospective bidders must arrange to print the plans and specifications at their own cost. The project documents, including final plans and specifications will be available on December 6, 2022 on the District's website:

<https://www.slvwd.com/doing-business/pages/bid-opportunities>

MANDATORY PREBID MEETING AND SITE WALK. SLVWD will host a pre-bid meeting and site walk at 10:00 a.m. on December 14, 2022. This meeting is considered mandatory, unless an interested contractor makes other arrangements prior to this time/date to tour the site with District personnel. The District also requests that each contractor brings no more than one vehicle, as parking at the site is very limited. The meeting will begin at the intersection of Country Club Drive and Dundee Avenue, with the nearest street address being 1120 Country Club Drive, Ben Lomond, CA 95005.

ENGINEER'S OPINION OF PROBABLE COSTS. The Engineer's Opinion of Probable Cost is hereby considered to be \$564,320.00, not including special inspections and testing, engineer observations, geotechnical inspections, and environmental observations.

CONTRACT TIME. The contract time is hereby established as 180 calendar days. The contract time shall be consecutive calendar days from the date of receipt of the Notice to Proceed.

LIQUIDATED DAMAGES. The fixed liquidated damages amount is hereby established as \$1,000 for each calendar day of unauthorized delay in completion of the Work.

BONDS. The Bidder to whom the award is made will be required to submit a payment bond and a performance bond, each in a principal amount not less than one hundred percent (100%) of the total Contract Price.

BIDS. Bidders must comply with and agree to all instructions and requirements in this Notice and in the Instructions to Bidders, including post-bidding procedures.

- A. All Bids must be submitted on the prescribed Bid Form.
- B. Bid security or a bid guaranty bond, in an amount not less than ten percent (10%) of the Total Bid amount, is required to be submitted with the Bid.
- C. Requests for interpretation of the Contract Documents shall be submitted to Josh Wolff in writing to JWolff@slvwd.com no later than 5:00 p.m., January 4, 2023. SLVWD will release a final response to requests for interpretation no later than 5:00 p.m., January 6, 2023.
- D. The successful Bidder shall execute the Contract Agreement within ten (10) work days after the date of the Notice of Award.
- E. The successful Bidder shall furnish insurance in accordance with the Contract Documents before execution of the Contract Agreement. The required insurance includes, but is not limited to, Contractor's Installation All Risk Insurance covering the value of the Work and all materials and equipment to be incorporated therein while at the site and during inland transit insuring the replacement value, subject to a deductible not to exceed \$5,000 for any single loss. This insurance shall also contain an insurer's waiver of subrogation against SLVWD, and it shall specifically cover losses due to earthquake and flooding.
- F. SLVWD may withhold issuance of the Notice to Proceed for a period not to exceed sixty (60) calendar days after the date the Contract Agreement is executed.
- G. The Contractor shall start the Work within ten (10) work days after the date of the Notice to Proceed.
- H. SECURITY SUBSTITUTIONS FOR MONEYS WITHHELD TO INSURE CONTRACTOR'S PERFORMANCE.

In accordance with Section 22300 of the State of California Public Contract Code, the Contractor, at his request and expense, will be permitted to substitute equivalent securities for any monies withheld to ensure performance. Upon satisfactory completion of the Contract, the Contractor shall receive from the escrow agent all securities, interest, and payments received by the escrow agent from SLVWD, pursuant to the terms of Section 22300. Refer to applicable portions of the Escrow Agreement (Section 00630) for Security Deposits in Lieu of Performance Retention included with the Contract Documents. The Contractor shall be the beneficial owner of any securities substituted for moneys withheld and shall receive any interest thereon.

- I. Contractor shall possess a Class 'A' Contractor's License at the time of bid submission and award of the Contract.

- J. Pursuant to Sections 1770 et seq. of the State of California Labor Code, the successful bidder shall pay not less than the prevailing rate of per diem wages as determined by the Director of the Department of Industrial Relations. SLVWD has obtained the general prevailing rate of per diem wages in the locality in which this work is to be performed for each craft or type of worker needed to execute the contract from the Director of the Department of Industrial Relations. These rates are on file at SLVWD located at 13060 CA-9, Boulder Creek, California, 95006 or may be obtained from the State of California, Division of Labor Statistics and Research at (415) 557-0561. Copies may be obtained on request. A copy of these rates shall be posted at the job site.
- K. No contractor or subcontractor may be listed on a bid proposal for a public works project unless registered with the Department of Industrial Relations pursuant to Labor Code section 1725. No contractor or subcontractor may be awarded a contract for public work on a public works project unless registered with the Department of Industrial Relations pursuant to Labor Code section 1725.5. This project is subject to compliance monitoring and enforcement by the Department of Industrial Relations.
- L. SLVWD reserve the right to reject any and all bids.

APPROVAL. This Notice is approved and authorized this 5th day of December, 2022.



Josh Wolff
District Engineer

END OF SECTION 00020

SECTION 00100

INSTRUCTIONS TO BIDDERS

IB-01 **GENERAL**. Sealed bids will be received only to the care of Holly Hossack at 13060 CA-9, Boulder Creek, California, 95006, Telephone (831) 338-2153 for the construction of the Work entitled:

Redwood Park Pipeline Replacement

The Contract Documents will be available for examination without charge, and copies may be secured and examined at SLVWD. Terms used in the Bidding Requirements shall have the meanings defined in the Conditions of the Contract.

IB-02 **EXAMINATION BY BIDDERS**. At his/her own expense and prior to submitting a Bid, each Bidder shall (a) examine the Contract Documents, (b) visit the site and determine the local conditions which in any way affect the performance of the Work, including access to the site, prevailing wages, and other pertaining cost factors, (c) familiarize himself/herself with all Federal, State, and local laws, ordinances, rules, regulations, and codes affecting the performance of the Work, including the cost of permits and licenses required for the Work, (d) make such surveys and investigations, including investigation of subsurface or latent physical conditions at the site or where Work is to be performed, as he/she may deem necessary for performance of the Work at his/her Bid price within the terms of the Contract Documents, (e) determine the character, quality, and quantities of the Work to be performed and the materials and equipment to be provided, and (f) correlate his/her observations, investigations, and determinations with the requirements of the Contract Documents. The Contract Documents show and describe the existing conditions as they are believed to exist, and the surveys, investigations and other data which have been used in the design of the Work. Except as provided otherwise by law or these Contract Documents, neither SLVWD nor the Engineer shall be liable for any loss sustained by the Contractor resulting from any variance between the conditions and design data given in the Contract Documents and the actual conditions revealed during the Bidder's examination or during the progress of the Work. The submission of a Bid shall be incontrovertible evidence that the Bidder has complied with all the requirements of this Section.

IB-03 **QUALIFICATIONS OF BIDDERS**.

- A. At time of bid submission, all Bidders must currently possess a Class 'A' Contractor's License, according to the laws of the State and legal jurisdiction of the place where the Work is located, and meet the qualifications stipulated hereinafter. All Subcontractors desiring to bid on the Work must possess a Contractor's License within their individual specialties.
- B. No person, organization, or corporation is allowed to make, submit, or be interested in more than one Bid for the Work unless in a subcontractor relationship with respect to the Bids or unless Alternative Bids are required. A person, organization, or corporation submitting sub-proposals or quoting prices on materials to Bidders is not prevented from submitting a Bid for the entire Work.

- C. At the time of bid submission, all Bidders must be currently registered with the Department of Industrial Relations ("DIR") and have paid the annual fee pursuant to Section 1725.5 of the California Labor Code.

IB-04 PREPARATION AND SUBMISSION OF BIDS.

- A. Bids shall be submitted on the prescribed Bid Document Forms Volume II bound herein. All bid items and statements shall be properly filled out. Numbers shall be stated both in words and in figures, where so indicated, and the signatures of all persons signing shall be in longhand. Where there is a conflict in the words and the figures, the words will govern. An appropriate Power of Attorney shall be submitted if the Bid is executed by other than an official of the Bidder, showing that signer of Bid has the authority to obligate the Bidder. **BID DOCUMENT VOLUME II MUST BE SUBMITTED AS A WHOLE, BOUND OR STAPLED, AND INTACT. DO NOT REMOVE ANY PAGES FROM BID DOCUMENT VOLUME II. ANY ADDENDA SHALL BE STAPLED TO BID DOCUMENT VOLUME II AND SHALL BECOME A PART OF THIS DOCUMENT. FAILURE TO DO SO WILL RESULT IN AN IMMEDIATE REJECTION OF THE BID. ADDITIONAL SHEETS ARE ALLOWABLE, AND MAY BE STAPLED TO THE BACK OF BID DOCUMENT VOLUME II.**
- B. Prices, wording, and notations must be in ink or typewritten. No erasures will be permitted. Mistakes may be crossed out and corrections typed or written in ink adjacent thereto, and must be initialed in ink by the person or persons signing the Bid or the authorized agent. Any alterations in the Contract Documents not thus initialed will be disregarded.
- C. Bids shall not contain any recapitulation of the Work or change in the phraseology. Unauthorized conditions, limitations or provisions attached to a Bid will render it informal and may cause its rejection. Alternative Bids or Incomplete Bids will not be received or considered unless required by the Contract Documents. No oral, facsimile, or telephonic proposals or modifications will be considered.
- D. Delivery of Bids shall comply with Specific Provisions as to place, date, and time. Bids shall be enclosed in a sealed opaque envelope bearing the Work title.
- E. In the event that the Bidder is a joint venture, there shall be submitted with the Bid, certifications signed by authorized officers of each of the parties to the joint venture, naming the individual who shall be the agent of the joint venture. The individual shall sign all necessary documents for the joint venture, and should the joint venture be the successful Bidder, shall act in all matters relative to the Contract resulting therefrom for the joint venture.
- F. Mailed Bids sent via the U.S. Postal Service shall be Registered or Certified Mail, Return Receipt Requested. The return receipt will be endorsed to show the date and time received. Bids submitted using other delivery services shall require a similar signature upon delivery with a time-stamped receipt. Mailed Bids not received at the required place before the date and time set for the receipt of Bids will be rejected. Misdirection of mailed Bids resulting in receipt of the Contractor's

Bid after the required date and time will render the Bid non-responsive and will result in rejection of the Bid.

IB-05 WITHDRAWAL OF BIDS. Any Bidder may withdraw his Bid prior to the date and time set for the receipt of Bids, either in person or by written notice delivered to SLVWD before said date and time. Faxed withdrawal notices are not allowed. Mailed withdrawal notices must be received before said date and time. Misdirection of mailed withdrawal notices resulting in receipt of said notice after the date or time set for receipt of Bids will render the withdrawal notice invalid.

IB-06 INTERPRETATIONS. Should any Bidder find discrepancies in or omissions from the Contract Documents, or if there should be doubt as to the true meaning of any part thereof, the Bidder shall at once submit a written request for correction, clarification, or interpretation. Such requests shall be submitted in writing to SLVWD to JWolff@slvwd.com no later than the date and time specified in the Notice Inviting Bids, Section 00020.

- A. If SLVWD or the Engineer determines the Contract Documents require changes, correction, clarification, or interpretation prior to the receipt of Bids, an appropriate Addendum will be issued.
- B. SLVWD, the Engineer, and their officers, employees, and agents will not be responsible for any changes, instructions, clarifications, interpretations, or other information pertaining to the Contract Documents given to Bidders during the bidding period in any manner other than written Addendum.

IB-07 BID PRICES.

- A. Bid prices shall be stated in United States dollars.
- B. Each proposed lump sum or unit price shall cover all costs and charges, including without limitation the costs of materials, labor, fabrication, construction, delivery, installation or application, supervision, insurance charges, overhead, profit, and taxes.
- C. No separate payment will be made for items other than those on the Bid Proposal Form unless specifically mentioned in these Contract Documents. The costs of overhead, administration, materials, equipment, supplies, insurance, bonds, meetings, temporary facilities, construction utilities, quality control not otherwise specified, and all other such items specified, indicated, or otherwise required to complete the Work, shall be included in the unit prices and/or lump sum prices.
- D. The Bid price for mobilization shall not exceed five percent (5%) of the cumulative total price for all other items identified in the Bid Proposal Form. (See Section 01200 regarding mobilization.)

IB-08 SUBCONTRACTOR LIST. Each Bidder shall list in the spaces provided in the Bid Proposal Form: (1) the name and business address of each Subcontractor proposed to perform or render service for a portion of the Work, or to specially fabricate and install a portion of the Work, if the value of such subcontracted portion exceeds one-half of one percent (0.5%) of the Bidder's total aggregate Bid amount, and (2) the portion of the

Work to be performed by each proposed Subcontractor. Only one Subcontractor shall be listed for each portion of the Work so defined by the Bidder. Proposed Subcontractors must be licensed according to the State and jurisdiction where the Work is located. Proposed Subcontractors must be registered with the DIR and have paid the annual fee pursuant to Section 1725.5 of the California Labor Code. No change may be made to the listing after receipt of Bids without the written consent of SLVWD.

IB-09 ADDENDA. Full consideration shall be given to all Addenda in the preparation of Bids, as Addenda form a part of the Contract Documents. Bidders shall verify the number of Addenda issued, if any, and acknowledge the receipt of all Addenda in the Bid. Failure to so acknowledge may cause the Bid to be rejected. Addenda may modify previously issued Addenda. No Addendum will be issued within 72 hours of the advertised Bid closing date and time without an appropriate adjustment to the Bid closing date and time.

IB-10 AWARD. Bids will be publicly opened and read aloud at SLVWD. Award of the Contract or the rejection of Bids will be made during the time accorded to review Bids.

- A. The Contract for the Work, if awarded, will be awarded to the eligible Bidder submitting the lowest responsive responsible Bid complying with these Instructions to Bidders, and other bidding requirements in the Contract Documents. By submitting a Bid, each Bidder agrees and consents that SLVWD, in determining the successful Bidder and his eligibility for the award, may ascertain and consider the Bidder's experience and facilities, conduct and performance under other contracts, financial condition, reputation in the industry, and other factors which could affect the Bidder's performance of the Work.
- B. The lowest Bid will be determined based on the Total Bid amount identified on all Bids received by SLVWD.
- C. The successful Bidder shall execute the Contract Agreement within ten (10) work days after the date of the Notice of Award. The contract time is hereby established as consecutive work days from the date of receipt of the Notice to Proceed. Bidder shall furnish Proof of Insurance as required herein, and the Contract Agreement shall be executed in the form provided by SLVWD.
- D. If a Bidder receiving a Notice of Award fails or refuses to execute the Contract Agreement within the stated time limit or fails or refuses to furnish Proof of Insurance as required herein, SLVWD may annul the award and issue an award to the next lowest responsive responsible Bidder or may reject all Bids.
- E. A corporation receiving the award shall furnish evidence of its corporate existence and evidence that the person signing the Contract Agreement for the corporation is duly authorized to do so.

IB-11 INSURANCE. The successful Bidder shall furnish to SLVWD evidence of insurance ensuring the payment of all obligations arising from the Work. Insurance shall comply with the requirements in the General Conditions. Insurance certificates shall be delivered to SLVWD at the time and place the Contract Agreement is executed.

- IB-12 RIGHTS RESERVED. SLVWD reserves the right to reject any or all Bids, to waive any informality or irregularity in any Bid, to have performed the entire Work defined by the Contract Documents or such parts of said Work as SLVWD may elect, to combine various alternative bids and bid items within a Bid, and to accept or reject one or more separately scheduled bid items within a Bid. SLVWD further reserves the right to withhold issuance of the Notice to Proceed, after execution of the Contract Agreement, for the period not to exceed sixty (60) calendar days after the date the Contract Agreement is executed. No additional payment will be made to the successful Bidder on account of such withholding.
- IB-13 LOCAL WAGE RATES. In accordance with the laws of the state Department of Industrial Relations and jurisdiction where the Work is located, SLVWD has determined and adopted the general prevailing per diem wages, including wages for overtime and holiday work, for each craft or type of workman needed in the execution of the Work. Said wages shall be the minimum paid to workmen employed for the Work. Copies of the wage determination are on file and may be obtained by interested parties at San Lorenzo Valley Water District, 13060 CA-9, Boulder Creek, California 95006
- IB-14 SEPARATE BID PRICE FOR EXCAVATION SAFETY MEASURES. If it is necessary for the Contractor to perform an excavation of 5 ft or more, then the requirements of Sections 6705 and 6707 of the California Labor Code apply to this Project. Accordingly, each Bidder shall state in the Bid the lump sum bid price for providing shoring, sheeting, bracing, and other safety measures for all excavations five (5) feet or more in depth. Before any Work is commenced, the Contractor shall secure and pay for the excavation permit required by the California Division of Occupational Safety and Health, and shall furnish SLVWD with a copy thereof prior to commencing any excavation. The Contractor shall conform to Labor Code Section 6705 by submitting a detailed plan showing the design of shoring, bracing, sloping, or other provisions to be made for worker protection from the hazard of caving ground during the excavation of such excavations, trench or trenches, or during the pipe installation therein. This plan must be prepared for all trenches five feet or more in depth, submitted by the Contractor, and accepted by SLVWD or by a registered civil or structural engineer employed by SLVWD to whom the authority to accept has been delegated, in advance of excavation. If the plan varies from the shoring system standards established by the Construction Safety Orders, the plan shall be prepared by a registered civil or structural Engineer at the Contractor's expense.

END OF SECTION 00100

SECTION 00500

CONTRACT AGREEMENT

THIS CONTRACT AGREEMENT is made this ____ day of _____, 202__, by and between San Lorenzo Valley Water District, a California County Water District, with its principal place of business located at 13060 CA-9, Boulder Creek, CA 95006, hereinafter referred to as "SLVWD," and

_____, a _____,
_____, License Number _____, with its principal place of business located at _____, hereinafter referred to as "Contractor." SLVWD and Contractor are referred to herein collectively as the "Parties", or individually, a "Party." Any capitalized terms used herein that are not defined in this Contract Agreement have the meanings set forth in the Contract Documents.

WITNESSETH

WHEREAS, SLVWD has caused Specifications, Drawings, and other Contract Documents to be prepared for certain Work referred to, in short, as the

Redwood Park Pipeline Replacement;

WHEREAS, Contractor has offered to perform the Work in accordance with all the terms and conditions of the Contract Documents;

NOW, THEREFORE, in consideration of the mutual covenants and agreements of the Parties herein contained and to be performed, Contractor hereby agrees to complete the Work at the prices and on the terms and conditions herein contained, and SLVWD hereby hires Contractor and agrees to pay the Contract Price provided herein to Contractor for the fulfillment of the Work and the performance of the covenants set forth herein.

1. The Contract Time is hereby established as 180 calendar days. The Contract Time shall be consecutive calendar days from the date of receipt of the Notice to Proceed.

2. The further terms, conditions and covenants of this Contract Agreement are set forth in the Contract Documents, each of which is incorporated herein by this reference made a part of the Contract. The Contract Documents (defined in the General Conditions) include without limitation the following exhibit parts:

- Legal and procedural documents, inclusive of this Contract Agreement and all notices, instructions, and forms issued to Bidders in the Bidding Requirements for the submittal of Bids, the Contractor's Bid, and the Bid security;
- Conditions of the Contract (inclusive of General, Supplementary, Special, and other Conditions);
- Specifications, including Technical Specifications;
- Drawings;
- Addenda and all Modifications, if any;
- Notice of Award; and

- Notice to Proceed.

3. For each calendar day of unauthorized delay in completion of the Work, Contractor shall be assessed liquidated damages pursuant to the terms of the Contract Documents including without limitation section 4.4 of the General Conditions. Liquidated damages shall be construed in accordance with Government Code Section 53069.85.

4. This Contract Agreement may be executed in counterparts each of which shall be deemed an original but all of which shall constitute one and the same instrument.

[SIGNATURES ON FOLLOWING PAGE(S)]

IN WITNESS WHEREOF, this Contract Agreement has been executed on the day and year first above written.

**SAN LORENZO VALLEY
WATER DISTRICT**

License No.: _____

By: _____
Rick Rogers, District Manager

By: _____
***Signature**

Name/Title (Please Print)

ATTEST:

ATTEST:

By: _____
Holly Hossack, District Secretary

By: _____
Signature

Name/Title (Please Print)

APPROVED AS TO FORM:

By: _____
Gina Nicholls, District Counsel
Nossaman, LLP

****Signature must be accompanied by notarized document citing the individual's relationship to the Party of the Contract and his/her power to sign on behalf of the Party.***

END OF SECTION 00500

SECTION 00600

NOTICE OF AWARD

To: _____
(Contractor)

Project: **Redwood Park Pipeline Replacement**

Your Bidder's Proposal dated _____, 2022, is accepted.

You are required by the Notice and Instructions to Bidders to execute the Contract Documents within ten (10) work days of the date of mailing of this notice (not including Sundays and holidays).

Received:

_____ Contractor	_____ San Lorenzo Valley Water District SLVWD
By: _____	By: _____
_____ Name /Title:	_____ Rick Rogers, District Manager Name/Title:
Date: _____	Date: _____

END OF SECTION 00600

SECTION 00610

PERFORMANCE BOND

KNOW ALL MEN AND WOMEN BY THESE PRESENTS:

THAT _____, hereinafter called Principal, and _____ hereinafter called Surety, are jointly and severally held and firmly bound unto the San Lorenzo Valley Water District, 13060 CA-9, Boulder Creek, CA 95006, hereinafter called SLVWD, its successors and assigns in the penal sum of _____ Dollars (\$_____) lawful money of the United States, for the payment whereof until, the Principal and Surety jointly and severally bind themselves, their heirs, executors, administrators, and successors, jointly and severally, forever firmly by these presents.

WHEREAS, SLVWD has awarded to Principal the Work entitled:

Redwood Park Pipeline Replacement (the "Contract"), and

WHEREAS, Principal is required under the terms of the Contract to furnish a bond for the faithful performance of the Contract,

NOW, THEREFORE, the condition of this obligation is such that if Principal shall faithfully perform the covenants, conditions, and agreements in the Contract and any changes made as therein provided, at the time and in the manner therein specified, and in all respects according to their true intent and meaning, and shall indemnify and save or hold harmless SLVWD, its directors, officers, employees, Engineer, and agents as therein stipulated, then this obligation shall become null and void; otherwise, it shall remain in full force and virtue, and Principal and Surety, in the event suit is brought on this bond, will pay to SLVWD sufficient funds to complete the Scope of Work required by the Contract.

As a condition precedent to the satisfactory completion of the Contract, the above obligation shall hold good for a period of not less than one (1) year after the completion of the Work and its acceptance by SLVWD, during which time if Principal, his/her or its heirs, executors, administrators, successors, or assigns shall fail to make full, complete, and satisfactory repair and replacements and totally protect SLVWD from loss or damage made evident during the period of not less than one (1) year from the date of acceptance of the Work, and resulting from or caused by defective materials and/or faulty workmanship, the above obligation in penal sum thereof shall remain in full force and effect. However, notwithstanding anything in this paragraph to the contrary, the obligation of Surety hereunder shall continue so long as any obligation of Principal remains.

AND, Surety, for value received, hereby stipulates and agrees that no change, extension of time, alteration of addition to the terms of the Contract or to the Work to be performed there under or the Specifications and Drawings accompanying the same, shall in any way affect its obligations to this bond, and it does hereby waive notice of any such change,

extension of time, alteration or addition to the terms of the Contract or to the Work or to the Drawings and Specifications. The Surety hereby waives the provisions of Sections 2819 and 2845 of the Civil Code of the State of California.

As part of the obligation secured hereby and in addition to the amount specified therefore, there shall be included costs and reasonable expenses and fees, including reasonable attorneys' fees and court costs, incurred by SLVWD in successfully enforcing any and all obligations hereunder, all to be taxed as costs and included in any judgment rendered.

AND IT IS HEREBY DECLARED AND AGREED that this obligation shall be binding upon and inure to the benefit of Principal, Surety, and SLVWD and their respective heirs, executors, administrators, successors, and assigns.

SIGNED AND SEALED THIS _____ day of _____, 2022

Principal

By: _____
Signature

Surety

By: _____
Signature

(Surety's Mailing Address)

(Telephone Number)

(Attach Notary Acknowledgement of Surety)

Approved as to form this _____ day of _____, _____.

Attorney for SLVWD

NOTE: *The principal amount of this bond shall not be less than one hundred percent (100%) of the total Contract Price.*

END OF SECTION 00610

SECTION 00620

PAYMENT BOND

KNOW ALL MEN AND WOMEN BY THESE PRESENTS:

THAT _____, hereinafter called Principal, and _____, hereinafter called Surety, are jointly and severally held and firmly bound unto the San Lorenzo Valley Water District, 13060 CA-9, Boulder Creek, CA 95006, hereinafter called SLVWD, its successors and assigns in the penal sum of _____ Dollars (\$ _____) lawful money of the United States, for the payment whereof unto SLVWD, the Principal and Surety jointly and severally bind themselves, their heirs, executors, administrators, and successors, jointly and severally, forever firmly by these presents.

WHEREAS, SLVWD has awarded to Principal the Work entitled:

Redwood Park Pipeline Replacement (the "Contract"), and

WHEREAS, said Principal is required to furnish a Payment Bond in connection with said Contract.

NOW, THEREFORE, the condition of this obligation is such that if said Principal, his/her or its heirs, executors, administrators, successors, or assigns, or any of his/her or its Subcontractors, shall fail to pay any of the persons named in Civil Code Section 3181, or amounts due under the Unemployment Insurance Code with respect to work or labor performed under the Contract, or for any amounts required to be deducted, withheld, and paid over to the Franchise Tax Board from the Wages of employees of the Principal and his/her subcontractors pursuant to Section 18668 of the Revenue and Taxation Code, with respect to such work and labor, or any amounts required to be deducted, withheld, and paid over the Employment Development Department from the wages of employees of the Principal and Subcontractors pursuant to Section 13020 of the Unemployment Insurance Code with respect to the work and labor, or for any work or labor for which a bond is required by the provisions of Sections 3247 through 3252 of the Civil Code, and provided that the persons, companies, or corporations so furnishing said materials, provisions, or other supplies, appliances, owned or used, in, upon, for, or about the performance of the work contracted to be executed or performed, or any person who performs work or labor upon the same, or any person who supplies both work and materials, thereto, shall have complied with the provisions of the Civil Code, then the Surety will pay the same or an amount not exceeding the amount herein above set forth, and also will pay in case suit is brought upon this bond, reasonable attorneys' fees and costs of SLVWD as shall be fixed by the court.

This bond shall insure to the benefit of any and all persons, companies, and corporations entitled to file claims under Section 3181 of the Civil Code, so as to give a right of action to them or their assigns in any suit brought upon this bond.

And the Surety, for value received, hereby stipulates and agrees that no change, extension of time, alteration or addition to the terms of the Contract, or to the Work to be performed thereunder, or the Drawings and Specifications accompanying the same shall in any way affect its obligations on this bond, and it does hereby waive notice of any such change, extension of time, alteration or addition to the terms of the Contract or to the Work or to the Drawings and Specifications.

The Surety hereby waives the provisions of Sections 2819 of the Civil Code.

AND IT IS HEREBY DECLARED AND AGREED that this obligation shall be binding upon and inure to the benefit of Principal, Surety, and SLVWD and their respective heirs, executors, administrators, successors, and assigns.

SIGNED AND SEALED THIS _____ day of _____, _____.

Principal

By: _____
Signature

Surety

By: _____
Signature

(Surety's Mailing Address)

(Telephone Number)

(Attach Notary Acknowledgement of Surety)

Approved as to form this _____ day of _____, _____.

Attorney for SLVWD

NOTE: *The principal amount of this bond shall not be less than one hundred percent (100%) of the total Contract Price.*

END OF SECTION 00620

SECTION 00630

ESCROW AGREEMENT FOR SECURITY DEPOSIT IN LIEU OF RETENTION

This Escrow Agreement is made and entered into by and between San Lorenzo Valley Water District (SLVWD) whose address is 13060 CA-9, Boulder Creek, CA 95006 hereinafter called "SLVWD" and _____ whose address is _____ hereinafter called "Contractor," and _____ whose address is _____ hereinafter called "Escrow Agent."

For the consideration hereinafter set forth, SLVWD, Contractor, and Escrow Agent agree as follows:

(1) Pursuant to Section 22300 of the Public Contract Code of the State of California, Contractor has the option to deposit securities with an Escrow Agent as a substitute for retention earnings required to be withheld by SLVWD, pursuant to the Construction Contract entered into between SLVWD and Contractor for:

Redwood Park Pipeline Replacement

in the amount of _____ dated _____ (hereinafter referred to as the "Contract"). Alternatively, on written request of the Contractor, SLVWD shall make payments of the retention earnings directly to the Escrow Agent. When Contractor deposits the securities as a substitute for Contract earnings, the Escrow Agent shall notify SLVWD within ten (10) calendar days of the deposit. The market value of the securities at the time of the substitution shall be at least equal to the cash amount then required to be withheld as retention under the terms of the Contract between SLVWD and Contractor. Securities shall be held in the name of SLVWD, and shall designate the Contractor as the beneficial owner.

(2) SLVWD shall make progress payments to the Contractor for such funds which otherwise would be withheld from progress payments pursuant to the Contract provisions, provided that the Escrow Agent holds securities in the form and amount specified above.

(3) When SLVWD makes payment of retention earned directly to the Escrow Agent, the Escrow Agent shall hold them for the benefit of the Contractor until such time as the escrow created under this Contract is terminated. The Contractor may direct the investment of the payments into securities. All terms and conditions of this agreement and the rights and responsibilities of the parties shall be equally applicable and binding when SLVWD pays the Escrow Agent directly.

(4) Contractor shall be responsible for paying all fees for the expenses incurred by Escrow Agent in administering the Escrow Account and all expenses of SLVWD. These expenses and payment terms shall be determined by SLVWD. Contractor and Escrow Agent.

(5) The interest earned on the securities or the money market accounts held in escrow and all interest earned on that interest shall be for the sole account of Contractor and shall be subject to withdrawal by the Contractor at any time and from time to time without notice to SLVWD.

(6) Contractor shall have the right to withdraw all or any part of the principal in the Escrow Account only by written notice to Escrow Agent accompanied by written authorization from SLVWD to the Escrow Agent that SLVWD consents to the withdrawal of the amount sought to be withdrawn by Contractor.

(7) SLVWD shall have a right to draw upon the securities in the event of default by the Contractor. Upon seven (7) calendar days' written notice to the Escrow Agent from SLVWD of the default, the Escrow Agent shall immediately convert the securities to cash and shall distribute the cash as instructed by SLVWD.

(8) Upon receipt of written notification from SLVWD certifying that the Contract is final and complete, and that the Contractor has complied with all requirements and procedures applicable to the Contract, Escrow Agent shall release to Contractor all securities and interest on deposit less escrow fees and charges of the Escrow Account. The escrow shall be closed immediately upon disbursement of all moneys and securities on deposit and payments of fees and charges.

(9) Escrow Agent shall rely on the written notifications from SLVWD and the Contractor pursuant to Sections (5) to (8), inclusive, of this agreement and SLVWD and Contractor shall hold Escrow Agent harmless from Escrow Agent's release and disbursement of the securities and interest as set forth above.

(10) The names of the persons who are authorized to give written notice or to receive written notice on behalf of SLVWD and on behalf of Contractor in connection with the foregoing, and exemplars of their respective signatures are as follows:

On behalf of SLVWD:

District Manager

Title

Rick Rogers

Name

Signature

13060 CA-9, Boulder Creek, California 95006

Address

On behalf of Contractor:

Title

Name

Signature

Address

On behalf of Escrow Agent:

Title

Name

Signature

Address

Redwood Park Pipeline Replacement
December 5, 2022

Escrow Agreement for Security Deposit in Lieu
00630-3

At the time the Escrow Account is opened, SLVWD and Contractor shall deliver to the Escrow Agent a fully executed counterpart of this Agreement.

IN WITNESS WHEREOF, the parties have executed this Agreement by their proper officers on the date first set forth above.

San Lorenzo Valley Water District

Contractor

Title

Title

Name

Name

Signature

Signature

END OF SECTION 00630

SECTION 00640

CERTIFICATE OF CONTRACTOR

I, _____, certify that I am a/the
_____ (designate sole proprietor, partner in partnership, or specify
corporate office, e.g., secretary) in the entity named as Contractor in the foregoing Contract. I
hereby expressly certify that the name of the entity to which I am associated is
_____; that this
entity is in good standing and has complied with all applicable laws and regulations, and that I
have been expressly authorized by the proper parties in this entity to execute this contract on
behalf of the above-named entity.

Date

By: _____
Signature

Name/Title (Please Print)

ATTEST:

By: _____
Signature

Name/Title (Please Print)

END OF SECTION 00640

SECTION 00645

CONTRACTOR'S CERTIFICATION
REGARDING WORKERS' COMPENSATION

Description of Contract: **Redwood Park Pipeline Replacement.**

Labor Code Section 3700:

Every employer except the State shall secure the payment of compensation in one or more of the following ways:

- (a) By being insured against liability to pay compensation by one or more insurers duly authorized to write compensation insurance in this State.
- (b) By securing from the Director of Industrial Relations a certificate of consent to self-insure, either as an individual employer or as one employer in a group of employers, which may be given upon furnishing proof satisfactory to the Director of Industrial Relations of ability to self-insure and to pay any compensation that may become due to his or her employees.
- (c) For any county, city, municipal corporation, public district, public agency, or any political subdivision of the state, including each member of a pooling arrangement under a joint exercise of powers agreement (but not the state itself), by securing from the Director of Industrial Relations a certificate of consent to self-insure against workers' compensation claims, which certificate may be given upon furnishing proof, satisfactory to the director, of ability to administer workers' compensation claims that may become due to its employees. On or before March 31, 1979, a political subdivision of the state which, on December 31, 1978, was uninsured for its liability to pay compensation, shall file a properly completed and executed application for a certificate of consent to self-insure against workers' compensation claims. The certificate shall be issued and be subject to the provisions of Section 3702.

For the purposes of this section, "state" shall include the superior courts of California.

I am aware of the provisions of Section 3700 of the Labor Code which require every employer to be insured against liability for workers' compensation or to undertake self-insurance in accordance with the provisions of that code, and I will comply with such provisions before commencing the performance of the work of this contract.

Dated: _____, ____

By: _____
(Contractor)

By: _____
(Authorized Representative of Contractor)

(Seal of Corporation)

Name/Title: _____
(Please Print)

Redwood Park Pipeline Replacement
December 5, 2022

Contractor's Certification Regarding Workers' Compensation
00645-2

(Labor Code Section 1861 provides that the above certificate must be signed and filed by the Contractor with SLVWD prior to performing any work under this Contract.)

END OF SECTION 00645

Section 00648

Information Pursuant to California Labor Code Section 2810.

1. The name, address, and telephone number of SLVWD is:

San Lorenzo Valley Water District
13060 CA-9
Boulder Creek, California 95006
(831) 338-2153

2. The name, address, and telephone number of the Contractor is:

3. A description of the labor or services to be provided is stated in the Contract Documents, including but not limited to Section 01100, Summary of the Work.
4. The Contract Time is stated in the Contract Documents, including but not limited to Section 00500, Contract Agreement.
5. The Contractor's employer identification number for state tax purposes is

_____.

6. The workers' compensation insurance policy and the name, address, and telephone number of the insurance carrier of the Contractor is:

Workers' Compensation Insurance Policy
Number: _____

Insurance Carrier Name: _____

Insurance Carrier
Address: _____

Insurance Carrier Telephone Number: _____

7. The vehicle identification ("VIN") for any vehicle that is owned by the Contractor and used for transportation in connection with any service provided pursuant to this Contract, the number of the vehicle liability insurance policy that covers the vehicle, and the name, address, and telephone number of the insurance carrier are as follows:

VIN: _____

Vehicle Liability Insurance Policy
Number: _____

Insurance Carrier Name: _____

Insurance Carrier
Address: _____

Insurance Carrier Telephone Number: _____

VIN: _____

Vehicle Liability Insurance Policy
Number: _____

Insurance Carrier Name: _____

Insurance Carrier
Address: _____

Insurance Carrier Telephone Number: _____

VIN: _____

Vehicle Liability Insurance Policy
Number: _____

Insurance Carrier Name: _____

Insurance Carrier
Address: _____

Insurance Carrier Telephone Number: _____

VIN: _____

Vehicle Liability Insurance Policy
Number: _____

Insurance Carrier Name: _____

Insurance Carrier
Address: _____

Insurance Carrier Telephone Number: _____

8. The address of any real property to be used by the Contractor to house workers in connection with the Contract is:

_____.

9. The total number of workers to be employed by the Contractor to perform labor or services under this Contract is _____.

- a. If the information pursuant to paragraph 9, above, is unknown, the Contractor shall provide the best estimate available at the time.
- b. If a best estimate is provided, the Contractor shall have a continuing duty to ascertain the actual figures and provide SLVWD with written notice of those actual figures once that information becomes known.

10. The total amount of all wages to be paid, and the date or dates when those wages are to be paid are:

- a. If the information pursuant to paragraph 10, above, is unknown, the Contractor shall provide the best estimate available at the time.
- b. If a best estimate is provided, the Contractor shall have a continuing duty to ascertain the actual figures and provide SLVWD with written notice of those actual figures once that information becomes known.

11. The total compensation for all services which the Contractor is obligated to perform under the terms and conditions of this Contract is _____.

12. The total number of persons who will be utilized by the Contractor under this Contract as independent contractors, along with a list of any current local, state, and federal contractor license identification numbers that the independent contractors are required to have under local, state, or federal laws or regulations.

Name of Independent
Contractor:

Contractor's License
Number(s):

Name of Independent
Contractor:

Contractor's License
Number(s):

Name of Independent
Contractor:

Contractor's License
Number(s): _____

Total Number of Persons Utilized as Independent Contractors: _____.

- a. If the information pursuant to paragraph 12, above, is unknown, the Contractor shall provide the best estimate available at the time.
- b. If a best estimate is provided, the Contractor shall have a continuing duty to ascertain the actual figures and provide SLVWD with written notice of those actual figures once that information becomes known.

END OF SECTION 00648

SECTION 00650

NOTICE TO PROCEED

To: _____
(Contractor)

Date: _____

Project: **Redwood Park Pipeline Replacement**

You are notified that the Contract Times under the above contract will commence to run on_____, 202_. On or before that date, you are to start performing your obligations under the Contract Agreement dated____, 202_. In accordance with the Contract Agreement, the date of Final Completion is_____.

Before you may start any Work at the Site, you must:

1. Provide product submittals for the water tanks, valves, pipes and appurtenances, and receive approval of these products from the District, and
2. Obtain the required permits from Santa Cruz County and other jurisdictions listed in the contract documents.

SLVWD

By: Rick Rogers

Title: District Manager

ACCEPTANCE OF NOTICE

Receipt of the above Notice to Proceed is hereby acknowledged by _____
this the _____ day of _____, _____.

Name: _____
(Print)

By: _____

Title: _____

END OF SECTION 00650

SHOP DRAWING SUBMITTAL FORM

Submittal No. _____ Specifications Section: _____

Submittal Description: _____

PROJECT INFORMATION	ROUTING	DATE
Owner: San Lorenzo Valley Water District	Contractor to C.M.	
Project Name: Redwood Park Pipeline Replacement	C.M. to Engineer	
Project No.:	Engineer to C.M.	
Contractor:	C.M. to Contractor	

We are sending you: _____ Attached _____ Under Separate Cover Via _____

Other: _____

_____ Submittals for Approval (Submit a minimum of 8 copies for approval).

_____ Product Data for Information Only (Submit a minimum of 8 copies).

Item	Copies	Date	Section No.	Description	Review/Action

Contractor to Certify either A or B:

_____ A. We have verified that the material or equipment contained in this submittal meets all requirements, including coordination with all related work, as specified (no exceptions).

_____ B. We have verified that the material or equipment contained in this submittal meets all the requirements specified, except for the following (or attached) deviations:

Certified By: _____

Contractor's Signature

Date Signed _____

END OF SECTION 00652

REQUEST FOR INFORMATION

RFI DATA/INFORMATION	
Originator	Date Transmitted:
Directed To:	Date Received:
Drawing Reference:	Date Reply Transmitted:
Specification Section:	Date Reply Received:
Subject:	
Date Reply Required:	
Message:	
Originator:	Date
Reply:	
Reply By:	Date:

END OF SECTION 00654

SECTION 00656

**AUTHORIZATION OF ENGINEERING COSTS FOR
EVALUATION OF SUBSTITUTES AND EQUALS**

To: _____
Contractor

Date: _____

PROJECT NAME: **Redwood Park Pipeline Replacement**

We have received a submittal for _____
on _____. The equipment submitted is being
substituted as being "equal" to the equipment originally specified. Per the General Conditions or
the Contract Documents, the Contractor shall pay for the San Lorenzo Valley Water District
(SLVWD) effort in establishing the quality of the submitted equipment and the suitability for the
intended purpose. The estimated time to review this submittal is hours at an hourly rate of
\$_____ Dollars, for a total cost of \$_____ dollars. Before any work can be
done on this review submittal, a signed copy of this authorization form must be received from the
Contractor by SLVWD. The starting date for the submittal review shall be the date that SLVWD
receives the signed authorization from the Contractor.

San Lorenzo Valley Water District, GM

APPROVED:

Contractor

Date

Distribution of Executed Document: SLVWD, District Manager
 SLVWD, District Engineer
 Contractor

END OF SECTION 00656

SECTION 00658

**AUTHORIZATION OF ENGINEERING COSTS FOR
REDESIGN DUE TO SUBSTITUTIONS AND EQUALS**

To: _____
Contractor

Date: _____

PROJECT NAME: **Redwood Park Pipeline Replacement**

As a result of the contractor's request to use the substitution (or equal) titled _____, the following redesign is required to adjoining and/or related Work shown on the Plans and referred to in the Specifications as _____.

The cost of the required engineering redesign work is detailed as follows:

Work Description	Labor Hours	Hourly Rate	Total Cost
1.		\$	\$
2.		\$	\$
3.		\$	\$
4.		\$	\$
TOTAL AUTHORIZED AMOUNT.....\$			

Before any work can be completed on this redesign effort, a signed copy of this authorization form must be received from the Contractor by SLVWD. The starting date for this redesign shall be the date that SLVWD receives the signed authorization from the Contractor.

APPROVED:

San Lorenzo Valley Water District, GM

Contractor

Date

Distribution of Executed Document: SLVWD, District Manager
 SLVWD, District Engineer
 Contractor

END OF SECTION 00658

CONTRACTOR RELEASE

Name of Contractor: _____

Period Work Performed: _____

RETENTION AMOUNT FOR THIS PERIOD: \$ _____

DESCRIPTION OF CLAIM

AMOUNT CLAIMED[illegible]

Contractor further certifies, warrants, and represents that all bills for labor, materials, and work due Subcontractors for the specified period have been paid in full and that the parties signing below on behalf of Contractor have express authority to execute this release.

Redwood Park Pipeline Replacement
December 5, 2022

Contractor Release
00660-2

Dated: _____

(Print Name of Contractor)

(Describe Entity: Partnership, Corporation, etc.)

By: _____

By: _____

By: _____

END OF SECTION 00660

SECTION 00686

UNCONDITIONAL RELEASE AND CERTIFICATE OF FINAL PAYMENT

To: San Lorenzo Valley Water District
13060 CA-9
Boulder Creek, CA 95006

Project No. _____

Contract Dated _____

CONTRACTOR:

Name: _____

Address: _____

DESCRIPTION OF PROJECT: The project consists of providing new water mains and residential water services along Country Club Drive and Woodland Drive in Ben Lomond, CA with associated fittings and valves. Provide and install approximately 1260-LF of 8-inch ductile iron pipe water main, approximately 44-LF of 6-inch ductile iron pipe water main, approximately 31-LF of 4-inch ductile iron pipe water main, and reconnect 4 existing residential water services. Provide traffic control during the work.

DESCRIPTION OF SITE (LOCATION): Unincorporated Santa Cruz County

With reference to said Contract, as amended, between the undersigned Contractor and SLVWD, the Undersigned hereby certifies and represents that it has made full payment of all costs, charges, and expenses incurred by it or on its behalf for work, labor, services, materials, and equipment supplied to the foregoing site and/or used in connection with its work under said Contract.

The undersigned further certifies that to its best knowledge and belief, each of its subcontractors and material suppliers has made full payment of all costs, charges, and expenses incurred by them or on their behalf for work, labor, services, materials, and equipment supplied to the foregoing site and/or used by them in connection with the Undersigned's work under said Contract.

In consideration of \$ _____ as final payment under the Contract, the Undersigned hereby unconditionally and forever discharges, waives, and releases SLVWD and the site and property from all claims, stop notices, liens, bond rights, and obligations and rights of every nature arising out of or in connection with the performance of the said Contract and all amendments thereto except as set forth below:

NOTE: If none, write "NONE" in space above. (Any claims excepted must be described and the specific amount claimed must be set forth.)

Unless any claims, stop notices, liens, bond rights, and obligations or rights are described and the specific amounts claimed, are described in the space above, Contractor certifies that there are none.

As additional consideration for the final payment, the Contractor agrees to indemnify and hold harmless SLVWD from and against all costs, losses, damages, claims, causes of action, judgments, and expenses, including attorney's fees arising out of or in connection with claims against SLVWD which arise out of the performance of the Work under the Contract and which may be asserted by the Contractor or any of its suppliers, subcontractors of any tier or any of their representatives, officers, agents, or employees, except for those claims listed above.

The foregoing shall not relieve the Undersigned of its obligations under the provisions of said Contract, as amended, which by their nature survive completion of the work including, without limitation, warranties, guarantees, and indemnities.

Redwood Park Pipeline Replacement
December 5, 2022

Release and Certificate of Final Payment
00686-3

Executed this _____ day of _____, 20__.

(Name of Contractor)

By: _____

Title: _____

(Attach Notary Acknowledgement)

Distribution:

Original	-	County Recorder
Copy	-	Contractor

END OF SECTION 00686

RECORDING REQUESTED BY:

San Lorenzo Valley Water District

WHEN RECORDED RETURN TO:

San Lorenzo Valley Water District
13060 CA-9
Boulder Creek, California 95006

MAIL TAX STATEMENTS TO:

NO FEE REQUIRED PER GOVERNMENT
CODE SECTION 27383

SECTION 00687

NOTICE OF COMPLETION

To: _____ Date: _____

Project No.: _____

Owner: San Lorenzo Valley Water District
13060 CA-9
Boulder Creek, CA 95006
Date of Completion: _____

OWNER'S ESTATE OF INTEREST:

Easement _____ Fee Title _____ Encroachment Permit _____

Other (describe) _____

CONTRACTOR FOR WORK OF IMPROVEMENT AS A WHOLE:

Name: _____

Address: _____

TITLE OF PROJECT: Redwood Park Pipeline Replacement

DESCRIPTION OF PROJECT: Replace 1335-LF of existing water mains with fittings
Valves and domestic services

LEGAL DESCRIPTION OF SITES: Roads within unincorporated Santa Cruz County

ADDRESS OF THE SITES: Roads within unincorporated Santa Cruz County
Country Club Drive and Woodland Drive in Ben Lomond, CA

This Notice is given for (check one):

- ☐ Completion of the work of improvement as a whole.
☐ Completion of a contract for a particular portion of the work of improvement (per Cal. Civ. Code § 8186).

If this notice is given only of completion of a contract for a particular portion of the work of improvement, the name and address of the direct contractor under that contract is:

Final payment will be made to the above contractor on or after thirty-five (35) calendar days from the recording date of this Notice of Completion, except where otherwise provided for by law.

VERIFICATION

I, the undersigned state that I am the _____ of the San Lorenzo Valley Water District, the public agency authorizing the Work of Improvement referred to in the foregoing Notice of Completion; that I have executed such Notice of Completion on behalf of such public agency and likewise make this verification on behalf of said public agency; and that I have read said Notice of Completion and know the contents thereof and the facts therein stated are true of my own knowledge.

I declare under penalty of perjury under the laws of the State of California that the foregoing is true and correct.

Date and Place

Rick Rogers, District Manager
San Lorenzo Valley Water District
13060 CA-9, Boulder Creek, California 95006

Distribution:

Original - County Recorder
Copy - Contractor

END OF SECTION 00687

SECTION 00692

CONDITIONAL WAIVER AND RELEASE UPON PROGRESS PAYMENT

California Civil Code Section 8132

NOTICE: THIS DOCUMENT WAIVES THE CLAIMANT'S LIEN, STOP PAYMENT NOTICE, AND PAYMENT BOND RIGHTS EFFECTIVE ON RECEIPT OF PAYMENT. A PERSON SHOULD NOT RELY ON THIS DOCUMENT UNLESS SATISFIED THAT THE CLAIMANT HAS RECEIVED PAYMENT.

Identifying Information

Name of Claimant: _____

Name of Customer: _____

Job Location: _____

Owner: _____

Through Date: _____

Conditional Waiver and Release

This document waives and releases lien, stop payment notice, and payment bond rights the claimant has for labor and service provided, and equipment and material delivered, to the customer on this job through the Through Date of this document. Rights based upon labor or service provided, or equipment or material delivered, pursuant to a written change order that has been fully executed by the parties prior to the date that this document is signed by the claimant, are waived and released by this document, unless listed as an Exception below. This document is effective only on the claimant's receipt of payment from the financial institution on which the following check is drawn:

Maker of Check: _____

Amount of Check: \$ _____

Check Payable to: _____

Exceptions

This document does not affect any of the following:

- (1) Retentions.
- (2) Extras for which the claimant has not received payment.
- (3) The following progress payments for which the claimant has previously given a conditional waiver and release but has not received payment:

Date(s) of waiver and release: _____

Amount(s) of unpaid progress payment(s): _____

(4) Contract rights, including:

(A) a right based on rescission, abandonment, or breach of contract, and

(B) the right to recover compensation for work not compensated by the payment.

SIGNATURE

Claimant's Signature: _____

Claimant's Title: _____

Date of Signature: _____

Note: Where the claimant is required to execute a waiver and release in exchange for or in order to induce the payment of a progress payment and the claimant is not, in fact, paid in exchange for the waiver and release or a single payee check or joint payee check is given in exchange for the waiver and release, the waiver and release shall follow substantially this form. This form of release complies with the requirements of California Civil Code Section 8132.

The Contractor is required to obtain from each subcontractor and supplier this conditional waiver and release of claims for each preliminary notice received by SLVWD. Final payment shall be held in abeyance pending receipt of release of claims from all subcontractors or suppliers.

Alternatively, the final payment will be made by check payable to the Contractor and subcontractor or supplier to the extent the subcontractor or supplier has not been paid as shown on the preliminary notice.

END OF SECTION 00692

SECTION 00693

UNCONDITIONAL WAIVER AND RELEASE UPON PROGRESS PAYMENT

California Civil Code Section 8134

NOTICE TO CLAIMANT: THIS DOCUMENT WAIVES AND RELEASES LIEN, STOP PAYMENT NOTICE, AND PAYMENT BOND RIGHTS UNCONDITIONALLY AND STATES THAT YOU HAVE BEEN PAID FOR GIVING UP THOSE RIGHTS. THIS DOCUMENT IS ENFORCEABLE AGAINST YOU IF YOU SIGN IT, EVEN IF YOU HAVE NOT BEEN PAID. IF YOU HAVE NOT BEEN PAID, USE A CONDITIONAL WAIVER AND RELEASE FORM.

Identifying Information

Name of Claimant: _____

Name of Customer: _____

Job Location: _____

Owner: _____

Through Date: _____

Unconditional Waiver and Release

This document waives and releases lien, stop payment notice, and payment bond rights the claimant has for labor and service provided, and equipment and material delivered, to the customer on this job through the Through Date of this document. Rights based upon labor or service provided, or equipment or material delivered, pursuant to a written change order that has been fully executed by the parties prior to the date that this document is signed by the claimant, are waived and released by this document, unless listed as an Exception below. The claimant has received the following progress payment:

\$ _____

Exceptions

This document does not affect any of the following:

- (1) Retentions.
- (2) Extras for which the claimant has not received payment.
- (3) Contract rights, including:
 - (A) a right based on rescission, abandonment, or breach of contract, and
 - (B) the right to recover compensation for work not compensated by the payment.

SIGNATURE

Claimant's Signature: _____

Claimant's Title: _____

Date of Signature: _____

Where the claimant is required to execute a waiver and release in exchange for, or in order to induce the payment of, a progress payment and the claimant asserts in the waiver it has, in fact, been paid the progress payment, the waiver and release shall follow substantially this form. This form of release complies with the requirements of California Civil Code Section 8134.

The Contractor is required to obtain from each subcontractor and supplier this unconditional waiver and release of claims for each preliminary notice received by SLVWD. Final payment shall be held in abeyance pending receipt of release of claims from all subcontractors or suppliers.

Alternatively, the final payment will be made by check payable to the Contractor and subcontractor or supplier to the extent the subcontractor or supplier has not been paid as shown on the preliminary notice.

END OF SECTION 00693

SECTION 00694

CONDITIONAL WAIVER AND RELEASE UPON FINAL PAYMENT

California Civil Code Section 8136

NOTICE: THIS DOCUMENT WAIVES THE CLAIMANT'S LIEN, STOP PAYMENT NOTICE, AND PAYMENT BOND RIGHTS EFFECTIVE ON RECEIPT OF PAYMENT. A PERSON SHOULD NOT RELY ON THIS DOCUMENT UNLESS SATISFIED THAT THE CLAIMANT HAS RECEIVED PAYMENT.

Identifying Information

Name of Claimant: _____

Name of Customer: _____

Job Location: _____

Owner: _____

Conditional Waiver and Release

This document waives and releases lien, stop payment notice, and payment bond rights the claimant has for labor and service provided, and equipment and material delivered, to the customer on this job. Rights based upon labor or service provided, or equipment or material delivered, pursuant to a written change order that has been fully executed by the parties prior to the date that this document is signed by the claimant, are waived and released by this document, unless listed as an Exception below. This document is effective only on the claimant's receipt of payment from the financial institution on which the following check is drawn:

Maker of Check: _____

Amount of Check: \$ _____

Check Payable to: _____

Exceptions

This document does not affect any of the following:

Disputed claims for extras in the amount of: \$ _____

SIGNATURE

Claimant's Signature: _____

Claimant's Title: _____

Date of Signature: _____

Notice: Where the claimant is required to execute a waiver and release in exchange for, or in order to induce the payment of, a final payment and the claimant is not, in fact, paid in exchange for the waiver and release or a single payee check or joint payee check is given in exchange for the waiver and release, the waiver and release shall follow substantially this form. This form of release complies with the requirements of California Civil Code Section 8136.

The Contractor is required to obtain from each subcontractor and supplier this conditional waiver and release of claims for each preliminary notice received by SLVWD. Final payment shall be held in abeyance pending receipt of release of claims from all subcontractors or suppliers.

Alternatively, the final payment will be made by check payable to the Contractor and subcontractor or supplier to the extent the subcontractor or supplier has not been paid as shown on the preliminary notice.

END OF SECTION 00694

SECTION 00695

UNCONDITIONAL WAIVER AND RELEASE UPON FINAL PAYMENT

California Civil Code Section 8138

NOTICE TO CLAIMANT: THIS DOCUMENT WAIVES AND RELEASES LIEN, STOP PAYMENT NOTICE, AND PAYMENT BOND RIGHTS UNCONDITIONALLY AND STATES THAT YOU HAVE BEEN PAID FOR GIVING UP THOSE RIGHTS. THIS DOCUMENT IS ENFORCEABLE AGAINST YOU IF YOU SIGN IT, EVEN IF YOU HAVE NOT BEEN PAID. IF YOU HAVE NOT BEEN PAID, USE A CONDITIONAL WAIVER AND RELEASE FORM.

Identifying Information

Name of Claimant: _____

Name of Customer: _____

Job Location: _____

Owner: _____

Unconditional Waiver and Release

This document waives and releases lien, stop payment notice, and payment bond rights the claimant has for labor and service provided, and equipment and material delivered, to the customer on this job. Rights based upon labor or service provided, or equipment or material delivered, pursuant to a written change order that has been fully executed by the parties prior to the date that this document is signed by the claimant, are waived and released by this document, unless listed as an Exception below. The claimant has been paid in full.

Exceptions

This document does not affect any of the following:

Disputed claims for extras in the amount of: \$ _____

SIGNATURE

Claimant's Signature: _____

Claimant's Title: _____

Date of Signature: _____

Where the claimant is required to execute a waiver and release in exchange for, or in order to induce the payment of, a progress payment and the claimant asserts in the waiver it has, in fact, been paid the final payment, the waiver and release shall follow substantially this form. This form of release complies with the requirements of California Civil Code Section 8138.

The Contractor is required to obtain from each subcontractor and supplier this unconditional waiver and release of claims for each preliminary notice received by SLVWD. Final payment shall be held in abeyance pending receipt of release of claims from all subcontractors or suppliers.

Alternatively, the final payment will be made by check payable to the Contractor and subcontractor or supplier to the extent the subcontractor or supplier has not been paid as shown on the preliminary notice.

END OF SECTION 00695

SECTION 00700

GENERAL CONDITIONS

LIST OF ARTICLES

ARTICLE 1 – DEFINITIONS
ARTICLE 2 – PRELIMINARY MATTERS
ARTICLE 3 – INTENT AND INTERPRETATION OF CONTRACT DOCUMENTS
ARTICLE 4 – TIME
ARTICLE 5 – LANDS, CONDITIONS AND LAYOUT
ARTICLE 6 – BONDS, INSURANCE AND INDEMNITY
ARTICLE 7 – SUPERVISION AND SUPERINTENDENCE
ARTICLE 8 – CONSTRUCTION PROCEDURES AND PROTECTION
ARTICLE 9 – LABOR, MATERIALS AND EQUIPMENT
ARTICLE 10 – SUBCONTRACTORS
ARTICLE 11 – LAWS AND REGULATIONS
ARTICLE 12 – SUBMITTALS
ARTICLE 13 – SAFETY PRECAUTIONS AND EMERGENCIES
ARTICLE 14 – SEPARATE CONTRACTS
ARTICLE 15 – SLVWD'S AND ENGINEER'S STATUS DURING CONSTRUCTION
ARTICLE 16 – CHANGES IN THE WORK
ARTICLE 17 – ACCESS, INSPECTIONS AND TESTS
ARTICLE 18 – DEFECTIVE WORK
ARTICLE 19 – GUARANTEES AND WARRANTIES
ARTICLE 20 – PAYMENTS AND COMPLETION
ARTICLE 21 – SUSPENSION AND TERMINATION
ARTICLE 22 – ARBITRATION
ARTICLE 23 – MISCELLANEOUS PROVISIONS

ARTICLE 1 – DEFINITIONS

- 1.1 Terms used in the Contract Documents are defined herein. The terms shall have the meanings described which shall be applicable to both the singular and plural thereof.
- 1.2 Addenda. Written or graphic instructed issued prior to execution of the Contract Agreement which modify or interpret the Contract Documents.
- 1.3 Bid. The offer or proposal of the Bidder submitted in the prescribed form setting forth the prices for the Work to be performed.
- 1.4 Bidder. Any person, firm, corporation, or organization submitting a Bid or Proposal for the Work.
- 1.5 Bonds. Bid, performance, and payment bonds, and other instruments of security furnished by the Contractor and his surety in accordance with the Contract Documents.
- 1.6 Change Order. A written order to the Contractor signed by SLVWD ordering and authorizing an addition, deletion, or revision in the Work, or an adjustment in the Contract Price or the Contract Time.
- 1.7 Contract Agreement. The Contract Documents form the Contract Agreement. The Contract Agreement represents the entire and integrated agreement between the parties hereto and supersedes all prior negotiations, representations, or agreements, either written or oral. The Contract Agreement may be amended or modified after execution only by a Modification. References herein to the Contract or the Agreement, or the Form of Agreement, shall be understood to mean and refer to the Contract Agreement.
- 1.8 Contract Documents. The Contract Documents consist of the Contract Agreement, notices, instructions, and forms issued to Bidders in the Bidding Requirements for the submittal of Bids, the Contractor's Bid, the Bid security, the Notice of Award, the Notice to Proceed, the Notice to Construct, if any, the Conditions of the Contract (General, Supplementary, and other Conditions), the Bonds, the Drawings, the Specifications, all Addenda, and all Modifications.
- 1.9 Contract Price. The total moneys payable to the Contractor under the Contract Documents.
- 1.10 Contract Time. The number of days for completion of the Work, or the date upon which the Work shall be completed and ready for use by SLVWD, as stated in the executed Contract Agreement.
 - 1.10.1 Substantial Completion. The time at which the Work (or a specified part thereof) has progressed to the point where, in the opinion of the Engineer, the Work is sufficiently complete, in accordance with the

Contract Documents, so that the Work can be utilized for the purposes for which it is intended.

1.10.2 Final Completion. The time at which the entirety of the Work is complete and ready for final payment, in accordance with the contract documents.

- 1.11 Contractor. The Contractor is the person, firm, corporation, or organization identified as such in the Contract Agreement and is referred to throughout the Contract Documents as if singular in number and masculine in gender. The term Contractor means the Contractor or his/her authorized representative.
- 1.12 Day and Days. The term Day shall mean calendar day, the term Calendar Days shall mean consecutive calendar days, and the term Work Days shall mean consecutive calendar days excluding Saturdays, Sundays, and legal holidays, unless otherwise stated or specified.
- 1.13 District Biologist. District Biologist of San Lorenzo Valley Water District, SLVWD or an authorized representative.
- 1.14 District Engineer. District Engineer of San Lorenzo Valley Water District, SLVWD or an authorized representative.
- 1.15 DIR. California Department of Industrial Relations.
- 1.16 Drawings. The Drawings or exact reproductions thereof which show the scope and character of the Work to be performed and which have been approved by SLVWD, and are referred to in the Contract Documents. The terms Drawing, Plan, and Plans have the same meaning as the term Drawings unless otherwise stated or specified.
- 1.17 Engineer. The term Engineer shall mean the person or firm appointed by SLVWD to undertake the duties and powers assigned to the Engineer by these Specifications acting directly or through authorized representatives. The term Engineer is referred to throughout the Contract Documents as if singular in number and masculine in gender, and means the Engineer or his authorized representative, including the Engineer's employees, agents, and consultants. (See Section 00800.)
- 1.18 Field Order. A Field Order is a written order issued by SLVWD to the Contractor which clarifies or interprets the Contract Documents pursuant to Paragraph 3.2, or orders minor changes or alterations in the Work pursuant to Paragraph 16.6.
- 1.19 Force Account Work: Work ordered on a construction project without an existing agreement on its cost, and performed with the understanding that the Contractor will bill the Owner according to the cost of the labor, materials and equipment, plus a certain percentage for overhead and profit.
- 1.20 Inspector. The Inspector is the authorized agent of SLVWD acting as the designee of the District Engineer, limited in each case to the duties entrusted

to him by SLVWD. The term Inspector applies to all Inspectors appointed by SLVWD. (See Section 00800)

- 1.21 Milestone. A principle event in the performance of the Work that the Contract requires the Contractor to achieve by an intermediate completion date or by a time prior to Substantial Completion of all the Work.
- 1.22 Modification. A Modification is a written amendment to the Contract Agreement signed by both parties, a Change Order, or a Field Order.
- 1.23 Notice of Award. The written notice by SLVWD to the Contractor that the Contractor is the successful Bidder and that, upon compliance with the conditions precedent to be fulfilled by the Contractor within the stated time, SLVWD will execute the Contract Agreement.
- 1.24 Notice to Construct. The written notice by SLVWD to the Contractor authorizing the Contractor to begin the physical installation of the particular material or equipment covered by such notice.
- 1.25 Notice to Proceed. The written notice by SLVWD to the Contractor authorizing him to proceed with the Work and establishing the date of commencement of the Work.
- 1.26 Owner. The Owner is the San Lorenzo Valley Water District (SLVWD) and is referred to throughout the Contract Documents as if singular in number and masculine in gender. The terms Owner and SLVWD mean the Owner or his authorized representative, and includes the Owner's employees, agents, and consultants. (See Section 00800.)
- 1.27 Project. The Project is the total construction designed for or by the Owner of which the Work performed or constructed under the Contract Documents may be the whole or a part.
- 1.28 Shop Drawings. All drawings, diagrams, illustrations, schedules, performance charts, brochures, and other data which are prepared by the Contractor or any Subcontractor, manufacturer, supplier, or distributor and which illustrate the equipment, material, or some portion of the Work.
- 1.29 Samples. Samples are physical examples furnished by the Contractor to illustrate materials, equipment, or workmanship, and to establish standards by which the Work will be judged.
- 1.30 Specifications. The Specifications include the Bidding Requirements, the Contract Forms, the Conditions of the Contract (General, Supplementary, and other Conditions), and the Divisions and Sections of the Specifications.
- 1.31 Subcontractor and Sub-subcontractor. The terms Subcontractor and Sub-subcontractor are referred to throughout the Contract Documents as if each were singular in number and masculine in gender, and means a Subcontractor or Sub-subcontractor or an authorized representative thereof. A Subcontractor is a person, firm, corporation, or organization who has a

direct contract with the Contractor to perform any of the Work at the site. A Sub-subcontractor is a person, firm, corporation, or organization who has a direct or indirect contract with a Subcontractor to perform any of the Work at the site.

- 1.32 Supplier. Any person, firm, corporation, or organization who supplies materials or equipment for the Work, including that fabricated to a special design, and may also be a Subcontractor or a Sub-subcontractor.
- 1.33 Surety. The term Surety is the person, firm, corporation, or organization that joins with the Contractor in assuming the liability for the faithful performance of the Work and for the payment of all obligations pertaining to the Work in accordance with the Contract Documents by issuing the Bonds required by the Contract Documents or by law.
- 1.34 Work. The term Work includes all labor, materials, equipment, and incidentals necessary to produce the construction required by the Contract Documents and any and all obligations, duties, and responsibilities necessary to the successful completion of the construction assigned to or undertaken by the Contractor under the Contract Documents.

ARTICLE 2 – PRELIMINARY MATTERS

- 2.1 Award. The award of the Contract Agreement, if awarded, will be to the eligible, lowest responsive responsible Bidder. No Notice of Award will be given until SLVWD has concluded such investigations as it deems necessary to establish the responsibility, qualifications, and financial ability of the Bidders to do the Work in accordance with the Contract Documents to the satisfaction of SLVWD within the time prescribed. SLVWD reserves the right to reject the Bid of any Bidder who does not pass such investigation to SLVWD's satisfaction. If the Contract Agreement is awarded, SLVWD will give the successful Bidder a Notice of Award within time period prescribed in Notice Inviting Bids after the opening of the Bids and no Bidder may withdraw his Bid for a period of time as prescribed in Notice Inviting Bids after the date set for the receipt of Bids unless other time periods are stated in the Bidding Requirements or elsewhere in the Contract Documents.
- 2.2 Execution of Contract Agreement. The Contract Agreement and such other Contract Documents are practicable shall be suitably identified as agreed by the parties and signed by SLVWD and the Contractor. The Contract Agreement shall be executed within the time period prescribed in Notice Inviting Bids of the Notice of Award unless otherwise provided in the Bidding Requirements or elsewhere in the Contract Documents. SLVWD will hold the Original Agreement and the Contractor shall receive a copy of the Agreement and such other Contract Documents. The Contract Agreement shall be executed in the form adopted or directed by SLVWD.
- 2.3 Delivery of Bonds and Insurance Endorsements. Simultaneously with the execution of the Contract Agreement, the Contractor shall deliver to SLVWD the required Bonds and Insurance Endorsements.

- 2.4 Forfeiture of Bid Security. Failure of the successful Bidder to whom a Notice of Award is tendered to execute the Contract Agreement and deliver the Bonds and other documents required of him at the time of execution within the time limit provided in the Contract Documents shall be just cause for SLVWD to annul the Notice of Award and declare the Bid and any security therefore forfeited.
- 2.5 Copies of Documents. SLVWD will furnish to the Contractor copies of the Specifications and Drawings as are reasonably necessary for the execution of the Work. Upon request, additional copies will be furnished at the cost of reproduction and handling as determined at the sole discretion of SLVWD.
- 2.6 Progress Schedule. Simultaneously with the execution of the Contract Agreement, the Contractor shall submit to SLVWD for approval as estimated progress schedule in chart form indicating the date that each part or brand of the Work will be started and completed including, where applicable, the continuance of operations as provided in Paragraph 12.10, and indicating a schedule of the required submittals including shop drawings, samples, lists of materials and equipment, equipment data, and instruction manuals. The schedule shall conform to the Work and the Contract Time, shall be subdivided and coordinated to the schedule of values, and shall be subject to such revisions SLVWD may require for his approval. The Contractor shall revise the approved progress schedule at monthly intervals, the revised schedules in the same form as the original approved schedule and concurrent with the time periods covered by applications for progress payments. Each revised schedule shall indicate the Work actually accomplished during the time period and the schedule for performance of the remaining Work. Each revised schedule shall be submitted to SLVWD for approval simultaneously with the Contractor's application for progress payment for the same time period, and shall be subject to such revisions SLVWD may require for his approval. SLVWD's approval of revised progress schedules will be a condition precedent to the approval of the Contractor's applications for progress payments.
- 2.7 Schedule of Values. Simultaneously with the execution of the Contract Agreement, the Contractor shall submit a schedule of values as required by Paragraph 20.1 for use in progress payments. When directed by SLVWD, the Contractor shall submit to SLVWD for approval a revised schedule of values coordinated to the revised progress schedules required under Paragraph 2.6 and pertinent requirements of Supplementary Conditions.
- 2.8 Insurance. Before execution of the Contract Agreement, the Contractor shall deliver to SLVWD the certificates and Proof of Insurance as required by Article 6.
- 2.9 Preconstruction Conference. Before the Work is started, a conference will be held to review the progress schedule and the schedule of values, to establish procedures for handling the required submittals and for processing applications for payment, and to establish a working understanding between the parties as to the Project and the Work. Present at the conference shall be SLVWD, the Engineer, and the Contractor and his Superintendent.

- 2.10 Verification. Before undertaking the Work, the Contractor shall carefully study and compare the Contract Documents for any discrepancies, inconsistencies, ambiguities, conflicts, or other errors in them or between the Contract Documents and the site conditions, and check and verify all figures, dimensions, and quantities shown thereon and all field measurements and actual site conditions, and shall bear all costs for any error in the Work resulting from his failure to so compare and verify. He shall at once report in writing to SLVWD any error in which he may discover and shall not perform or construct any of the Work affected thereby until an interpretation or clarification has been issued pursuant to Paragraph 32. The Contractor assumes full responsibility for having familiarized himself with the nature and extent of the Contract Documents, the Work, locality, and local conditions that may in any manner affect the Work to be done, and represents that he has visited the site and correlated his observations with the requirements of the Contract Documents.
- 2.11 Qualifications of Subcontractors and Suppliers.
- 2.11.1 Listing. The listing of Subcontractors shall be submitted with the Bid as required by the instructions to Bidders and the Bid Form.
- 2.11.2 Revision of Listing. No change or revision shall be made to the list nor shall any other Subcontractor, person, or organization not named in the accepted list be employed on or for the Work without SLVWD's consent, the issuance of an appropriate Modification, and at no additional cost to SLVWD.
- 2.12 Starting the Work. The Contractor shall start the Work not later than the date stated in the Notice to Proceed, which date will be the first day of the Contract Time. Unless otherwise provided in the Bidding Requirements, the date so stated for the Work to start will be the tenth day from the date of the Notice to Proceed. SLVWD reserves the right to delay issuance of the Notice to Proceed for a period not to exceed sixty (60) calendar days after the date the Contract Agreement is executed, unless otherwise provided in the Bidding Requirements, and no additional payment will be made to the Contractor on account of such delay.
- 2.13 Contractor's License. Contractor shall possess a Class 'A' Contractor's License at the time of bid submission and award of the Contract, unless otherwise specified in the Invitation to Bidders. Contractor shall fill out and execute the Contractor's Licensing Statement. (See Section 00020 and 00406.)
- 2.14 Registration with DIR. Subcontractors must be registered with the DIR and have paid the annual fee pursuant to Section 1725.5 of the California Labor Code.

ARTICLE 3 – INTENT AND INTERPRETATION OF CONTRACT DOCUMENTS

- 3.1 Intent of the Contract Documents. The Contract Documents are complementary and what is called for by one is as binding as if called for by

all. Any Work that may be reasonably inferred from the Drawings or Specifications as being required to produce the intended result shall be provided by the Contractor whether or not it is specifically called for. The Contractor shall furnish and pay for all labor, supervision, materials, equipment, transportation, construction equipment and machinery, tools, appliances, water, fuel, power, energy, light, heat, utilities, telephone and communications, temporary and sanitary facilities, storage, protection, safety provisions, and all other facilities, services, and incidentals of any nature whatsoever necessary for the satisfactory and acceptable execution, testing, initial operation, and completion of the Work in accordance with the Contract Documents, ready for use, occupancy or operation by SLVWD.

- 3.2 Interpretations. Written clarifications of interpretations necessary for the proper execution or progress of the Work, in the form of drawings or otherwise, will be issued with reasonable promptness by SLVWD and in accordance with any schedule agreed upon. Such clarifications or interpretations shall be consistent with or reasonably inferable from the intent of the Contract Documents and shall become a part thereof, and may be affected by Field Order. If the Contractor believes that a written clarification or interpretation entitles him to an increase in the Contract Price or an extension of the Contract Time, he may make a claim therefore as provided in Paragraph 16.4.

Pursuant to this section of the General Conditions, the Contractor shall use the Request for Clarification Form, included herein (at the end of the General Conditions section), for submittal of inquiries and requests for information or clarification of the Contract Documents.

- 3.3 Organization of Drawings and Specifications. Except where a particular item or type of equipment is specified or otherwise required to be assembled of various components under the coordination and responsibility of one manufacturer or supplier (sometimes referred to or specified as until responsibility), the organization of the Specifications into Division, Sections, Articles, and paragraphs, the listing of the Work included and not included in the various sections of the Specifications, and the arrangement of the Drawings shall not control the Contractor in dividing the Work among Subcontractors nor establish the extent of Work to be performed by any trade.
- 3.3.1 Drawings. Scale dimensions on Drawings shall govern where figured dimensions are not indicated. Figured dimensions on Drawings shall govern over scale dimensions, and detailed Drawings shall govern over general Drawings.
- 3.3.2 Specification Titling and Arrangement. The Article and paragraph titles and other identifications of subject matter in the Specifications are intended as an aid in locating and recognizing various requirements. Except where titling forms are part of the text, such as the beginning words of a sentence or establishes the subject of an Article or paragraph, the titles are subordinate to and do not define, limit, or otherwise restrict the Specifications test. Underlining or capitalizing of words in the text does not

signify or mean that such words convey special or unique meanings having precedence over any other part of the Contract Documents. The Specification text shall govern over titling and shall be understood to be and interpreted as a whole. The order of Articles, paragraphs, and subparagraphs is established by the alpha-numeric or similar system employed in the text.

- 3.3.3 Specification Language. Words or phrases requiring an action or performance, such as perform, provide, install, furnish, erect, connect, test, operate, and adjust, shall be understood to include the meaning of the phrase "The Contractor shall" unless otherwise specified. The requirements of the Drawings and Specifications apply to all Work of the same type, kind, and class even though the word "all" may not be stated. The usage and meaning of various words and phrases employed in the Specifications and herein are as follows, and shall be understood to apply to the future, present, and past tenses according to the context.
- 3.3.3.1 References to Drawings. The words indicated, shown, detailed, noted, scheduled, illustrated, and words of like import shall mean that reference is made to the Drawings unless stated otherwise.
- 3.3.3.2 Directives. The words directed, direction, designated, selected, and words and phrases of like import shall mean that the direction, designation, selection, or like action of SLVWD is intended unless stated otherwise.
- 3.3.3.3 Submittals. The words submit, submittal, submission, and words of like import shall be understood to include the meaning of the phrase "Submit to SLVWD for approval" unless stated otherwise.
- 3.3.3.4 Equals and Approvals. The words equal, approved equal, equivalent, and words and phrases of like import shall be understood to be followed by the expression "in the opinion of SLVWD" unless stated otherwise. The words approval, acceptable, acceptance, satisfaction, and words of like import shall mean that the approval, acceptance, or satisfaction of SLVWD is intended unless stated otherwise.
- 3.3.3.5 Perform. The word perform shall mean that the Contractor shall perform all operations required to complete the mentioned action or Work in accordance with the intent of the Contract Documents.
- 3.3.3.6 Provide. The word provide shall mean that the Contractor shall furnish and install the mentioned Work, complete in place, connected, and ready for use by SLVWD in accordance with the intent of the Contract Documents, except the words providing and provided may mean "contingent upon" and the phrase "as provided in" may mean "in accordance with" where such is the context.
- 3.3.3.7 Required. The word required and words of like import shall mean "as required to complete the Work" and "as required by SLVWD" according to the context, unless stated otherwise.

3.3.3.8 Technical Words. Work, materials, or equipment described in words which so applied have a well-known trade or technical meaning shall be deemed to refer to such recognized meanings.

3.4 Reference or Standard Specifications. Specifying in the Contract Documents by reference to standard or reference type specification documents or to another part of the Contract Documents shall have the same force and effect as if the document or portion referred to were exactly repeated at the place where reference is made. In case of conflict between any applicable code, law, ordinance, rule, regulation, or order and the referenced standard or reference Specification Documents, the Contractor shall conform to the most restrictive requirement provided such conformance is lawful. Standard or reference Specification Documents incorporated into the Contract Documents by reference shall be those in effect on the date shown at the end of the Notice Inviting Bids. The Contractor, Subcontractors, Sub-subcontractors, and suppliers of materials and equipment for the Work shall be fully familiar with the referenced documents. Abbreviations specified to indicate or identify standard or reference specification documents, such as ASTM, ANSI, AWWA, and ASME, shall be interpreted according to their well-known technical and trade meanings and usage.

Work conducted in conjunction with the Contract shall conform to the requirements of the Caltrans Standard Specifications, latest edition, unless otherwise indicated or directed in the Contract Documents included herewith.

3.5 Precedence of Documents: It is the intent of the Contract Documents to provide the SLVWD with complete and fully operational facilities as indicated and specified. All information conveyed by the Contract Documents shall be construed to that effect, and shall be performed to that effect.

To the fullest extent reasonably possible, all provisions of the Contract Documents shall apply to performance of the Work; provided, however, that in resolving conflicts, errors, omissions, or discrepancies in any of the Contract Documents, the order of precedence shall be as follows:

- Permits;
- Applicable Codes;
- Change Orders;
- Approved Revisions to the Contract Documents;
- Addenda;
- Supplementary Conditions;
- Contract Agreement;
- Invitation to Bidders;
- California State Requirements/Supplementary General Conditions;
- General Conditions;
- Technical Plans and Drawings;
- Technical Specifications;
- Standard Drawings;

- SLVWD Standard Specifications and Drawings;
- Referenced Standard Specifications and Drawings.

ARTICLE 4 – TIME

- 4.1 Time Limits. All time limits stated in the Contract Documents are of the essence of the Contract Agreement.
- 4.2 Time of Performance. The Contractor shall construct and complete the Work, including final clean up, final inspection, and final acceptance of the Work, within the Contract Time. It is expressly understood and agreed, by and between SLVWD and the Contractor, that the Contract Time for the completion of the Work is a reasonable time, taking into consideration the average climatic and economic conditions and other factors prevailing in the locality of the Work. (See Section 00800)
- 4.3 Extension of Contract Time. If the Work is not completed within the Contract Time and any previously authorized extensions thereof, SLVWD may extend the Contract Time at his discretion and, if so extended, the Contractor shall pay to SLVWD all or any part, as SLVWD may deem just and proper, of the actual costs incurred by SLVWD due to such extension and that are directly related to the Work including the cost of additional engineering, consultant or professional services, tests, inspections, painting inspections, supervision, administration, and other incidental and overhead expenses, and the Change Order authorizing such extension of the Contract Time will effect an appropriate reduction in the Contract Price.
- 4.4 Delays and Liquidated Damages. If the Work is not completed within the Contract Time, or within any period of authorized extension thereof, it shall be understood and agreed that SLVWD will suffer damage solely by reason of delay. Since it is impractical and infeasible to determine the amount of actual damage, it is agreed that the Contractor shall pay to SLVWD, as fixed and liquidated damages and not as a penalty, the amount stated in the Contract Agreement, unless otherwise provided or agreed by the parties. Payment shall be made for each calendar day of delay until the Work is completed and accepted; and the Contractor and his surety shall be liable for the amount thereof, except the Contractor will not be charged liquidated damages because of any delays in the completion of the Work due to unforeseeable causes beyond their control and without the fault or negligence of the Contractor including, but not restricted to, acts of God or of the Public enemy, acts of the Government, acts of SLVWD including any preference, priority, or allocation order duly issued by SLVWD, acts of another contractor in the performance of a contract with SLVWD, fires, floods, epidemics, quarantine restrictions, strikes, freight embargoes, and unusually severe weather. The Contractor shall, within ten (10) work days from the beginning of any such delay, notify SLVWD in writing of the cause of the delay, whereupon SLVWD will ascertain the facts and the extent of the delay and extend the time for completing the Work when in SLVWD's judgment the findings of fact justify such an extension, and SLVWD's findings of fact thereby shall be final and conclusive on the parties hereto. It is understood and agreed that such liquidated damage provision does not limit SLVWD with respect to any other damage capable of ascertainment. The Contractor hereby acknowledges and agrees that the Engineer and other

professionals, consultants, and specialists appointed or employed by SLVWD for the Work will suffer damages as a result of any unauthorized delay in completion of the Work and accepts the liability and responsibility for these damages as damage to SLVWD that is capable of ascertainment.

- 4.5 Material Escalation. If, during the acquisition of materials for performance of the Contract, the Contractor experiences a Significant Price Increase (defined below) of the price of pipe, fittings and appurtenances, through no fault of the Contractor, the Contract Price shall be equitably adjusted by an amount calculated pursuant to this Section 4.5. As used herein, a Significant Price Increase shall mean an increase in the price of pipe, fittings and appurtenances that exceeds five percent (5%), as demonstrated by the Contractor by providing documentation of the change in the US Producer Price Index: Material Recyclers: Ferrous Metal Scrap showing at least a five percent (5%) increase from date of Contractor's Bid submittal to the date of material invoicing by the Contractor's supplier. Upon demonstrating the existence of a Significant Price Increase, the Contractor shall be entitled to a Contract Price adjustment in an amount calculated by the District by determining the price difference between the Contractor's price assumptions for pipe, fittings and appurtenances, as documented with valid quotes from suppliers submitted by Contractor with the Bid, and Contractor's actual supplier invoices for the Project. Any such Contract Price adjustment shall not include any increase in Contractor overhead nor profit. Valid quotes from suppliers used to support Contractor's price assumptions in the Bid submittal must, at a minimum, show the supplier's unit prices for the specific types of pipe, fittings and appurtenances to be used in the Project. In order to seek and be entitled to any Contract Price adjustment under this Section 4.5, the Contractor must demonstrate to the District's reasonable satisfaction that the Contractor took affirmative steps to place orders, take delivery and/or seek price lockdowns on the applicable pipe, fittings and appurtenances in order to limit the impact of such price escalation on the Project.
- 4.6 Labor Escalation. Bid prices assume that Work on the Project will commence within 60-days of Award. If unavailability of materials causes start of Work to be delayed more than 60-days, the Contractor may request adjustment of the labor portion of Contractor's Bid price. Unavailability of materials pursuant to this Section 4.6 must be demonstrated by the Contractor to District's satisfaction, and shall be distinct from any increases of the price of materials, for which the Contractor's rights are established by Section 4.5 above. Contractor shall make this request for an adjustment of the labor portion of the Contractor's Bid price in writing, and the request shall include, at a minimum, documentation of local Prevailing Wage for each classification of worker at the time of Bid submittal and local Prevailing Wage for each worker classification at the time materials become available. In addition, the Bid submittal must include Contractor's assumptions for labor costs. Increases in labor costs to the District shall be limited to the change in local Prevailing Wage from the Bid date to the date of Contractor performance

ARTICLE 5 – LANDS, CONDITIONS, AND LAYOUT

- 5.1 Land and Rights-of-Way. SLVWD will furnish and pay for the land, easements, and rights-of-way for the facilities to be installed. The Contractor shall obtain consents from the property owners, make all necessary arrangements, and pay all costs for additional land areas or access required by him during the course of construction outside the limits of the land, easements, and rights-of-

way furnished by SLVWD, without liability to SLVWD.

- 5.2 Data Furnished by SLVWD. Upon written request, SLVWD will furnish to the Contractor a copy of all available boundary surveys and subsurface investigations. (See Section 00800.)
- 5.3 Subsurface Conditions. Documents and drawings pertaining to subsurface conditions at the site(s) are listed in the Supplemental Conditions. Neither SLVWD or the Engineer warrant or guarantee the accuracy or adequacy of any such report or any data, statements, opinions, recommendations, or conclusions therein, nor shall SLVWD or the Engineer be responsible or liable for any loss sustained by the Contractor because of any variance between the conditions indicated in or deduced by the Contractor from such a report or the Contract Documents and the actual conditions encountered in the Work. The Contractor shall make such subsurface investigations he/she may require to establish the true nature of the subsurface conditions affecting the Work, the difficulties which may be encountered (including subsurface rock or other obstacles), and the de-watering or other operations which may be required to complete the Work. No additions or extra payment will be made to the Contractor on account of any subsurface conditions whether or not known or latent, including rock. This paragraph shall be construed in accordance with Public Contract Code Section 7104 and Government Code Section 4215; to the extent such provisions may apply.
- 5.4 Environmental Conditions. Documents pertaining to environmental conditions at the site(s) are listed in the Supplemental Conditions. Neither SLVWD or the Engineer warrant or guarantee the accuracy or adequacy of any such report or any data, statements, opinions, recommendations, or conclusions therein, nor shall SLVWD or the Engineer be responsible or liable for any loss sustained by the Contractor because of any variance between the conditions indicated in or deduced by the Contractor from such a report or the Contract Documents and the actual conditions encountered in the Work. The Contractor shall make such additional investigations he/she may require to establish the true nature of the conditions affecting the Work.
- 5.5 Laying Out the Work. Owner shall provide engineering surveys to establish reference points for construction which in Engineer's judgment are necessary to enable Contractor to proceed with the Work. Contractor shall

be responsible for laying out the Work, shall protect and preserve the established reference points and property monuments, and shall make no changes or relocations without the prior written approval of Owner. Contractor shall report to Engineer whenever any reference point or property monument is lost or destroyed or requires relocation because of necessary changes in grades or locations, and shall be responsible for the accurate replacement or relocation of such reference points or property monuments by professionally qualified personnel.

- 5.6 Preparation. Prior to setting out the work, the Contractor shall have all utility lines located and marked in the field and shall have all right-of-ways cleared, graded, and ready for construction activities.

ARTICLE 6 – BONDS, INSURANCE, AND INDEMNITY

- 6.1 Bonds. The Contractor shall furnish performance and payment Bonds for the faithful performance and payment of all his obligations under the Contract Documents. Each Bond shall be in penal sums at least equal to the Contract Price unless otherwise stated in the Bidding Requirements, and in such form and with such sureties as are acceptable to SLVWD. Prior to execution of the Contract Agreement SLVWD may require the Contractor to furnish other Bonds in such form and with such sureties as SLVWD may require. Sureties, to be acceptable to SLVWD, shall be legally authorized to do business in the State and jurisdiction where the Work is to be constructed and shall have assets that exceed its liabilities in an amount equal to, or in excess of, the amount of the bond. Bonds shall be duly executed by a responsible corporate surety, authorized to issue such bonds in the State of California and secured through an authorized agent with an office in California. The bidder shall also be required to submit along with the proposal and bond the following documents:

- a) The original, or a certified copy, of the unrevoked appointment, power of attorney, bylaws, or other instrument entitling or authorizing the person who executed the bond to do so.
- b) A certified copy of the authority of the insurer by the Insurance Commissioner.
- c) Proof that the Surety is named in the current list of "Surety Companies Acceptable on Federal Bonds" as published by the United States Treasury Department.
- d) Proof that the Surety has an "A" policyholder's rating and a financial rating of at least Class VII in accordance with the most current rating by A.M. Best Company.

The performance bond shall remain in full force and effect for the entire guarantee period as provided in Paragraphs 19.1 and 19.2. If such Bonds are required by written instructions given prior to the opening of Bids, the premiums shall be paid by the Contractor; if subsequent thereto, they will be paid by SLVWD. If at any time a surety on any such Bond is declared bankrupt or loses its right to do business in the State or jurisdiction in which the Work is to be performed or is removed from the list of Surety Companies

Acceptable on Federal Bonds, the Contractor, within ten (10) work days after notice by SLVWD to do so, shall substitute an acceptable Bond or Bonds in such form and sum and signed by such other surety or sureties as may be satisfactory to SLVWD. The premium on such Bond or Bonds shall be paid by the Contractor. No further payments shall be deemed due nor shall be made to the Contractor until the new surety or sureties shall have furnished an acceptable Bond or Bonds to SLVWD.

- 6.2 Insurance. No Work shall be done under these Contract Documents unless there is in full force and effect during and until final acceptance of the Work, and thereafter as provided in subparagraph 6.2.1, all the insurance required to be furnished by the Contractor under this Article. The Contractor shall procure and maintain insurance against claims for injuries to persons or damages to property which may arise from or in connection with the performance of the work hereunder by the Contractor, his agents, representatives, employees, or subcontractors. Nothing herein contained shall be construed as limiting in any way the extent to which the Contractor may be held responsible for payment of damages to persons or property resulting from his operations or the operations of any Subcontractor or Sub-subcontractor under him.
- 6.2.1 Carriers and Evidence. All insurance policies shall be with such insurance carriers and in such form as is satisfactory to and approved by SLVWD. The Insurance is to be placed with insurers with a current A.M. Best rating of no less than A: VII, unless otherwise acceptable to SLVWD. Contractor shall file with SLVWD a Certificate of Insurance for each policy required of him, and shall submit the actual insurance policies to SLVWD for inspection if requested or so required herein. Any insurance bearing on the adequacy of performance shall be maintained by the Contractor after final acceptance of the Work for the entire guarantee period as provided in Paragraphs 19.1 and 19.2. If the Contractor fails to maintain the required insurance, in whole or in part, SLVWD may secure and pay the premiums for such insurance and the Contractor shall pay to SLVWD such premium costs SLVWD may so incur in accordance with Paragraph 20.12.
- 6.2.2 Additional Insureds, Primary Insurance. SLVWD, its officers, officials, directors, employees, and volunteers shall be included as an additional insured in all insurance policies to be maintained by the Contractor, including comprehensive general liability and auto policies with respect to liability arising out of automobiles owned, leased, hired, or borrowed by or on behalf of the Contractor, and with respect to liability arising out of work or operations performed by or on behalf of the Contractor including materials, parts, or equipment furnished in connection with such work or operations. Such other persons or organizations as SLVWD may designate shall also be included as additional insureds. General liability coverage can be provided in the form of an endorsement to the Contractor's insurance (at least as broad as ISO Form CG 20 10 (11/85) or both CG 20 10 and CG 20 37 forms if later revisions used). The insurance afforded to the additional insureds shall be primary as respect to SLVWD, its officers, officials, directors, employees, and volunteers. If the additional insureds have other insurance which might be applicable to any loss, the insurance to be maintained by the Contractor shall be primary and the amount of the insurance to be maintained by the Contractor shall not be reduced or prorated by the

existence of such other insurance. Any insurance or self-insurance maintained by SLVWD, its officers, officials, directors, employees, and volunteers shall be excess of the Contractor's insurance and shall not contribute with it. Exclusions in the insurance policies to be maintained by the Contractor are subject to the approval of SLVWD.

6.2.3 Noncancellation Clause and Renewals. All insurance policies required of the Contractor shall contain or be endorsed to contain a provision that the coverage afforded under the policies will not be canceled or changed until at least thirty (30) calendar days' prior written notice (ten (10) days for non-payment) has been given to SLVWD by registered or certified mail. Exact copies of renewal policies or endorsement extensions of previous policies shall be delivered to SLVWD by the Contractor prior to the expiration date of any of the insurance.

6.2.4 Indemnification. The Contractor shall indemnify, defend, and save harmless SLVWD, its officers, officials, directors, employees, and volunteers and each of them from and against all losses and all claims, demands, payments, suits, actions, recoveries, and judgments of every nature and description brought or recovered against any of them by reason of any act or omission of the Contractor, his agents or employees, or of any Subcontractor or Sub-subcontractor relating to or arising out of the execution of the Work, excepting that caused by the active negligence, sole negligence, or willful misconduct of SLVWD. The Contractor shall maintain and pay for such insurance as will protect SLVWD from any and all contingent liability under the Contract Agreement and a copy of such insurance policy shall be filed with SLVWD.

6.2.5 Workers' Compensation and Employer's Liability Insurance. The Contractor shall maintain or cause to be maintained an adequate workers' compensation insurance, including occupational disease provisions, under the laws of the State where the Work is located and employer's general liability insurance for the benefit of his employees and the employees of any Subcontractor or Sub-subcontractor under him not protected by such compensation laws. The Contractor shall maintain Workers' Compensation insurance as required by the State of California, with statutory limits, and Employer's Liability insurance with limits of no less than those stated in the Supplementary Conditions per accident for bodily injury or disease. The workers' compensation insurance shall include an All States endorsement, a voluntary compensation endorsement, a marine workers and a longshoreman's and harbor worker's endorsement where applicable to the Work, and an endorsement waiving subrogation against the Contractor and SLVWD for all work performed by the Contractor, its employees, agents, and subcontractors.

The Contractor shall execute the Contractor's Certificate Regarding Workers' Compensation pursuant to Section 1881 of the California Labor Code. (See Section 00662.)

6.2.6 Public Liability and Property Damage Insurance. The Contractor shall maintain or cause to be maintained public liability and property damage insurance in commercial general liability policy form to protect the Contractor against claims or loss from liability imposed by law from damages which

may arise out of or result from the Contractor's operations under the Contract Agreement, whether such operations be by himself or by any Subcontractor or any Sub-subcontractor or by anyone directly or indirectly employed by any of them, or by anyone for whose acts any of them may be liable, on account of bodily injury, sickness, or disease, including death resulting therefrom, suffered or alleged to have been suffered by any person or persons resulting directly or indirectly from said operations, and against claims or loss from liability imposed by law for damage to any property caused directly or indirectly by said operations, which insurance shall also cover accidents arising out of the use and operation of automobiles, trucks, and other vehicles on or for the Work whether or not owned by those performing said operations and, further, shall include operations and premises coverage, contractual liability and indemnification agreement coverage, and products and completed operations coverage. The insurance required of the Contractor under this subparagraph shall remain in full force and effect for the entire time of the Contractor's guarantee. Unless otherwise stated in the Supplementary Conditions, the coverage amount of said insurance shall be not less than the following:

Commercial General Liability: Insurance Services Office Form CG 00 01, including products and completed operations, with limits of no less than those stated in the Supplementary Conditions per occurrence for bodily injury, personal injury, and property damage. If a general aggregate limit applies, either the general aggregate limit shall apply separately to this project/location or the general aggregate limit shall be twice the required occurrence limit.

Auto Liability: Insurance Services Office Form Number CA 0001 covering Code 1 (any auto), with limits no less than those stated in the Supplementary Conditions per accident for bodily injury and property damage.

Contractor's Pollution Legal Liability and/or Asbestos Legal Liability and/or Errors and Omissions (if the project involves environmental hazards) with limits no less than those stated in the Supplementary Conditions per occurrence or claim, and in policy aggregate.

- 6.2.7 Property Insurance. The Contractor shall maintain or cause to be maintained, until the Work is accepted by SLVWD, Builders' Risk "All-Risk" Completed Value Insurance coverage including earthquake and flood upon the entire Work and including completed Work, Work in progress, and materials and equipment in transit or storage for the Work, to the full value thereof and no coinsurance penalty provisions. Contractor may submit evidence of Builder's Risk insurance in the form of Course of Construction coverage. Such coverage shall name SLVWD as loss payee as their loss may appear. This insurance shall include the interests of SLVWD, the Contractor, and the Subcontractors and Sub-subcontractors in the Work. Such insurance may have a deductible clause with a maximum Five- Thousand Dollar (\$5,000) deductible unless otherwise stated in the Supplementary Conditions. Any insured loss is to be adjusted with SLVWD and made payable to SLVWD as trustee for the insureds as their interests may appear. SLVWD and the Contractor waive all rights against each other for damages caused by fire or other perils to the extent covered by

insurance provided under this subparagraph, except such rights as they may have to the proceeds of such insurance held by SLVWD as trustee. The Contractor shall require similar waivers by Subcontractors and Sub-subcontractors. If after such loss no other special agreement is made, replacement of damaged Work may be covered by an appropriate Change Order. Under the contract documents, the property insurance shall include coverage against the perils of flood and earthquake. (See Section 00800.)

If the project does not involve new or major reconstruction, at the option of SLVWD, an Installation Floater may be acceptable. For such projects, a Property Installation Floater shall be obtained that provides for the improvement, remodel, modification, alteration, conversion or adjustment to existing buildings, structures, processes, machinery and equipment. The Property Installation Floater shall provide property damage coverage for any building, structure, machinery, or equipment damaged, impaired, broken or destroyed during the performance of the Work, including during transit, installation, and testing at SLVWD's site.

6.2.7.1 Responsibility for Work.

- 1) Contractor shall be responsible for and shall bear any and all risk of loss or damage to Work in progress, all materials delivered to the site and all materials and equipment until completion and acceptance of the Work, unless such loss or damage results from the sole active negligence of SLVWD, or its representatives, and as otherwise hereinafter provided for in Paragraphs 6.2.7.1.2 and 6.2.7.1.3.
- 2) As provided in Section 7105 of the California Public Contract Code, the Contractor shall not be responsible for the cost of repairing or restoring damage to Work determined to have been approximately caused by an Act of God, in excess of five percent (5%) of the contract price, provided that the Work damaged was built in accordance with accepted and applicable building standards and the plans and specifications as set forth in this Contract.

The Contractor shall obtain insurance to indemnify SLVWD for any damage to the Work caused by an Act of God if the premium of said insurance coverage is called for as a separate bid item in the Schedule of Quantities and Prices.

The Contractor's Installation All Risk Insurance shall be provided covering value of the Work and all materials and equipment to be incorporated therein while at the site and during inland transit insuring to the replacement value, subject to the deductible not to exceed \$5,000 for any single loss. This insurance shall also contain an insurer's waiver of subrogation against SLVWD. This insurance shall specifically cover losses due to earthquake.

- 3) As provided in Section 7105 of the California Public Contract Code, the term "Acts of God" shall include only the following occurrences or conditions and effects: earthquakes in excess of a magnitude of 3.5 on a Richter Scale and tidal waves.

- 4) Pursuant to provisions of Section 7105 of the Public Contract Code SLVWD reserves the right to make changes in this Contract in the course of construction to bring the completed improvements into compliance with environmental requirements or standards established by State or Federal statutes and regulations enacted after this Contract has been awarded or entered into. In such cases, the Contractor shall be paid for the changes in accordance with the provisions of the Contract governing payments for changes in the Work, or if such relevant provisions are not set forth in this Contract, payment shall be as agreed to by the parties pursuant to procedures under this Contract. SLVWD further reserves the right to terminate the contract pursuant to provisions provided herein for environmental considerations as may be allowed under Section 7105.
- 6.3 Loss of Use Insurance. SLVWD may purchase and maintain such insurance as will insure SLVWD against loss of use of SLVWD's property due to fire or other hazards or permits, however caused.
- 6.4 Loss or Damage and Indemnity Agreement. The Contractor shall be responsible for any liability imposed by law for any damage to the Work or any part thereof or to any of the materials or other things used in performing the Work or for injury to any person or persons or for any property damage. The Contractor shall indemnify and hold SLVWD, its officers, officials, directors, employees, and volunteers and each of them harmless against any and all liability, claims, loss or injury, including costs, expenses, and attorney's fees incurred in the defense of same, arising from any allegation, whether groundless or not, of damage or injury to any person or property resulting from the performance of the Work or from any material used in the Work or from any condition of the Work or Work site, or from any cause whatsoever during the process of the Work. Said indemnity includes acts of passive negligence of SLVWD, its officers, officials, directors, employees, or volunteers. This indemnity agreement does not extend to one whose sole negligence or willful misconduct caused injury or damage.
- 6.5 Nonlimitation of Indemnity Agreements. The indemnification obligations of the Contractor under the Contract Documents shall not be limited in any way by any limitation on the amount or type of damages, compensation or benefits payable by or for the Contractor or any Subcontractor or Sub- subcontractor of any tier under workers' compensation acts, disability benefit acts, or other employee benefit acts.
- 6.6 Occurrence Coverage. Coverage required by this Contract shall be occurrence coverage.
- 6.7 Deductibles and Self-Insured Retentions: Any deductibles or self-insured retentions must be declared to and approved by SLVWD. At the option of SLVWD, either: the insurer shall reduce or eliminate such deductibles or self-insured retentions as respects SLVWD, its officers, officials, directors, employees, and volunteers; or the Contractor shall provide a financial guarantee satisfactory to SLVWD guaranteeing payment of losses and related investigations, claim administration, and defense expenses.

- 6.8 Waiver of Subrogation. Contractor hereby agrees to waive rights of subrogation which any insurer of Contractor may acquire from Contractor by virtue of the payment of any loss. Contractor agrees to obtain any endorsement that may be necessary to affect this waiver of subrogation.
- 6.9 Subcontractors. Contractor shall require and verify that all subcontractors maintain insurance meeting all of the requirements stated herein unless otherwise agreed to in writing by SLVWD prior to commencement of work by such subcontractor.
- 6.10 Verification of Coverage. Contractor shall furnish SLVWD with original certificates and amendatory endorsements, or copies of the applicable insurance language, effecting coverage required by this Contract. All certificates and endorsements are to be received and approved by SLVWD before work commences. However, failure to obtain the required documents prior to the work beginning shall not waive the Contractor's obligation to provide them. SLVWD reserves the right to require complete, certified copies of all required insurance policies, including endorsements, required by these specifications, at any time.

ARTICLE 7 – SUPERVISION AND SUPERINTENDENCE

- 7.1 Contractor's Supervision. The Contractor shall supervise and direct the Work efficiently and with his best skill and attention. He shall be solely responsible for means, methods, techniques, procedures, and sequences of construction. The Contractor shall coordinate all parts of the Work and shall be responsible to see that the finished Work complies accurately with the Contract Documents.
- 7.2 Superintendent. The Contractor shall keep on the Work at all times during its progress a competent resident English-speaking Superintendent satisfactory to SLVWD, who shall not be replaced without ten (10) work days' written notice to SLVWD except under extraordinary circumstances. The Superintendent shall be the Contractor's representative at the site and shall have the authority to act on behalf of the Contractor. All communications, instructions, and directions given to the Superintendent shall be as binding as if given to the Contractor. Whenever the Contractor or the Superintendent is not present on a part of the Work where SLVWD wishes to give orders or directions, the orders or directions shall be received and obeyed by the Foreman in charge of that part of the Work the same as if the order or direction had been given to the Contractor or the Superintendent. Any order or direction given by SLVWD not otherwise required to be in writing will be given or confirmed in writing upon request of the Contractor.

ARTICLE 8 – CONSTRUCTION PROCEDURES AND PROTECTION

- 8.1 Contractor's Plant and Equipment. The Contractor shall furnish sufficient plant and equipment as necessary to perform the Work in a manner satisfactory to SLVWD and in accordance with the Contract Documents, types and designs that comply with the requirements of Article 13 and with the requirements prescribed by laws, ordinances, codes, rules, regulations,

and orders pertaining to wind and seismic forces at the place of the Project. Construction equipment or machinery that at any time produces unsatisfactory results shall be promptly repaired or replaced by the Contractor and as SLVWD may require.

- 8.2 Use of Site. The Contractor shall confine his equipment, the storage of materials and equipment, and the operations of those directly and indirectly employed by him to areas permitted by law, ordinances, permits, and the Contract Documents, and shall not unreasonably encumber the site with materials and equipment. Nothing in the Contract Documents shall grant to the Contractor exclusive occupancy of the site of the Work and Project.
- 8.3 Overloading. No part of the Work or new and existing structures, scaffolding, shoring, sheeting, construction machinery and equipment, or other permanent and temporary facilities shall be loaded with weights or subjected to stresses or pressures that endanger any of them. The Contractor shall bear the cost of correcting damage caused by overloading or excessive stresses or pressures.
- 8.4 Use of Explosives. The use of explosives for any and all purposes is not permitted for the Work under this Contract.
- 8.5 Cutting and Patching. The Contractor shall perform all cutting, fitting, or patching of the Work that may be required to make its several parts fit together properly and satisfactorily, and shall not endanger any Work, structures, adjacent property, workmen, or the public by cutting, excavating, or otherwise altering the Work or any part of it. The Contractor shall restore all such cut or patched Work and improvements as approved by SLVWD.
- 8.6 Verification of Installed Work. The Contractor shall correct all defects in installed Work of the Contract before subsequent related or connected Work is applied or installed. Where the Contract Documents require a material or item of equipment to be applied or installed under the supervision, inspection, or direction of the supplier or manufacturer, or his representative, the supplier, manufacturer, or his representative shall inspect the applicable installed Work and issue a letter to SLVWD stating the corrections required to or approval of the installed Work before his material or equipment is installed or applied.
- 8.7 Manufacturers' Instructions. Unless otherwise provided in the Contract Documents, the Contractor shall apply, install, erect, connect, use, clean, condition, and operate manufactured articles, materials, and equipment in accordance with the various manufacturers' instructions including those in the instruction manuals required in Paragraph 12.7 and other instructions required in Paragraph 12.8. The Contractor shall compare the requirements of the various manufacturers' instructions with the requirements of the Contract Documents, shall promptly notify SLVWD in writing of any difference between such requirements, and shall not proceed with any of the Work affected by such differences until an interpretation or clarification is issued pursuant to Paragraph 3.2. The Contractor shall bear all costs for any error in the Work resulting from his failure to so compare the various requirements and notify SLVWD of any such differences.

- 8.8 Public Convenience. The Contractor shall at all times so conduct his operations as to ensure the least possible obstruction and inconvenience to traffic and the general public and the residents in the vicinity of the Work, to protect persons and property, and to preserve access to driveways, houses, and buildings. The Contractor shall have under construction no greater amount of Work than he can properly perform with due regard to the rights of the public, and shall not create any public nuisance. No road, street, or highway shall be closed to the public except with the permission of the proper authorities. Where existing streets are not available as detours, the Contractor shall permit traffic to safely pass through the Work with as little delay and inconvenience as possible, unless otherwise authorized by SLVWD. When a section of new surfacing, paving, or a traffic structure intended for public use has been completed, it shall be opened for use at the request of SLVWD. The Contractor shall furnish competent flagmen whose sole duty shall be the directing of traffic through or around the Work when ordered by SLVWD, required by public authorities having jurisdiction, or required by law. At no time shall the Contractor prevent free access to fire hydrants, water and gas main valves, manholes or vaults, or other utility facilities. The Contractor shall make temporary provisions to ensure the use of walkways and sidewalks and the proper functioning of gutters, sewer and storm drain inlets, and ditches, which shall not be obstructed.
- 8.9 Protection. The Contractor shall take all precautions and furnish and maintain protection to prevent damage, injury, or loss to all employees and workmen on the Work and all other persons who may be affected thereby; all the Work and all materials and equipment to be incorporated therein, whether in storage on or off the site, under the care, custody or control of the Contractor or any of his Subcontractors or Sub-subcontractors; and other improvements and property at the site or where Work is to be performed including buildings, trees and plants, pole lines, fences, guard rails, guide posts, culvert and project markers, signs, structures, conduits, pipe lines, and improvements within or adjacent to streets, rights-of-way, or easements, except those items required to be removed by the Contractor in the Contract Documents. The Contractor's protection shall include all the safety pre- cautions required under Article 13 and other necessary forms of protection, and the notification of SLVWD of utilities and adjacent property.
- 8.9.1 Utilities and Substructures. The indication of the type and approximate location of existing utilities and substructures in the Contract Documents represents a diligent search of known records, but the accuracy and completeness of such indications are not warranted by SLVWD or the Engineer and utility structures and services not so indicated may exist. Before commencing any excavations, the Contractor shall investigate, determine the actual locations, and protect the indicated utilities and structures, shall determine the existence, position, and ownership of other utilities and substructures in the site or where the Work is to be performed by communication with such owners, search of records, or otherwise, and shall protect all such utilities and substructures. SLVWD has indicated on the Plans and Specifications with reasonable accuracy the location of main or trunk line utilities located on the site of project. The Contractor shall be compensated for reasonable costs of locating and repairing any such facilities if not located with reasonable accuracy unless Contractor has failed to exercise reasonable care. Contractor shall not be assessed liquidated damages for delay caused by the failure of SLVWD to provide for the

removal, relocation, or protection of such utilities not identified in the Plans and Specifications. The Contractor shall verify the actual location and depth by "pot holing" of each utility. This paragraph shall be construed in accordance with Government Code Section 4215.

- 8.9.2 Maintenance of Facilities. Unless otherwise provided in the Contract Documents or otherwise cared for by SLVWD thereof, all water, gas, oil, or irrigation drainage lines and house connection lines, sprinkling systems, and other subsurface, surface and overhead structures of any nature along the Work shall be maintained by the Contractor at his expense, and shall not be disturbed, disconnected, or damaged by him during the progress of the Work. The Contractor shall install temporary pipes of adequate size to carry off sewage from any sewer facilities cut off by construction operations. Installation of temporary pipes shall be made immediately upon cutting of the existing facility, and no sewage shall be allowed to flow from any severed facility upon the ground surface or in the trench excavation. Pipe used in temporary sewers may be clay, metal, concrete, PVC or HDPE. Before completion of Work, the Contractor shall replace all severed connections and restore to operating order the existing sanitary facilities with matching materials and construction. No liquid from any severed facility shall be allowed to flow upon the ground surface or in any excavation.
- 8.9.3 Restoration and Repair. Except for those improvements and facilities required to be permanently removed by the Contract Documents, the Contractor shall make satisfactory and acceptable arrangements with the appropriate owners and, at his expense, shall repair and restore all improvements, structures, property, utilities, and facilities disturbed, disconnected, or damaged as a result or consequent of his Work or the operations of those for whom he is responsible or liable, including that caused by trespass of any of them with or without his knowledge or consent, or by the transporting of workmen, materials, or equipment to or from the site.
- 8.9.4 Protection of Workers in Trench Excavations. (See California State Requirements, Section 00800CA, Paragraph L.)
- 8.10 Utilities.
- 8.10.1 Water Supply. The Contractor shall not draw water from any fire hydrant or service, nor operate any valve or control of any water system without the written permission of SLVWD thereof, and a copy of each written permission shall be filed with SLVWD. Water use shall be metered through a hydrant meter, service meter or temporary meter, as directed by the Owner.
- 8.10.2 Temporary Utility Interruptions. If the temporary interruption of utility services is necessary for the prosecution of the Work, the Contractor shall make all arrangements with the utility owners and pay all fees and charges levied by them for the interruptions, and shall notify the affected users at least forty-eight (48) hours in advance of the probable duration of interruption unless such notice is given by the appropriate utility owner.
- 8.10.3 Temporary Removal or Maintenance. If it should be necessary to move or temporarily maintain the property of any public utility or other property, the cost of which because of the terms of any franchise or for any other reason must be borne by SLVWD thereof, such owner will, upon proper application

by the Contractor, be notified by SLVWD to move or temporarily maintain such property until after the expiration of the time required for the Work. SLVWD, public authorities having jurisdiction, and SLVWDs of public utilities and franchises shall have access to any street, alley, right-of-way, or easement for the purpose of maintaining or of making repairs or changes in property made necessary by the Work.

ARTICLE 9 – LABOR, MATERIALS, AND EQUIPMENT

- 9.1 Workman. The Contractor shall at all times enforce strict discipline and good order among his employees and those of any Subcontractor or Sub-subcontractor, and shall not employ on the Work any unfit person or anyone not skilled and experienced in the assigned task. All Superintendents and foremen shall be English-speaking. Any Superintendent, foreman, laborer, or other person employed on the Work who fails or refuses to perform the Work in the manner required by the Contract Documents shall be discharged immediately and such person shall not again be employed on the Work. When required in writing by SLVWD, the Contractor, Subcontractor, or Sub-subcontractor shall discharge any person who is, in the opinion of SLVWD, incompetent, unfaithful, disorderly, or otherwise unsatisfactory. Such discharge shall not be the basis of any claim for compensation or damages against SLVWD or the Engineer.
- 9.2 Workmanship. The quality of workmanship produced by skilled, knowledgeable, and experienced journeymen mechanics and artisans is required for the Work; Particular attention shall be given to the appearance and finish of exposed Work. The decision of SLVWD with regard to the quality and adequacy of workmanship shall be final and binding.
- 9.3 Materials and Equipment. All materials and equipment incorporated in the Work shall be new unless otherwise specified. Materials and equipment not covered by detailed requirements in the Contract Documents shall be of the best commercial quality, suitable for the purpose intended, and approved by SLVWD prior to use in the Work. The Contractor shall provide proper storage facilities and exercise such measures as will ensure the preservation of the required quality and fitness of all materials and equipment. Materials or equipment not conforming to the requirements of the Contract Documents shall be rejected and immediately removed from the site of the Work. Materials, supplies, or equipment to be incorporated into the Work shall not be purchased by the Contractor or any Subcontractor or Sub-subcontractor subject to a chattel mortgage or under a conditional sale contract or other agreement by which an interest is retained by the seller.
- 9.3.1 Plurality of Terms. Where materials or equipment are referred to in the singular number, it is intended unless otherwise limited that such reference shall be applied to as much material or equipment as is required to complete the Work.
- 9.3.2 Optional Materials. Where any material or equipment item is specified by two or more manufacturer's name or proprietary identifications, the Contract may provide any one of the materials or equipment so specified. Only one brand, kind, or make of material or equipment shall be used for each specific purpose throughout the Work notwithstanding that similar material or

equipment of two or more manufacturers may be specified for the same purpose.

9.3.3 Space Requirements and Arrangement. The Contractor shall ensure that the materials and equipment to be furnished fit the space available, and shall make the necessary field measurements to ascertain space requirements including those for connections. If material or equipment requiring arrangement or connections different from those required by the Contract Documents is approved by SLVWD, the Contractor shall bear all costs for installing the material or equipment and for changes to adjoining or related Work SLVWD may require.

9.3.4 Materials Furnished by SLVWD. Material or equipment to be furnished by SLVWD will be supplied in accordance with the Specifications.

9.4 Substitutions and Equals. References in the Contract Documents to any material, item of equipment, or type of construction by manufacturer's name, make, catalog number, or other proprietary identification shall be interpreted as establishing a standard of quality. If the Contractor wishes to furnish or use a proposed substitute or equal material, item of equipment, or type of construction, he shall make written application to SLVWD for approval, certifying in writing that the proposed substitute or equal will perform adequately the duties imposed by the general design, be similar and of equal substance to that specified, and be suited to the same use and capable of performing the same function as that specified, and stating all variations in costs pertaining to the application. No proposed substitute or equal shall be ordered or installed without the written approval of SLVWD, and it shall be understood and agreed that the decision of SLVWD in this matter shall be final and binding.

Prior to the receipt of Bids, requests for consideration of proposed substitute or equal materials or equipment shall comply with the Bidding Requirements. After receipt of Bids, if the Contractor should wish to propose a substitute or equal item for any specified by brand or trade name, within five (5) work days after issuance of the Notice of Award, he shall in writing notify SLVWD of his intent to do so and at that time submit to SLVWD an itemized list of the item or items he proposes setting forth the various manufacturers' names and such other information he has available. Unless this notification is given within the time stated, the Contractor shall provide only the items specified by brand or trade name. If notification is so given to SLVWD, within thirty-five (35) work days after issuance of the Notice of Award, the Contractor shall supply data to SLVWD to substantiate the proposed substitution or equal. SLVWD will then decide whether the proposed substitution or equal is in fact equal in quality and utility to the specified trade or brand name items. It is agreed that the decision of SLVWD in this matter shall be final.

9.4.1 Use of Approved Substitutions or Equals. The Contractor's use of approved substitutions or equals shall in no way relieve the Contractor from compliance with the Contract Documents. The Contractor shall bear all extra expense resulting from providing or using approved substitutions or equals where they affect the adjoining or related Work, including the expense of required engineering, redesigning, drafting, and permits where

necessary, whether SLVWD's approval is given before or after receipt of Bids.

The Contractor shall approve engineering costs for review and evaluation of substitutions or equals prior to the performance of the engineering work using the form titled, "Authorization of Engineering Costs for Evaluation of Substitutions and Equals", bound herein (at the end of the General Conditions section of these Specifications). SLVWD's Representative will not perform the submittal review until the authorization form is signed and returned by the Contractor. If the Contractor does not provide this authorization, the submittal will be rejected.

The Contractor shall approve engineering costs associated with redesign of adjoining or related Work caused by substitutions or equals prior to the performance of the engineering work using the form titled "Authorization of Engineering Costs for Redesign Due to Substitutions or Equals", bound herein (at the end of the General Conditions section of these Specifications). SLVWD's Representative will not perform the redesign until the authorization form is signed and returned by the Contractor. If the Contractor does not provide the required authorization, the submittal which created the need for redesign will be requested.

SLVWD, at its own discretion, will deduct the authorized costs from the Contractor's monthly progress payment or will require direct payment of the authorized amounts by the Contractor to SLVWD's Representative providing the evaluation and/or redesign services.

- 9.4.2 Unauthorized Substitutions. If substitute materials or equipment are installed without SLVWD's approval, the Contractor shall remove the unauthorized materials or equipment and install those required by the Contract Documents at his expense.

ARTICLE 10 – SUBCONTRACTORS

- 10.1 Responsibility for Subcontractors. The Contractor shall be fully responsible for all acts and omissions of his Subcontractors, Sub-subcontractors, and of persons directly or indirectly employed by them and of persons for whose acts any of them may be liable to the same extent that he is responsible for the acts and omissions of persons directly employed by him. Under these Contract Documents, no Subcontractor or Sub-subcontractor will be recognized as such, and all persons and organizations engaged by the Contractor for the furnishing or installing of any part of the Work, either at the site or elsewhere, are considered as and agreed to be employees of the Contractor except with regard to insurance as provided in Article 6 and except with regard to payment as provided in Article 20. Nothing in the Contract Documents shall create any contractual relationship between any Subcontractor, Sub-subcontractor, or any person directly or indirectly employed by them, and SLVWD and the Engineer. The Contractor will be responsible for ensuring that the Subcontractor and any Sub-Subcontractor is registered with the DIR as required by Section 1725.5 of the California Labor Code.

- 10.2 Extent of Subcontracting. It is SLVWD's intent that the Work shall be performed and constructed by a Contractor who is staffed and equipped to construct the major portion of the Work with his own directly employed personnel and with the minimum feasible subcontracting. Subcontracting may be permitted by SLVWD to such extent as is shown to be necessary or advantageous to the Contractor without injury to the intent and interest of SLVWD.
- 10.3 Subcontractual Relations. All Work, performed for the Contractor by a Subcontractor shall be pursuant to an appropriate agreement between the Contractor (and where appropriate between Subcontractor and Subcontractor) which shall contain provisions that: (a) protect and preserve the rights of SLVWD and the Engineer with respect to the Work to be performed under the subcontract so that the Subcontracting thereof will not prejudice such rights; (b) require that such Work be performed in accordance with the requirements of the Contract Documents; (c) require under each subcontract to which the Contractor is a party the submission to the Contractor of applications for payment and claims for additional costs, extension of time, damages for delay or otherwise with respect to the subcontracted portions of the Work (via any Subcontractor or Sub-subcontractor where appropriate) in sufficient time that the Contractor may apply for payment in accordance with Article 20 and comply in accordance with the Contract Documents for like claims by the Contractor upon SLVWD; (d) waive all rights the contracting parties may have against one another for damages caused by fire or other perils covered by the property insurance except such rights as they may have to the proceeds of such insurance held by SLVWD as trustee as provided in subparagraph 6.2.7; and (e) obligate each Subcontractor specifically to consent to the provisions of this Paragraph 10.3.

ARTICLE 11 – LAWS AND REGULATIONS

- 11.1 Governing Law. The Contract Documents shall be governed by the law of the place of the Project.
- 11.2 Compliance. The Contractor shall inform himself/herself of all laws, ordinances, codes, rules, and regulations in any manner affecting those employed on the Work, or the materials used in the Work, or in any way affecting the conduct of the Work, and of all orders and decrees of bodies or tribunals having any jurisdiction or authority over the Work. He shall at all times himself give all notices and observe and comply with, and shall require all his agents, employees, Subcontractors, and Sub-subcontractors to observe and comply with all such applicable laws, ordinances, rules, regulations, orders, and decrees in effect or which may become effective before completion and acceptance of the Work; and shall protect and indemnify SLVWD and the Engineer against any claim of liability arising from or based upon the violation of any such law, ordinance, code, rule, regulation, order, or decree, whether by himself, his employees, or his Subcontractors or Sub-subcontractors, or any other person or organization employed for or upon the Work. If the Contractor observes that any requirement of the Contract Documents is at variance with such laws, ordinances, codes, rules, regulations, orders, or decrees, he shall promptly notify SLVWD in writing and shall not proceed with any Work affected by such variance without SLVWD's written instructions or the issuance of an appropriate Modification.

- 11.3 Permits, Fees, and Taxes. Unless otherwise provided in the Contract Documents, the Contractor shall secure and pay for all permits, governmental fees, and licenses necessary for the execution and completion of the Work. The Contractor shall pay all sales, consumer, use, and other taxes required by law including all taxes properly assessed against his equipment or property used in connection with the Work. All such costs shall be included in the bid prices.
- 11.4 Provisions of Law Deemed Inserted. Each and every provision of law required by law to be inserted in the Contract Documents shall be deemed to be inserted and the Contract Documents shall be read and enforced as though it were included. If through mistake or otherwise any such provision is not inserted, or is not correctly inserted, then upon application of either party to the Contract Agreement, the Contract Documents will be physically amended to make such insertion or correction and an appropriate Modification will be issued.
- 11.6 Validity of Agreement. The invalidity in whole or in part of any provision of this Agreement, by operation of law or judicial decree, shall not void or affect the validity of any other provision of this Agreement.

ARTICLE 12 – SUBMITTALS

- 12.1.1 General. Unless otherwise specified or directed by SLVWD, the Contractor shall submit to SLVWD for his review and approval all shop drawings, samples, materials lists, equipment, data, instruction manuals, record documents, manufacturers' equipment manuals, and other submittals required by the Contract Documents and herein, or subsequently as covered by Modifications. Submittals and their contents shall be properly prepared, identified, and transmitted as provided herein or as SLVWD may otherwise direct. Except for record documents and instructional manuals for operation and maintenance, submittal shall be approved before the material or equipment covered by the submittal is delivered to the site. The progress schedule required under Paragraph 2.6 shall be coordinated to this requirement.

Pursuant to this section of the General Conditions, the Contractor shall use the Transmittal Form, included herewith (located at the end of the General Conditions section), for submittal of shop drawings to the SLVWD. The procedures governing shop drawing submittal is contained in these General Conditions. Failure to comply with all requirements specified herein will constitute grounds for return of the shop drawings for proper re-submittal. The Contractor shall sequentially number each submittal. The Contractor may, within five (5) working days of the Notice of Award, submit to the Engineer an alternate Transmittal Form for review and approval for use under this Contract. The Engineer shall have the sole right for determination of the Transmittal Form to be used, and the Contractor shall use the form designated for use by the Engineer.

- 12.1.2 Deviations. At the time of the submission, the Contractor shall give notice in writing in the submittal of any deviation from the requirements of the Contract Documents. The deviations shall be clearly indicated or described, including all other changes required to correlate the Work. The Contractor

shall state in writing all variation in costs occasioned by the deviations and his assumption of the cost of all related changes if the deviation is approved.

- 12.1.3 Schedule of Submittals. The progress schedule required under Paragraph 2.6 shall allow not less than twenty (20) working days for the review of submittals, not including the time necessary for delivery or mailing, and shall cause no delay in the Work or the work of any other contractor. Extension of the Contract Time will not be granted because of the Contractor's failure to make timely and correctly prepared and presented submittals with allowance for the checking and review periods.
- 12.1.4 Method of Submittal. The Contractor shall deliver submittals by means of dated, signed, and sequence numbered transmittals on the Contractor's letterhead, identifying as to initial or resubmittal status, and fully describing the submittal contents. Submittals are not acceptable directly from Subcontractors, suppliers, or manufacturers. In each transmittal the Contractor shall state the Drawing numbers and Specification Sections, Articles, and paragraphs to which the submittal pertains; accompanying data sheets, catalogs, and brochures shall be identified in the same manner, and where several types or models are contained, the Contractor shall delete non-applicable portions or specifically indicate which portions are intended and applicable.
- 12.1.5 Contractor's Review and Approval. Every submittal of shop drawings, samples, materials lists, equipment data, instruction manuals, and other submittals upon which the proper execution of the Work is dependent shall bear the Contractor's review and approval stamp certifying that the Contractor (a) has reviewed, checked, and approved the submittal and has coordinated the contents with the requirements of the Work and the Contract Documents including related Work, (b) has determined and verified all quantities, field measurements, field construction criteria, materials, equipment, catalog numbers, and similar data, or will do so, and (c) states the Work covered by the submittal is recommended by the Contractor and the Contractor's guarantee will fully apply thereto. The Contractor's stamp shall be dated and signed by the Contractor in every case. It is expected that the Contractor will prepare his submittals in such a manner that he is able to obtain a submittal approval by the second submission. SLVWD reserves the right to deduct moneys from the amounts due to Contractor to cover the cost of the Engineer's review time beyond the second submission.
- 12.1.6 Corrections and Resubmittals. The Contractor shall make all required corrections and shall resubmit the required number of corrected submittals until approved. The Contractor shall direct specific attention in writing to revisions other than the corrections called for on previous submittals, and shall state in writing all variations in costs and his assumption of the cost of related changes the same as is required for deviations in subparagraph 12.1.1. Identify each resubmittal with number of the original submittal followed by consecutive letters starting with "A" for first resubmittal, "B" for second resubmittal, etc.
- 12.1.7 Check of Returned Submittals. The Contractor shall check submittals returned to him for correction and ascertain if the corrections result in extra cost to him above that included under the Contract Documents, and shall

give written notice to SLVWD within five (5) work days if, in his opinion, such extra cost results from corrections. By failing to so notify SLVWD or by starting any Work covered by a submittal, the Contractor waives all claims for extra costs resulting from required corrections.

- 12.1.8 Review and Approval. Submittals will be reviewed with reasonable promptness, but only for conformance with the design concept of the Project and with the information given in the Contract Documents. The approval of a separate item as such will not indicate approval of the assembly in which the item functions. The approval of submittals shall not relieve the Contractor of responsibility for any deviation from the requirements of the Contract Documents or for any revision in resubmittals unless the Contractor has given notice in writing of the deviation or revision at the time of submission or resubmission and written approval has been given to the specific deviation or revision, nor shall any approval relieve the Contractor of responsibility for errors or omissions in the submittals or for the accuracy of dimensions and quantities, the adequacy of connections, and the proper and acceptable fitting, execution, and completion of the Work.
- 12.1.9 Incomplete Submittals, including those not correctly transmitted, not correctly titled and identified, or not bearing the Contractor's review and approval stamp, will be returned to the Contractor without review.
- 12.1.10 Conformance. No Work represented by required submittals shall be purchased or commenced until the applicable submittal has been approved. Work shall conform to the approved submittals and all other requirements of the Contract Documents unless subsequently revised by an appropriate Modification, in which case the Contractor shall prepare and submit revised submittals as may be required. The Contractor shall not proceed with any related Work which may be affected by the Work covered under submittals until the applicable submittals have been approved, particularly where piping, machinery, and equipment and the required arrangements and clearances are involved.
- 12.1.11 Interrelated Submittals. Except where the preparation of a submittal is dependent upon the approval of a prior submittal, all submittals pertaining to the same class or portion of the Work shall be submitted simultaneously.
- 12.2 Shop Drawings. Each submittal shall be complete with respect to dimensions, design criteria, materials, connections, bases, foundations, anchors, and the like, and shall be accompanied by technical and performance data as necessary to fully illustrate the information in the shop drawings. Unless otherwise specified, each submittal shall include one set of reproducible digital copies.
- 12.3 Samples. Unless otherwise specified, each submittal shall include two (2) sets of samples. One set of approved samples and all disapproved samples will be returned to the Contractor. Samples of value retained by SLVWD will be returned to the Contractor after completion of the Work if the Contractor's first transmittal for the sample requests its return. Approved samples of manufactured items returned to the Contractor may be installed in the Work

if the location is recorded and the samples bear temporary identification as such.

- 12.4 Materials Furnished Under Standard Specifications. For materials specified by reference to standard or reference specifications, the Contractor shall prepare and submit for approval a list of such materials by manufacturer's names and identifications to the extent requested by SLVWD.
- 12.5 Material Lists. For each item listed, the Contractor shall include the manufacturer's name and address, trade or brand name, local supplier's name and address, catalog numbers and cuts, brochures, terms and conditions of manufacturer's guarantee and warranty, other information to fully describe the item, and supplementary information as may be required for approval. Cuts, brochures, and data shall be marked to indicate the items proposed and the intended use.
- 12.6 Equipment Data. The Contractor shall submit complete technical and catalog data for every item of mechanical and electrical equipment and machinery to be incorporated in the Work, including components. Submittal copies shall be bound, indexed, and contain information as required in Paragraph 12.5 for submittal of materials lists and shall further include specific information on performance and operating curves and data, ratings, capacities, characteristics, efficiencies, and other data to fully illustrate and describe the items as may be specified or required for approval. Data shall be submitted in sets covering complete systems or functioning units.
- 12.7 Instruction Manuals. The Contractor shall obtain data from the various manufacturers and submit instruction manuals covering all mechanical equipment and machinery installed in the Work.
- 12.7.2 Contents. Each manual shall have an index listing the contents. Information in the manuals shall include not less than (a) general, introduction and overall equipment description, purpose, functions, and simplified theory of operation, (b) specifications, installation instructions, procedures, sequences, and precautions, including tolerances for level, horizontal, and vertical alignment, (d) grouting requirements including grout spaces and materials, (e) list showing lubricants for each item of mechanical equipment, approximate quantities needed per year, and recommended lubrication intervals; where possible, types of lubricants shall be consolidated with equipment manufacturers' approval to minimize the number of different lubricants required for plant maintenance, (f) startup and beginning operation procedures, (g) operational procedures, (h) shut down procedures, (i) short and long term inactivation procedures, (j) maintenance, calibration, and repair instruction, (k) parts lists and spare parts recommendations, (l) lists of all special tools, instruments, accessories, and special lifting and handling devices required for periodic maintenance, repair, adjustment, and calibration, and (m) other information as may be specified or required for approval.
- 12.7.3 Format and Organization.
- a. Use drawings and pictorials to illustrate the printed text as necessary to fully present the information.

- b. Where information covers a family of similar items of equipment, identify the applicable portions by heavy weighted arrows, boxes or circles, or strike-out the inapplicable information. Non-conforming data are not acceptable and will be returned for rework and resubmittal.
- c. Contractor shall incorporate into books all Manufacturers' Equipment Manuals including those specified in pertinent Sections of the Specifications. These books shall be organized by Equipment Class in same manner and sequence as the Specifications, i.e. Mechanical, Electrical, Instrumentation, etc. Book size and quantity shall be sufficient for inclusion of all data, and be of type and quality hereinafter specified in Article 12.7.3.
- d. Within each book of manuals, provide a Table of Contents for that book. If more than one book is necessary for a Class of Equipment, place a complete Table of Contents for that Class of Equipment within each book of that Class.
- e. In addition, an overall Index of Contents shall be prepared in ten (10) sets and submitted separately to SLVWD for his insertion in his Operation and Maintenance Manuals.
- f. When a manufacturer's manual exceeds one (1) inch in thickness and is bound as specified in Article 12.7.3 it need not be rebound within another book, but the Overall Index shall refer to it by title and indicate that it is bound separately.

12.7.4 Manual Binding.

- a. Bind all books in sturdy hard covers fastened to provide full view of contents on each page, and ease of making content additions or replacements. No book shall be more than four (4) inches thick. Manuals less than one (1) inch thick shall be bound in substantial three-ring loose leaf binders; others shall have covers secured by operable locking-bars to permit full view opening with contents bound by hinged interfacing pairs of three-ring binding posts, Model S70468-12 by McBee, Springfield, MO., or Model 745483 by Inter-City, St. Louis, Mo., or equal.
- b. Permanently label face of cover and bound edge of each book "MANUFACTURERS' INSTRUCTION MANUAL," and indicate Class of Equipment, i.e., Mechanical, Electrical, Instrumentation, etc. or name specific equipment if a single unit is contained. Where more than one book is needed for a Class of Equipment or a single specific equipment unit, number books consecutively BOOK I, BOOK II, etc.
- c. If more than one Class of Equipment is contained in a book, separate each class with a tabbed stiff divider insert page.
- d. Prior to purchase or delivery, submit samples of each intended type of binder and obtain approval from SLVWD.

12.7.5 Manual Submittals. Submittals shall include two (2) copies of each manual, one of which will be returned to the Contractor marked to show the required

corrections or approval. When approved, the Contractor shall deliver ten (10) copies to SLVWD unless otherwise specified.

- 12.8. Manufacturers' Instructions. In addition to the instructions submitted under Paragraph 12.7, the Contractor shall submit manufacturers' instructions to the extent specified or requested by SLVWD for his determination of their adequacy and approval. When approved, the Contractor shall distribute copies to all those involved with the instructions.
- 12.9 Tools, Accessories, Spare Parts, and Maintenance Materials. The Contractor shall furnish and deliver all special tools, instruments, accessories, spare parts, and maintenance materials required by the Contract Documents, and shall furnish and deliver the special tools, instruments, accessories, and special lifting and handling devices shown in the instruction manuals approved under Paragraph 12.7. Unless otherwise specified or directed by SLVWD, the items shall be delivered to SLVWD, with the Contractor's written transmittal accompanying each shipment, in the manufacturers' original containers labeled to describe the contents and the equipment for which it is furnished. The Contractor shall deliver a copy of each transmittal to the Engineer for record purposes.
- 12.10 Continuance of Operations. The Contractor shall arrange and schedule the Work in such manner as to ensure that all existing utility treatment or disposal operations and facilities are maintained in operation and in no way disrupted or disabled as a result of the Work. The Contractor shall submit for approval a written plan and description of the proposed schedule, methods, and facilities to be employed in conforming to this requirement.
- 12.11 Record Drawings and Specifications. The Contractor shall maintain one record copy of all Drawings, Specifications, Addenda, Modifications, approved submittals, correspondence, and transmittals at the site in good order and readily available to SLVWD, the Engineer, and the Inspector. The Record Drawings shall be clearly and correctly marked and the Record Specifications annotated by the Contractor to show all changes made during the construction process at the time the changed Work is installed. No such changes shall be made in the Work unless previously authorized by a Modification or by specific approval of deviations or revisions in submittals.
- 12.11.1 Buried and Concealed Work. The Contractor shall record the precise location of all piping, conduits, ducts, cables, and like Work that is buried, embedded in concrete or masonry, or concealed in wood or metal framed walls and structures at the time such Work is installed and prior to concealment. Each feature of the concealed Work, such as the beginning and end of straight runs, radius center point of curved runs, angles, connections, plugged tees or other fittings for future connections, and like items shall be accurately located by not less than two dimensions to permanent structures. The depth below finish grade, slab, or paving shall be noted for buried pipe, conduit, or ducts at the beginning and end of straight grade runs and at all grade change points, excepting sewer or drain lines run between manholes. Should the Contractor fail to record such buried or concealed Work, he shall uncover the unrecorded Work to the extent required by SLVWD and shall satisfactorily restore and reconstruct the removed Work with no change in the Contract Price or the Contract Time.

- 12.11.2 Delivery. Upon completion and prior to final inspection of the Work, the Contractor shall submit the Record Drawings and Specifications to SLVWD for review, and shall make such revisions or corrections as may be necessary for them to be a true, complete, and accurate record of the Work in the opinion of SLVWD. When approved, the Contractor shall deliver the Record Drawings and Specifications to SLVWD.
- 12.12 Revision of Submittals. Whenever a Modification causes a change to the information contained in previously approved submittals, the Contractor shall submit information and data corresponding to the changed requirements for approval. After completion of the operational test required in Paragraph 17.4, the Contractor shall submit revised or additional information and data for the instruction manuals and equipment data as SLVWD may require. Revision submittals shall be submitted following the procedures required for previously approved submittals.

ARTICLE 13 – SAFETY PRECAUTIONS AND EMERGENCIES

- 13.1 Contractor's Responsibility for Safety. The Contractor shall be responsible for initiating, maintaining, and supervising all safety precautions and programs in connection with the Work. This requirement will apply continuously twenty-four (24) hours a day every day until final acceptance of the Work and shall not be limited to normal working hours. The duties of SLVWD, Engineer and Inspector do not include review of the adequacy of the Contractor's safety measures in, on, or about the site and vicinity.
- 13.2 Safety Officer. The Contractor shall designate a responsible member of his organization at the site whose duty shall be the prevention of hazards and accidents. This person shall be the Contractor's Superintendent unless otherwise designated in writing by the Contractor to SLVWD.
- 13.3 Safety Measures. The Contractor shall comply with all laws, ordinances, codes, rules, regulations and lawful orders of any public authority having jurisdiction for the safety of persons or property or to protect them from damage, injury or loss. The Contractor shall comply with the "Manual of Accident Prevention in Construction" published by the Associated General Contractors of America, Inc., including the recommendations for safe construction methods and the requirements for the guarding of machinery and equipment therein, to the extent that the provisions of the manual are not in conflict with applicable laws, ordinances, rules, regulations, and orders. The Contractor shall maintain copies of all documents mentioned or referenced in this paragraph readily available at the site until the Work is completed.
- 13.4 Warnings and Barricades. The Contractor shall provide and maintain barricades, guards, temporary bridges and walkways, watchmen, night lights and danger signals illuminated from sunset to sunrise, and all other necessary appliances and safeguards to protect the Work, life, property, the public, excavations, equipment, and materials. Barricades shall be of substantial construction and shall be painted such as to increase their visibility at night. Suitable warning signs shall be so placed and illuminated at night as to show in advance where construction, barricades, or detours exist. Guard rails shall be provided for bridges and walkways over or

adjoining excavations, shafts, and other openings and locations where injury may occur.

- 13.5 Fire Prevention. The Contractor's Safety Officer shall inspect the entire Work and site, including storage areas, at frequent intervals to verify that fire prevention measures are constantly enforced.
- 13.5.1 Fire Extinguishers and Hoses. The Contractor shall furnish and maintain fully charged fire extinguishers of the appropriate type, supplements with temporary fire hoses wherever an adequate water supply exists, at the places where burning, welding, or other operations that may cause a fire are being performed.
- 13.5.2 Flammable or Toxic Materials. Only a working supply of flammable or toxic materials shall be permitted in or on any of the permanent structures and improvements, and shall be removed therefrom at the end of each day's operations. The Contractor shall store flammable or toxic materials and waste separate from the Work and stored materials for the Work in a manner that prevents spontaneous combustion or dispersion, and none shall be placed in any sewer or drain piping nor buried on SLVWD's property.
- 13.6 Safety Helmets, Clothing, and Equipment. The Contractor shall not permit any person for whom he is responsible or liable to enter or remain on the site of the Work unless the person is equipped with and wearing a safety helmet and other protective clothing and safety equipment conforming to the requirements of Paragraph 13.3, and shall discharge from the site all persons not so equipped. The Contractor shall post conspicuous signs at appropriate locations warning the public and persons engaged upon the Work of this requirement. The Contractor shall furnish for their temporary use such safety helmets, protective clothing, and safety equipment as SLVWD, the Engineer, or their representatives may request of him.
- 13.7 Hazardous Areas. The Contractor shall not permit or allow any person or persons to enter any pipe or space containing hazardous or noxious substances person for whom he is responsible or liable to enter or remain on the site of the Work unless the person is equipped with and wearing a safety helmet and other protective clothing and safety equipment conforming to the requirements of Paragraph 13.3, and shall discharge from the site all persons not so equipped. The Contractor shall post conspicuous signs at appropriate locations warning the public and persons engaged upon the Work of this requirement. The Contractor shall furnish for their temporary use such safety helmets, protective clothing, and safety equipment as SLVWD, the Engineer, or their representatives may request of him.
- 13.8 Emergencies.
- 13.8.1 Work During an Emergency. The Contract shall perform any and all operations and shall furnish any materials and equipment necessary during an emergency endangering life or property and, in all cases, shall notify SLVWD of the emergency as soon as practicable, but shall not wait for instruction before proceeding to properly protect both life and property. Any additional compensation or extension of Contract Time claimed by the Con-

tractor on account of an emergency shall be applied for as provided in Paragraph 16.4.

- 13.8.2 Representatives for Emergencies. The Contractor shall file with SLVWD a written list giving the names, addresses, and telephone numbers of at least two of his representatives who can be contacted at any time in case of emergency. The representatives shall be fully authorized and equipped to correct any unsafe or inconvenient conditions on short notice. The Contractor shall promptly notify SLVWD of all changes in the listing.

ARTICLE 14 – SEPARATE CONTRACTS

- 14.1 Award of Separate Contracts. SLVWD reserves the right to award other contracts in connection with other portions of the Project. When separate contracts are awarded for different portions of the Project, "the Contractor" in the contract documents in each case shall be the contractor who signs each separate contract. The Contractor shall not cause any unnecessary hindrance or delay to any other contractor working on the Project. If the performance of any contract for the Project is likely to be interfered with by the simultaneous execution of some other separate contract or contracts, SLVWD will decide which contractor may proceed. SLVWD shall not be responsible for any damages suffered or extra costs incurred by the Contractor resulting directly or indirectly from the award or performance or attempted performance of any other separate contract or contracts on the Project, or caused by any decision or omission of SLVWD respecting the order of precedence in the performance of the separate contracts awarded for completion of the Project. Any costs caused by defective or ill-timed work shall be borne by the contractor responsible therefore.

- 14.2 Mutual Responsibility of Contractors. The Contractor shall cooperate with other contractors with regard to storage of materials and execution of their work, and shall coordinate with them with respect to construction scheduling and sequence of operations, all subject to the approval of SLVWD. The Contractor shall properly connect his Work to the work of separate contractors, and shall inspect the work of other contractors affecting his Work and promptly report to SLVWD in writing any irregularities or defects in the separate contract work which renders it unsuitable for reception or connection of his Work. Failure of the Contractor to inspect and report shall constitute an acceptance of the other contractor's work as fit and proper to receive his Work, except as to defects which may develop in the other separate contractor's work after the execution of the Contractor's Work.

Each Contractor shall monitor the schedule and progress of each other Contractor whose work affects his own work, and shall be responsible for giving timely notice to SLVWD of potential problems of interface so that SLVWD can mitigate the issue.

- 14.3 Cutting and Patching Under Separate Contracts. The Contractor shall be responsible for any cutting, fitting, and patching that may be required to complete his Work except as otherwise specifically provided in the Contract Documents. The Contractor shall not endanger any work of any other contractor by cutting, excavating, or otherwise altering any work and shall

not cut or alter the work of any other contractor except with the written consent of SLVWD.

- 14.4 Claims Between Separate Contractors. Should the Contractor cause damage to the work or property of any separate contractor on the Project, the Contractor shall, upon due notice, settle with such other contractor by agreement or arbitration, if he will so settle. If such separate contractor sues SLVWD or initiates an arbitration proceeding on account of any damage alleged to have been so sustained, SLVWD will notify the Contractor who shall defend such proceedings at the Contractor's expense, and if any judgment or award against SLVWD arises therefrom, the Contractor shall pay or satisfy it and shall, as provided in Paragraph 20.12, pay SLVWD for all attorneys' fees, court or arbitration costs, and additional administrative, professional, consultant, inspection, testing, and other service costs which SLVWD has incurred.

ARTICLE 15 – SLVWD'S AND ENGINEER'S STATUS DURING CONSTRUCTION

- 15.1 Authority of SLVWD. SLVWD shall have the authority to enforce compliance with the Contract Documents. On all questions relating to quantities, the acceptability of materials, equipment, or Work, the adequacy of the performance of the Work, and the interpretation of the Drawings and Specifications, the decision of SLVWD is final and binding and shall be precedent to any payment under the Contract Agreement unless otherwise provided in the Contract Documents. SLVWD shall have the authority to stop the Work or any part thereof as may be necessary to ensure the proper execution of the Work, to disapprove of or reject Work which is defective, to require the uncovering and inspection or testing of Work as provided in Paragraph 17.5, to require re-examination of Work as provided in Paragraph 18.4, to issue interpretations and clarifications as provided in Paragraph 3.2, to order minor changes or alterations in the Work as provided in Paragraph 16.6, and other authority as provided elsewhere in the Contract Documents. SLVWD shall not be liable for the results of any ruling, interpretation, or decision rendered or request, demand, instruction, or order issued by him in good faith. The Contractor shall promptly comply with request, demands, instructions, and orders from SLVWD.
- 15.2 Engineer's Observation of the Work. The Engineer will make periodic observations of the progress and quality of the executed Work and will determine, in general, if the Work is proceeding in accordance with the Contract Documents. The Engineer will not be required to make exhaustive or continuous observations to check the quality or quantity of the Work. Neither observations by the Engineer nor inspections, tests, or approvals by persons other than the Contractor shall relieve the Contractor from his obligations to perform and construct the Work in accordance with the requirements of the Contract Documents. SLVWD will inform the Contractor in writing of other duties of the Engineer under the Contract Documents, if any.
- 15.3 Limitations On Responsibility. SLVWD and the Engineer will not be responsible for construction means, methods, techniques, procedures, sequences, or the safety precautions and programs incident thereto, or for the acts or omissions of the Contractor or any Subcontractor,

Sub-subcontractor, or any of their agents or employees, or any other persons performing any of the Work, or for the Contractor's failure to perform and construct the Work in accordance with the Contract Documents. Neither the Engineer's authority to act under the Contract Documents nor any decision made by him in good faith either to exercise or not exercise such authority shall give rise to any duty or responsibility of the Engineer to the Contractor, any Subcontractor or Sub-subcontractor, any of their agents or employees, or any other person performing any of the Work, nor shall anything in the Contract Documents create any contractual relationship between any of them and the Engineer.

- 15.4 Protests. If the Contractor considers any Work requested or ordered of him to be outside the requirements of the Contract Documents, or considers any request, demand, instruction, order, ruling, or decision of SLVWD to be unfair, he shall, within ten (10) work days after any such request, demand, instruction, order, ruling, or decision is made or given, file a written protest with SLVWD stating clearly and in detail his objections and the reasons therefore. Except for written protests as are made of record in the manner and within the time stated herein, the Contractor shall be deemed to have waived and does hereby waive all grounds for protests or objections to such requests, demands, instructions, orders, rulings, or decisions. SLVWD will issue a written decision regarding each protest so filed with reasonable promptness.

ARTICLE 16 – CHANGES IN THE WORK

- 16.1 Change Orders. Without invalidating the Contract Agreement and without notice to sureties or insurers, SLVWD may, at any time, order additions, deletions, or revisions in the Work; these will be authorized by Change Order. The Contractor shall comply promptly with the requirements of all executed Change Orders. The Work involved in Change Orders shall be executed under the applicable conditions and requirements of the Contract Documents. If any Change Order causes an increase or decrease in the Contract Price or an extension or shortening of the Contract Time, an equitable adjustment will be made and included in the Change Order. Additional or extra Work performed by the Contractor without authorization of a Change Order will not entitle the Contractor to an increase in the Contract Price or an extension of the Contract Time, except as provided in subparagraph 13.8.1 for emergencies and in Paragraph 18.4 for the re-examination of Work.
- 16.2 Valuation of Change Orders. When required by SLVWD, the Contractor shall submit in the form prescribed by SLVWD an itemized cost breakdown with supporting data of the quantities and prices used by him in computing the value of any change that may be ordered. The cost or credit to SLVWD resulting from a change in the Work will be determined by one or more of the following methods: (a) by an acceptable lump sum proposal from the Contractor, (b) by unit prices accepted by SLVWD and stated in the Contract Documents or unit prices subsequently fixed by agreement between the parties, (c) by cost and a mutually acceptable fixed amount for overhead and profit, or (d) by force account when directed in writing and administered by SLVWD. Under the methods described in (c) and (d), the Contractor shall maintain an accurate written daily direct cost record pertaining to such

ordered Work in the form and detail acceptable to SLVWD. The Contractor shall certify each daily record to be true and correct, and shall furnish copies to SLVWD as the ordered Work progresses. The direct costs so recorded shall include only the labor cost for workmen and foremen (payroll taxes and assessments, fringe benefits, employer's contributions, workers' compensation coverage, withholdings required by law, and other verified direct labor costs included), the cost of materials and equipment delivered and installed in such Work as substantiated by appropriate documents, the cost of construction machinery and equipment based on fair rental values acceptable to SLVWD, and the cost of incidentals directly related to such Work. The direct costs shall not include any labor or office costs pertaining to the Contractor, his superintendents, his office staff and office facilities, or anyone not directly employed on such Work, nor the premium costs for bonds or insurance other than workers' compensation insurance, nor the cost or rental of small tools as all such indirect costs form a part of the Contractor's overhead expense. Under the method described in (d), the maximum percentage which will be allowed for the Contractor's combined overhead and profit will be: (1) for all such Work done by his own organization, the Contractor may add up to ten (10) percent of his actual net increase in cost, and two (2) percent for all such Work done by Subcontractors, each Subcontractor may add up to ten (10) percent of his actual net increase in costs for combined overhead and profit and the Contractor may add up to five (5) percent of the Subcontractor's total for his combined overhead and profit. The amount of credit to be allowed by the Contractor to SLVWD for any such change which results in a net decrease in cost will be the amount of the actual net decrease as determined by SLVWD taking into consideration adjustments for overhead and profit as determined herein, plus deductions for combined overhead and profit as computed in (1) and (2) above. When both additions and credits are involved in any one change, the combined overhead and profit shall be figured on the basis of the net difference.

- 16.3 Notice to Sureties. The Contractor shall notify his sureties and the carriers of the insurance furnished and maintained by him of any changes affecting the general scope of the Work or change in the Contract Price, and the amount of the applicable Bonds and the coverage of the insurance shall be adjusted accordingly. The Contractor shall furnish proof of such adjustments to SLVWD.
- 16.4 Contractor's Claims. If the Contractor wishes to make a claim for a change in the Contract Price or the Contract Time, the Contractor shall give SLVWD written notice thereof within ten (10) work days after the occurrence of the event giving rise to such claim. This notice shall be given by the Contractor before proceeding to execute the Work covered by the claim except in an emergency endangering life or property. No such claim shall be valid unless so made. Any change in the Contract Price or the Contract Time resulting from a claim that is approved by SLVWD will be authorized by Change Order.
- 16.5 Adjustment of Unit Prices. If unit prices are stated in the Contract Documents or subsequently agreed upon, and if the quantities originally contemplated are so changed (by 30% or greater quantity change) in a proposed Change Order such that application of the agreed unit prices to

the quantities of Work proposed will create a hardship on SLVWD or the Contractor, the applicable unit prices will be equitably adjusted to prevent such hardship by negotiation or by force account.

- 16.6 Minor Changes. SLVWD may issue written Field Orders or other written orders that authorize minor changes or alterations in the Work consistent with the overall intent of the Contract Documents that do not involve an adjustment in the Contract Price or an extension of the Contract Time. Such orders shall be binding on the Contractor and he shall carry out such orders promptly. If the Contractor believes any minor change or alteration ordered by SLVWD entitles him to an increase in the Contract Price or an extension of the Contract Time, he may make a claim therefore as provided in Paragraph 16.4.
- 16.7 Information Revisions Caused by Change Orders. As provided in Paragraph 12.12, whenever a Change Order or other Modification causes a change in the information contained in previously approved submittals, the Contractor shall include in the itemized breakdown required of him under Paragraph 16.2 all costs for preparing and submitting revised information and submittals corresponding to the changed requirements. If the Change Order or other Modification causes no change in such information or submittals, the Contractor shall so certify in writing in his itemized breakdown.
- 16.8 Change Order Procedure. The following procedure will be followed in issuing a change order.
- 16.8.1 The Inspector identifies the need for a change in plans.
- 16.8.2 The Inspector discusses the required change with the Engineer and Contractor.
- 16.8.3 The Engineer prepares a detailed description of the Work required, including any additional drawings, and prepares a change order in the required format.
- 16.8.4 The change order is provided to the Contractor for his review and negotiation of the price for the change.
- 16.8.5 The Engineer and Contractor agree on the Work to be performed and price for doing the Work. Each signs the change order, indicating that both agree as to the terms of performing the required change.
- 16.8.6 The Engineer submits the change order to the SLVWD through the designated SLVWD Representative.
- 16.8.7 If the SLVWD Staff concurs with the change order, it is submitted to the General Manager for approval and signature if the change order involves a change in a price that is within the General Manager's approval authority. If the change order involves a change in price that is greater than the General Manager's approval authority, it will be submitted to the Board of Directors for approval. If the Board of Directors approves, the General Manager signs the change order, authorizing the change to be implemented.

- 16.9 Field Order Procedure. The following procedure will be followed in issuing a field order.
- 16.9.1 Inspector identifies the need for a field order change.
- 16.9.2 The Inspector discusses the required change with the Engineer and Contractor.
- 16.9.3 The Inspector prepares a detailed written description of the minor changes or alterations in the work.
- 16.9.4 The Contractor reviews field order.
- 16.9.5 The Inspector and Contractor agree on field order work to be performed. Each signs the field order, indicating that both agree as to the terms of performing the required changes.
- 16.9.6 General Manager signs the field order authorizing the change to be implemented.

ARTICLE 17 – ACCESS, INSPECTIONS, AND TESTS

- 17.1 Access to the Work and Records. SLVWD, the Engineer, the Inspector, and the representatives of any Federal, State, or other public body or authority having jurisdiction of the Project shall have, at all times and for any purpose, immediate access to the Work and the premises used by the Contractor for the Work and shall have access to the places where materials or equipment are being fabricated, manufactured, or produced for the Work. To the extent requested by SLVWD, the Contractor shall furnish access to the purchase orders and records, invoices, bills of lading, payroll records, and other documents and records pertaining to the Work, or shall furnish certified true copies thereof at his expense.
- 17.2 Inspection. SLVWD will furnish inspection of the Work at no cost to the Contractor except as provided in Paragraphs 4.3, 14.4, 17.5, 17.6, 18.1, and 21.2, and except for inspections required to be furnished and paid for by the Contractor elsewhere in the Contract Documents. All Work shall be performed and constructed under the inspection of the Inspector unless waived in writing by SLVWD in each case or exempted wholly or in part from inspection elsewhere in the Contract Documents. Any Work requiring such inspection that is performed or constructed in the absence of the Inspector shall be considered defective and is subject to rejection. The Contractor shall give written notice to SLVWD at least five (5) work days in advance of the performance of any part of the Work requiring special inspection by someone other than the Inspector and shall state the probable duration of the required special inspection. Inspection of any material or equipment at the factory or shop will not constitute an acceptance. The Inspector is authorized to suspend any part or all of the Work, by notice to the Contractor confirmed in writing, when a question arises as to whether the materials or equipment being installed or the methods or workmanship being used comply with the Contract Documents until such question is decided by SLVWD. The Inspector is not authorized to accept or reject any Work, to modify or change any requirement of the Contract Documents, to advise or instruct the Contractor or his employees as to the prosecution of the Work,

to perform any duty or service for the Contractor, or relieve the Contractor of the obligation to fulfill any conditions and requirements of the Contract Documents.

- 17.3 Testing. All Work, materials, and equipment to be performed and constructed by the Contractor are subject to testing for compliance with the Contract Documents and shall be tested when required by the Contract Documents. The Contractor shall give SLVWD timely written notice of the dates and times that testing is to be performed at the site or the place of manufacture or fabrication. All tests are subject to the observation of the Engineer and approval of SLVWD and shall be performed as directed by SLVWD unless otherwise provided in the Contract Documents. Materials or equipment required to be tested prior to installation shall not be installed until SLVWD has approved the test results and the tested material or equipment in writing. Under these Contract Documents, the Contractor shall employ the services and pay the costs of tests performed by a testing laboratory or agency for field slump tests, concrete strength, optimum moisture, soil compaction tests, and painting/cratering in the field and at the shop. The Contractor shall bear all other testing costs. The Contractor shall pay SLVWD, in accordance with Paragraph 20.12, any cost SLVWD incurs for test where the tested material or equipment fails the test and for retesting caused by failure disclosed in previous tests.
- 17.3.1 Contractor's Testing Agency. If materials or equipment are required to be tested by a testing laboratory or agency employed by the Contractor, the testing laboratory or agency shall be satisfactory to and approved by SLVWD. The Contractor shall deliver five (5) certified copies of each test report to SLVWD unless otherwise specified.
- 17.3.2 Test Samples. The Contractor, at his expense, shall furnish samples of materials to be tested in sufficient time before use to allow for testing and to cause no delay in the Work.
- 17.3.3 Test Costs. The Contractor shall bear all testing costs unless otherwise provided in the Contract Documents.
- 17.4 Operational Tests. After the Work is completed and as one of the precedents to final inspection, the Contractor shall perform operational tests as required by the Contract Documents and as required to demonstrate to SLVWD the correct and proper operation of the various facilities forming a part of the Work including but not limited to the correct sequences of operation and the satisfactory performance of all components. The Contractor shall repair, replace, adjust, or otherwise correct the improper operation of any system or component and all faulty or defective Work as SLVWD may require for his approval. Based upon the operational tests results, the Contractor shall prepare and submit revised or additional information and data for the previously approved submittals as required by SLVWD and as provided in Paragraph 12.12. Each operational test shall be performed continuously for not less than 168 hours (7 days).
- 17.5 Uncovering the Work. Any Work that is covered by the Contractor before required inspections or tests are performed or approvals are given shall be uncovered by the Contractor to the extent directed by SLVWD, and the Contractor shall bear all the expense for uncovering, exposure, inspection, testing, and of satisfactory reconstruction.

- 17.6 Inspections, Tests, and Approvals Required By Others. If the laws, ordinances, rules, regulations, or orders of any public body or authority having jurisdiction require any Work to be specifically inspected, tested, or approved by someone other than the Contractor, SLVWD, the Engineer, or the Inspector, the Contractor shall give all required notices and make all required arrangements therefore, and shall deliver to SLVWD certificates of inspection, testing, or approval issued by the applicable public bodies or authorities having jurisdiction. The cost of all such inspections, tests, and approvals shall be borne by the Contractor unless otherwise provided in the Contract Documents.
- 17.7 Soil Compaction Testing. The Contractor shall employ the services and pay the costs of tests performed by a testing laboratory for optimum moisture and soil compaction tests in the field.

ARTICLE 18 – DEFECTIVE WORK

- 18.1 Correction of Defective Work. All Work, material, or equipment that is unsatisfactory, faulty, incomplete, or does not conform to the Contract Documents, or does not meet the requirements of any inspection, test, or approval is defective. If the Work or any part thereof is found to be defective, whether or not manufactured, fabricated, installed, completed, or over-looked and accepted by SLVWD, the Contractor shall, promptly and in accordance with the written instructions of SLVWD and within the reasonable time limits stated therein, either correct such defective Work or, if it has been rejected by SLVWD, remove it from the site and replace it with non-defective and conforming Work. The Contractor shall bear all costs for the correction or removal and replacement of defective Work and all additional direct and indirect costs SLVWD may incur on account of defective Work including the costs of additional administrative, professional, consultant, inspection, testing, and other services. If such additional costs are incurred by SLVWD prior to the making of final payment, a Change Order will be issued to effect a reduction in the Contract Price in the amount of SLVWD's additional costs; otherwise, the Contractor shall pay the amount to SLVWD in accordance with Paragraph 20.12. The Contractor shall also bear all costs of making good all Work and the work and property of separate contractors, SLVWD, and others that is destroyed or damaged by his correction or removal and replacement of his defective Work.
- 18.2 SLVWD's Right to Correct Defective Work. If the Contractor fails to correct or remove and replace defective Work in accordance with the requirements of Paragraph 18.1, SLVWD may correct or remove and replace it without prejudice to any other remedy SLVWD may have, and SLVWD may store the removed materials or equipment at the expense of the Contractor. If the Contractor does not pay the cost of such removal and storage within ten (10) days thereafter, SLVWD may upon ten (10) additional days' written notice sell such removed Work at auction or private sale and shall account for the net proceeds or deficit thereof, after deducting all expenses SLVWD may incur from such removal, storage, or sale. If SLVWD corrects or removes and replaces defective Work prior to the making of final payment, one or more Change Orders will be issued to effect appropriate reductions in the Contract Price for all costs and expenses incurred by SLVWD in the correction or removal and replacement of defective Work, adjusted to account for the net proceeds or deficit of said auction or sale, if any, and all

additional costs SLVWD may incur on account of defective Work as provided in Paragraph 18.1; otherwise, the Contractor shall pay to SLVWD the amount of all such costs and expenses incurred by SLVWD adjusted to account for the net proceeds or deficit of said auction or sale, if any, in accordance with Paragraph 20.12.

18.3 SLVWD's Right to Accept Defective Work. SLVWD may accept defective Work instead of requiring its correction or removal and replacement. In such case, if acceptance occurs prior to the making of final payment, a Change Order will be issued incorporating the necessary revisions in the Contract Documents, including appropriate reduction in the Contract Price covering the value of such accepted defective Work and the additional costs SLVWD may incur on account of such defective Work as provided in Paragraph 18.1; or, if the acceptance occurs after the making of final payment, the amount that would have been the reduction in the Contract Price prior to the making of the final payment shall be paid by the Contractor to SLVWD in accordance with Paragraph 20.12.

18.4 Re-Examination of Work. If SLVWD, at any time prior to the final acceptance of the Work, orders reexamination of Work completed, including the uncovering, removing, exposing, dismantling, inspecting, or testing of Work covered by such order, the Contractor shall promptly comply with the order. If the Work so re-examined is defective, the Contractor shall correct or remove and replace it with nondefective and conforming Work in accordance with all the provisions of Paragraph 18.1 and also shall bear the cost of the satisfactory reconstruction of the Work. If the Work so re-examined is not defective or if any defective or deficient condition discovered was caused by a separate Contractor employed on the Project, the Contractor shall satisfactorily reconstruct the Work as ordered by SLVWD and, if claim is made as provided in Paragraph 16.4, a Change Order will be issued to compensate the Contractor for his Work under such order, valued as provided in Paragraph 16.2, and to effect an appropriate adjustment of the Contract Time.

ARTICLE 19 – GUARANTEES AND WARRANTIES

19.1 Contractor's Guarantee. The Contractor shall warrant and guarantee the entire Work and all parts thereof, including that performed and constructed by Subcontractors, Sub-subcontractors, and others employed directly or indirectly on and for the Work, against faulty or defective materials, equipment, or workmanship for a period of one (1) year from the date of SLVWD's written final acceptance of the Work or such longer period of time as may be prescribed by law or by the terms of any special guarantee or warranty required by the Contract Documents.

19.2 Bonds and Insurance. The performance bond and the public liability and property damage insurance required of the Contractor in Article 6 shall remain in full force and effect for the entire time of the Contractor's guarantee.

19.3 Corrections During Guarantee Period. The Contractor's correction of defective Work during the guarantee period shall be in accordance with all the provisions of Paragraph 18.1 or SLVWD may correct or accept it as provided in Paragraphs 18.2 and 18.3.

- 19.4 Guarantee of Work on Property of Others. The Contractor's guarantee shall cover and include any of the Work installed on property not owned by SLVWD, whether public or private, and shall include the repair of damage to improvements and existing conditions on such other property caused by settlement or otherwise resulting from the Contractor's operations unless the owner of such other property shall in writing release SLVWD from liability and responsibility for Work or damage therefrom on such other property.
- 19.5 Manufacturer's Warranties. As a precedent to final inspection, the Contractor shall deliver to SLVWD all the manufacturers' warranties required by the Contract Documents, with SLVWD named as beneficiary. In addition, for all equipment and machinery bearing a manufacturer's warranty that extends for a longer period of time than the Contractor's guarantee, the Contractor shall secure and deliver the warranties to SLVWD in the same manner.

ARTICLE 20 – PAYMENTS AND COMPLETION

- 20.1 Schedule of Values. Prior to applying for the first progress payment, the Contractor shall submit to SLVWD for approval, in the form directed by or acceptable to SLVWD, a complete schedule of the values of the various portions of the Work, including quantities and unit prices if required by SLVWD, aggregating the Contract Price (except in cases and to the extent that accepted unit prices form the basis for payment). The schedule shall subdivide the Work into component parts in sufficient detail to serve as the basis for progress payments during construction, to coordinate with the progress schedule required under Paragraph 2.6, to form the basis for possible change orders or field orders and shall be supported by such data to substantiate its correctness as SLVWD may require. Each item in the Schedule of Values shall include its proper share of overhead and profit. An unbalanced breakdown providing for overpayment to the Contractor on items of Work performed during the initial phases of the Work, such as mobilization, will not be approved. The Schedule of Values, when approved by SLVWD, shall be used only as a basis for the Contractor's applications for payment and not for additions to or deductions from the Contract Price.
- 20.2 Contractor's Certification. All applications for payment shall contain the Contractor's certification that all his labor for the period for which payment is claimed has been paid, including all amounts to the account of such labor lawfully required to be allocated, withheld, or set aside, and that he has assured himself and represents that all labor on the account of Subcontractors or Sub-subcontractors for which payment amounts are claimed has also been paid.
- 20.3 Contractor's Warranty of Title. The Contractor warrants and guarantees that title to all Work, materials, and equipment covered by an application for payment, whether incorporated in the Work or not, will have passed to SLVWD prior to the making of the application for payment, free and clear of all liens, claims, security interests or encumbrances (hereafter in these General Conditions referred to as "liens"); and that no Work, materials, or equipment covered by an application for payment will have been acquired by the Contractor or by any other person performing the Work at the site or furnishing materials and equipment for the Work, subject to an agreement under which an interest therein or encumbrance thereon is retained by the seller or otherwise imposed by the Contractor or such other person.

- 20.4 Progress Payments. Unless otherwise provided in the Contract Documents, at least four (4) work days before each progress payment application falls due, but not more often than once a month, the Contractor shall submit to SLVWD for review the itemized progress payment application in the form required by SLVWD, filled out and signed by the Contractor and supported by such data substantiating the Contractor's right to payment as SLVWD may require. Any progress payment application not accompanied by the revised progress schedule required of the Contractor in Paragraph 2.6 will be returned to the Contractor. Progress payments shall be made in accordance with the withholding requirements of Public Contract Code Section 9203.

Pursuant to Section 20104.50 of the California Public Contract Code, upon receipt of a payment request, SLVWD shall review such request as soon as practicable after receipt for the purpose of determining that the payment request is a proper payment request. Any payment request determined not to be a proper payment request suitable for payment shall be returned to the Contractor as soon as practicable, but not later than seven (7) days after receipt. The returned request shall be accompanied by a document setting forth in writing the reasons why the payment request is not proper. If SLVWD fails to make any progress payment within thirty (30) days after receipt of an undisputed and properly submitted payment request, SLVWD shall pay interest to the Contractor equivalent to the legal rate set forth in subdivision (a) of Section 685.010 of the California Code of Civil Procedure. A "progress payment" includes all payments due to the Contractor, except that portion of the final payment designated by this Agreement as retention earnings. A payment request shall be considered properly executed if funds are available for payment of the payment request and payment is not delayed due to an audit inquiry by a financial officer of SLVWD.

Pursuant to Section 10262 of the California Public Contract Code and section 7108.5 of the California Business and Professions Code, the Contractor shall pay its Subcontractors, within seven (7) days of receipt of each progress payment, the respective amounts allowed the Contractor on account of the work performed by its Subcontractors, to the extent of each Subcontractor's interest therein.

- 20.4.1 Progress Payment for Materials and Equipment. If an application requests payment on account of imperishable materials or equipment not incorporated in the Work but delivered and suitably stored at the site, or at some other location approved by SLVWD and agreed to in writing, the application shall be accompanied by such bills of sale, data, and other procedures satisfactory to SLVWD as will establish SLVWD's title to such materials or equipment or otherwise protect SLVWD's interest including applicable liability and property insurance and transportation to the site. Payment on account of such materials or equipment will not include any amount for the Contractor's overhead or profit or relieve the Contractor of his obligation to protect and install such materials or equipment in accordance with the Contract Documents and for the restoration of damaged or defective Work.
- 20.4.2 Retention. SLVWD will retain a portion of the amount otherwise due the Contractor. Unless otherwise provided in the Contract Agreement or

subsequently agreed by the parties, SLVWD will retain an amount equal to five percent (5%) of the estimated value of the actual Work completed and five percent (5%) of the value of material delivered on the ground or stored subject to, or under the control of, SLVWD and unused.

20.4.3 Approval of Progress Payments. Upon receipt of an application for progress payment, the application shall be reviewed by SLVWD as soon as practicable after receipt for the purpose of determining that the payment application is a proper payment application. Any payment application determined not to be a proper payment application suitable for payment shall be returned to the Contractor as soon as practicable, but not later than seven (7) calendar days, after receipt. An application returned pursuant to this paragraph shall be accompanied by a document setting forth in writing the reasons why the payment application is not proper. SLVWD shall make any progress payment within 30 days after receipt of an undisputed and properly submitted payment request from the Contractor. The number of days available to SLVWD to make a payment without incurring interest equivalent to the legal rate set forth in subdivision (a) of Section 685.010 of the Code of Civil Procedure shall be reduced by the number of days by which SLVWD exceeds the seven (7) calendar day return requirement set forth in this paragraph.

20.4.4 Each application for progress payment shall be accompanied by the following. Progress Payment Applications not accompanied by Items 1, 2, 3, and 4 below will be returned to the Contractor.

1. Progress Report – A narrative summary indicating the status of the Work performed and other pertinent activities including the actual percentage of Work completed, an estimate of the percentage of Work to be completed in the succeeding month, a revised CPM schedule, problem areas and manpower used by trade and hours. If the Work has fallen behind the schedule, the Contractor shall state how the time is to be made up to remain on schedule.
2. Record Drawings and Specifications – Submit changes during previous month. These may be photocopies of the Specifications or bluelines of the drawing sheets changed.
3. Certified Payrolls – Submit copies of certified payroll including fringe benefit statements for each employee during the progress period. The Contractor and each Subcontractor must comply with Sections 1776 and 1771.4(a)(3)(A) of the Labor Code regarding payroll records.
4. Progress Photographs:
 - a. General - Provide photographs of the site and construction throughout the progress of Work, acceptable to SLVWD. Photographs shall be taken on the cutoff date for each application for payment and at the beginning and completion of each of the following elements of Work:
 1. Prior to Work
 2. Final Completion

In addition, the Engineer may request up to five (5) photographs of various views (non-aerial) in any one (1) month of progress or problem areas.

- b. Photographs. Digital photographs in RAW, TIFF, or JPG format will be required. Provide 3 CDs or DVDs of the photographs.
- c. Technique. Provide factual presentation. In each photograph include an object of known size to determine size of object being photographed. Provide correct exposure and focus, high resolution and sharpness, maximum depth of field, and minimum distortion. Any photograph which is not clear and distinct, double exposed, over exposed, etc. shall be retaken.
- d. Views. Provide photographs from two (2) views at each element of Work. The Engineer will select the various viewpoints for photography.
- e. Submittals. Contractor shall deliver the photographs with each application for payment. The photographs will be dated by the Photographer.

20.5 Withholding of Payments.

20.5.1 Right to Withhold. SLVWD may refuse to approve any payment because of subsequently discovered evidence or the results of subsequent inspection or tests, nullify any such payment previously approved to such extent as may be necessary in the opinion of SLVWD to protect SLVWD from loss because: (a) the Work is defective, (b) third party claims have been filed or there is reasonable evidence indicating probable filing of such claims, (c) the Contract Price has been reduced because of Change Orders, (d) of the Contractor's failure to make payment properly to Subcontractors or for labor, materials, or equipment, (e) of damage to another contractor or to the property of others caused by the Contractor, (f) of reasonable doubt that the Work can be completed for the unpaid balance of the Contract Price, (g) of reasonable indication that the Work will not be completed within the Contract Time, (h) of the Contractor's neglect or unsatisfactory prosecution of the Work including failure to clean up, (i) SLVWD has been required to correct defective Work as provided in Paragraph 18.2 or to finish the Work as provided in Paragraph 21.2, (j) of insurance premium costs SLVWD has incurred by the Contractor's failure to maintain the insurance required of him, (k) of reasonable doubt as to the Contractor's warranty of title required under Paragraph 20.3, (l) of payments due SLVWD from the Contractor, or (m) of provisions of law that enable or require SLVWD to withhold such payments in whole or in part. When the grounds for withholding payments are removed, payment will be made for amounts withheld because of them to the extent the Contractor is entitled to payment.

20.5.2 SLVWD's Right To Apply Withheld Payments. SLVWD may, but is not obligated to the Contractor, his surety or sureties, or any third party, to apply the amounts withheld pursuant to subparagraph 20.5.1 to the payment of any and all claims which are grounds for such withholding. In so doing, SLVWD shall be deemed the agent of the Contractor and any payments so made by SLVWD shall be considered as a payment made under the Contract Agreement by SLVWD to the Contractor and SLVWD shall not be

liable to the Contractor for such payment made in good faith. Such payment by SLVWD may be made without prior judicial determination of the claim or claims. SLVWD will render to the Contractor a proper accounting of such funds disbursed on behalf of the Contractor.

- 20.6 Payments to Subcontractors. The Contractor shall pay each Subcontractor, upon receipt of payment from SLVWD, an amount equal to the percentage of completion allowed to the Contractor on account of such Subcontractor's Work, less the percentage retained from payments to the Contractor. The Contractor shall also require each Subcontractor to make similar payments to his Sub-subcontractors. If SLVWD refuses or fails to approve an application for payment for any cause which is the fault of the Contractor and not the fault of a particular Subcontractor, the Contractor shall pay that Subcontractor on demand, made at any time after SLVWD's approval for payment should otherwise have been issued, for his Work to the extent completed less the retained percentage. The Contractor shall pay each Subcontractor a just share of any insurance moneys received by the Contractor under subparagraph 6.2.7, and he shall require each Subcontractor to make similar payment to his Sub-subcontractors. Neither SLVWD nor the Engineer shall have any obligation to pay or to see to the payment of any moneys to any Subcontractor or Sub-subcontractor except as may otherwise be required by law.
- 20.7 Final Inspection and Acceptance. Upon written notice from the Contractor that the entire Work required by the Contract Documents is complete and that all submittals required of him are made, and after the Contractor has delivered the Bonds, certificates in inspection, proof of insurance, guarantees, warranties, releases, and other documents, all as required by the Contract Documents or by law, a post construction conference will be held to review the Work and resolve any unsettled matters. Present at the conference shall be SLVWD, the Engineer, the Inspector, the Contractor, and the Superintendent. Following this conference, the Engineer will make a final inspection with SLVWD and the Contractor, and SLVWD will notify the Contractor in writing of any particulars in which this inspection reveals that the Work is defective, and will also notify the Contractor in writing of any deficiencies in the submittals and other documents required of him. The Contractor promptly shall make such corrections as are necessary to remedy all defects or deficiencies. After the Contractor has completed any such corrections to the satisfaction of SLVWD, SLVWD will issue a written final acceptance of the Work and file any notice of completion required by law or otherwise.
- 20.8 Application for Final Payment. After issuance of SLVWD's final written acceptance, the Contractor may make application for final payment following the procedure for progress payments. Neither the final payment nor the remaining retained percentage shall become due unless the application for final payment is accompanied by such supporting data as SLVWD may require, together with complete and legally effective releases or waivers, satisfactory to SLVWD, of all liens arising out of the Contract Documents and the labor and services performed and the material and equipment furnished thereunder. In lieu thereof and as approved by SLVWD, the Contractor may furnish receipts or releases in full; an affidavit of the Contractor that the releases and receipts include all labor, services, material, and equipment for which a lien could be filed, and that all payrolls, material, and equipment bills, and other indebtedness connected with the Work for which SLVWD or his property might in any way be responsible, have been

paid or otherwise satisfied; and consent of Surety, if any, to final payment. If any Subcontractor, Sub-subcontractor, or supplier fails or refuses to furnish a release or receipt in full, the Contractor may furnish a Bond satisfactory to SLVWD to indemnify him against any such lien. If any such lien remains unsatisfied after all payments are made, the Contractor or his surety shall pay to SLVWD all moneys SLVWD may be compelled to pay in discharging such lien, including all costs and reasonable attorneys' fees.

- A. The Contractor must obtain an unconditional waiver and release of claims upon final payment from all suppliers and subcontractors which have filed preliminary notices with SLVWD.
- B. The Contractor must obtain in writing releases from each owner of real property from which the Contractor has obtained permission to use land. Such release shall state that the land is returned to the property owner in an acceptable condition. Similar releases must be obtained from owners of property disturbed by the Contractor from which the Contractor has not obtained permission to use or enter; except that releases are limited to restoration of land to original lines and grades, restoration of vegetation, and removal of waste material.

THE APPLICATION FOR FINAL PAYMENT SHALL INCLUDE FROM THE CONTRACTOR A SIGNED RELEASE AND CERTIFICATE OF FINAL PAYMENT FORM AS INCLUDED HEREIN. (See Release and Certificate of Final Payment, Section 00686.)

- 20.9 Approval of Final Payment. SLVWD will, within ten (10) work days after the Contractor has fulfilled and satisfied all the requirements of Paragraph 20.8, indicate in writing his approval of payment or will return the application to the Contractor, indicating in writing his reasons for refusing to approve final payment, in which case the Contractor shall make the necessary corrections and resubmit the application. SLVWD, within the time period stated in the Supplementary Conditions, Section 00800, will pay the Contractor the amount so approved unless a longer period of time is prescribed by law or required for the lawful filing and publishing of Notices of Completion and the expiration of any lien periods thereof. (See Supplementary Conditions, Section 00800)
- 20.10 Continuing Obligation of the Contractor. The Contractor's obligation to perform and complete the Work in accordance with the Contract Documents is and shall be absolute. Neither the observation during construction and final inspection of the Work by SLVWD and the Engineer, nor any payment by SLVWD to the Contractor under the Contract Documents, nor any use or occupancy of the Work or any part thereof by SLVWD, nor any act of acceptance by SLVWD, nor any failure to do so, nor any correction of defective Work by SLVWD shall constitute acceptance of Work not in accordance with the Contract Documents.
- 20.11 Release of Claims. Contractor shall, before being entitled to final payment, also execute and file with SLVWD a release upon the form provided by SLVWD, releasing SLVWD from all claims or liability relating to undisputed contract amounts or work performed in relation to such amounts. However, any payment, final or otherwise, shall not release the Contractor or his sureties from any obligations under the Contract Documents or the performance bond or payment bond. The making of final payment by SLVWD shall not constitute a waiver of claims by SLVWD for unsettled liens,

from faulty or defective Work appearing after final acceptance of the Work by SLVWD, from failure of the Work to comply with the requirement of the Contract Documents, or from the terms of any special guarantees or warranties required by the Contract Documents.

- 20.12 Contractor's Payment to SLVWD. The Contractor shall pay to SLVWD all moneys so required of him under the provisions of the Contract Documents. If any such payments are required prior to final payment, an appropriate Change Order will be issued and, as provided in subparagraph 20.5.1, the amount of such payments may be withheld from payments due the Contractor. If the payments then or then after due the Contractor are insufficient to cover any payments due SLVWD from the Contractor, or if the amount of such payment due SLVWD is determined after the making of final payment, the difference in the amounts of the payments or the amount so determined shall be paid by the Contractor to SLVWD. The obligation of the Contractor to pay the moneys due SLVWD from him shall specifically bind the Contractor's sureties, assigns, executors, administrators, and heirs to his obligation to so pay SLVWD.
- 20.13 Interest. Any moneys not paid when due to either party under this Contract Agreement shall bear interest at the maximum legal rate in force at the place of the Project.
- 20.14 Nonreceipt of Payment. The Contractor shall notify SLVWD in writing of any approved progress payment not received by him within five (5) work days after the date the payment should properly have been paid to him. In the absence of such written notice in each case, the Contractor hereby agrees and waives his right under Paragraph 21.5 to terminate the Contract Agreement or stop the Work on account of nonpayment by SLVWD and further waives his right under Paragraph 20.13 to interest on the amount of any such payment not received by him.
- 20.15 False Claim Act. The Contractor certifies that he will not make any false claims pursuant to Government Code Section 12650 *et seq.*
- 20.16 Compliance with Law. Notwithstanding anything to the contrary in the foregoing provisions, this Article 20 shall be interpreted in accordance with Public Contract Code Section 7107.

ARTICLE 21 – SUSPENSION AND TERMINATION

- 21.1 Suspension of Work. SLVWD, at any time and without cause, may suspend the Work or any part thereof by notice in writing to the Contractor. Unless otherwise provided in the Contract Documents, the Contractor shall have no claim for damages or compensation on account of such suspension unless he makes a claim therefore as provided in Paragraph 16.4, but the Contractor will be allowed an extension of the Contract Time to complete the Work and an appropriate Change Order will be issued. The Contractor shall resume the Work when so notified in writing by SLVWD.
- 21.2 Suspension of Contract Agreement. If the Contractor abandons the Work, or if he is adjudged a bankrupt or insolvent, or if he makes a general assignment for the benefit of his creditors, or if a trustee or receiver is appointed for the Contractor or for any of his property, or if he files a petition to take advantage of any debtor's act or to reorganize under bankruptcy or similar laws, or if he persistently fails to supply sufficient skilled

superintendence and workmen or suitable materials or equipment, or if he persistently fails to make prompt payments to Subcontractors or for labor, materials or equipment, or if he disregards laws, ordinances, rules, regulations, or orders of any public body having jurisdiction, or if he disregards the authority of SLVWD, or neglects to prosecute the Work in accordance with the Contract Documents including requirements of the progress schedule, or if he fails to promptly comply with the requirements of any Change Order, or if he assigns this Contract Agreement otherwise than herein provided, or if SLVWD at any time is of the opinion that the performance of the Work is unnecessarily or unreasonably delayed or that the Contractor is willfully violating any of the provisions of the Contract Documents or is executing the same in bad faith, or if the Work is not fully completed within the Contract Time and any authorized extensions thereof, or if SLVWD is of the opinion that the Work cannot be completed for the unpaid balance of the Contract Price or will not be completed within the Contract Time, or if the Contractor otherwise violates any provisions of the Contract Documents, then SLVWD may, without prejudice to any other right or remedy and by means of written notice to the Contractor and his surety, instruct the Contractor to discontinue all Work or any part thereof under the Contract Agreement or terminate the services of the Contractor. The Contractor, under a written instruction to discontinue, shall not resume any of the Work except by written notice from SLVWD. In either such case, SLVWD may take possession of the Work and Project and of all materials, equipment, plant, tools, supplies, construction machinery and equipment, and property of every kind thereon owned and furnished by the Contractor for the purpose of the Work, and finish the Work by whatever method SLVWD may deem expedient. The Contractor shall not be entitled to receive any further payment after the date of said written notice from SLVWD unless instructed in writing by SLVWD to resume any part of the Work, or until the Work is finished by SLVWD if SLVWD so elects. If the unpaid balance of the Contract Price exceeds the direct and indirect costs to SLVWD of finishing the Work, including compensation for additional administrative, consultant, professional, testing, and inspection services, such excess will be paid to the Contractor. If such costs to SLVWD exceed such unpaid balance, the Contractor, in accordance with Paragraph 20.12, shall pay the difference to SLVWD.

- 21.3 Contractor's Continuing Liability. When the Contractor's services have been discontinued or terminated as provided in Paragraph 21.2, said discontinuance or termination shall not affect any rights of SLVWD against the Contractor then existing or which may then after accrue. Any retention or payment of moneys by SLVWD due the Contractor will not release the Contractor from liability.
- 21.4 Termination of Contract Agreement. Upon seven (7) calendar days written notice to the Contractor, SLVWD may, without cause and without prejudice to any other right or remedy, elect to abandon the Work and terminate the Contract Agreement. In such case, the total compensation to be paid to the Contractor shall be determined on the basis of the components stated in Section 8-1.14(E) of the California Department of Transportation's Standard Specifications dated 2010, a copy of which is provided in Section 00700A.
- 21.5 Stopping Work or Termination by Contractor. If, through no fault, act, or omission of the Contractor, Subcontractor, Sub-subcontractor, or their agents or employees, or any other person performing any of the Work under a contract with the Contractor, the Work is suspended for a period of more than ninety (90) calendar days by SLVWD (except as provided in Paragraph

23.6 for Federal hindrance), or under an order of any court or other public authority having jurisdiction, or SLVWD fails to act on any application for progress payment within thirty (30) calendar days after it is submitted, or SLVWD fails to pay the Contractor any progress payment sum approved by SLVWD within forty-five (45) calendar days of its approval, or SLVWD fails to pay the Contractor any sum awarded by arbitrators within sixty (60) calendar days of its approval and presentation, then the Contractor may, upon fourteen (14) calendar days written notice to SLVWD, terminate the Contract Agreement and recover from SLVWD payment for all Work satisfactorily executed and for any proven loss sustained upon any materials, equipment, tools, and construction equipment and machinery, including reasonable profit and damages. In addition and in lieu of terminating the Contract Agreement, if SLVWD has failed to act on an application for progress payment or has failed to make any progress payment as aforesaid, the Contractor may, upon fourteen (14) calendar days written notice to SLVWD, stop the Work until he has been paid all amounts then correctly due him, in which event and upon resumption of the Work, an appropriate Change Order will be issued for adjusting the Contract Price or extending the Contract Time, or both, to compensate for the costs and delays attributable to such storage of the Work.

- 21.6 Continuing Liability of Sureties. Termination of the contract shall not relieve the surety or sureties from obligations for any just claims arising out of the Work performed.

ARTICLE 22 – ARBITRATION

- 22.1 Resolution of Certain Disputes. See California State Requirements, Section 00800CA, Paragraph O.
- 22.2 Payment of Undisputed Amounts. SLVWD shall be entitled to withhold any disputed unpaid contract amount, which would otherwise be due and payable after the filing of any claim by the Contractor pursuant to Article 22 of the General Conditions, pending final resolution of the claim.
- 22.3 Waiver of Rights. Except as set forth in this Article 22, or as otherwise provided under state law, it is understood and agreed by the parties that all rights any of them may have to arbitration for settling of disputes, claims, and other matters arising out of or relating to this Contract Agreement, or the breach thereof, are hereby specifically waived by all of them.

ARTICLE 23 – MISCELLANEOUS PROVISIONS

- 23.1 Successors and Assigns. SLVWD and the Contractor each binds themselves, their partners, successors, assigns, and legal representatives to the other party hereto and to the partners, successors, assigns, and legal representatives of such other party in respect to all covenants, agreements, and obligations contained in the Contract Documents. Neither party to the Contract Agreement shall assign the Contract Agreement or sublet it as a whole without the written consent of the other, nor shall the Contractor assign any moneys due or to become due to them hereunder without the previous written consent of SLVWD.
- 23.2 Written Notice. Written notice shall be deemed to have been duly served if delivered in person to the individual or member of the firm or to an officer of the corporation for whom it was intended on the date of delivery, or if

delivered at or sent by registered or certified mail to the last business address known to him who gives the notice on the third business day after it is deposited in the mail, or if delivered to the Project Superintendent on the date of delivery. The address given in the Contractor's Bid on which the Contract Agreement is founded is hereby designated as the place to which all notices, letters, and other communications to the Contractor shall be mailed or delivered, except that said address may be changed by the Contractor by notifying SLVWD in writing. This shall not preclude the service of any notice, letter, or other communication upon the Contractor personally.

- 23.3 Communications. SLVWD will issue all communications to the Contractor and the Contractor shall deliver all communications to SLVWD unless otherwise provided in the Contract Documents or directed by SLVWD.
- 23.4 Rights and Remedies. The duties and obligations imposed by the Contract Documents and the rights and remedies available thereunder and, in particular but without limitation, the warranties, guarantees, and obligations imposed upon the Contractor by subparagraph 6.2.4 and by Paragraphs 6.4, 19.1, and 20.3 and the rights and remedies available to SLVWD and the Engineer thereunder, shall be in addition to and not a limitation of any otherwise imposed or available by law, by special guarantee or warranty, or by other provisions of the Contract Documents.
- 23.5 Royalties and Patents. Unless otherwise specifically stipulated elsewhere in the Contract Documents, the Contractor shall pay and, in particular but without limitation, the warranties, guarantees and obligations imposed upon the Contractor by subparagraph 6.2.4 and by Paragraphs 6.4, 19.1, and 20.3 and the rights and remedies available to SLVWD and the Engineer thereunder, shall be in addition to and not a limitation of any otherwise imposed or available by law, by special guarantee or warranty, or by other provisions of the Contract Documents.
- 23.6 Federal Hindrance. In entering into this Contract Agreement, it is clearly understood by all parties hereto that conditions may subsequently arise resulting from, connected with, or growing out of any war in which the United States may be engaged, or any national emergency or condition created directly or indirectly by or for the national defense or national interests, and which are entirely beyond the control of either party, that may hinder, delay, or render impossible the performance of this Contract Agreement in accordance with its terms and conditions. It is therefore mutually understood and agreed, anything herein contained to the contrary notwithstanding, that in the event the Contractor shall be prevented from performing the Work or any part thereof by reasons of the conditions above stated, the Contractor shall notify SLVWD in writing of his inability to perform, stating in full the reason therefore and the probable duration of such inability. If required, he shall also submit proof or evidence in support of his claim of inability to perform. If it shall appear to the satisfaction of SLVWD that the cause of inability to perform arose after the Contract Agreement was entered into and is beyond the control of the Contractor, SLVWD may, (a) if lawfully within its power, remove the cause which prevents performance; or (b) suspend this Contract Agreement until the cause of inability to perform is removed; or (c) with the consent of the Contractor, renegotiate or amend this Contract Agreement by extending the time of performance or by making the changes in the character of the Work, or in the materials or equipment required in order to enable performance of

the Work; or (d) waive performance of that part of the Work which is impossible, or supply substitute materials for those unavailable, and where this remedy is resorted to, the payment due the Contractor will be reduced to the extent of the Work not required to be performed, based so far as is practicable upon unit prices bid, by an appropriate Change Order. If none of the foregoing procedures are adopted by SLVWD within thirty (30) calendar days after SLVWD is satisfied and so finds that the Contractor is unable to perform for the reasons above stated, then either party hereto may, without incurring any liability, elect to declare this Contract Agreement terminated upon the ground of impossibility of performance. Upon such termination, the Contractor will be paid as provided in Paragraph 21.4 for termination of the Contract Agreement.

- 23.7 Oral Agreements. No oral order, objection, claim, or notice by any party to the others shall affect or modify any of the terms or obligations contained in any of the Contract Documents, and none of the provisions of the Contract Documents shall be held to be waived or modified by reason of any act whatsoever, other than by a definitely agreed waiver or modification thereof in writing, and no evidence shall be introduced in any proceeding of any other waiver or modification.
- 23.8 Work in Jurisdiction of Others. Where any of the Work is adjacent to or crosses highways, railroads, streets, utilities, property, right-of-ways, or easements under the jurisdiction of Federal, State, County, City, or other public agency, public utility, or private entity from whom SLVWD has not obtained permits, the Contractor shall secure written permission from the proper authority and furnish bonds and insurance and pay all fees and charges as the proper authority may require for permission before executing such Work. A copy of each written permission shall be filed with SLVWD before such Work is begun. The Contractor shall repair or replace all existing construction damaged in the execution of the Work to the satisfaction of the proper authority, and shall furnish to SLVWD a release from the proper authority prior to final inspection of the Work.
- 23.9 Cash Allowances. When included in the Contract Documents, the Contractor shall include in his Bid and the Contract Price the cash allowances stated in the Contract Documents.
- 23.9.1 Cash Allowances for Permits. These stated allowances represent the estimated permit fee(s) payable to government agencies as required to perform the Work. The Contractor's costs for labor, overhead, profit, and other expenses required to obtain the cash allowance permits shall be included in the Contract Price since they are not included in the cash allowance estimates.
- 23.9.2 Cash Allowances for Materials and Equipment. These stated allowances represent the net cost estimate of the materials and equipment delivered and unloaded at the site, and all applicable taxes. The Contractor's handling costs on the site, labor, installation costs, overhead, profit, and other expenses contemplated for the cash allowance material and equipment shall be included in the Contract Price since they are not included in the cash allowance estimates. The Contractor shall purchase the cash allowance materials and equipment as directed by SLVWD on the basis of the lowest responsive bid of at least three competitive bids. If the actual cost of the materials and equipment approved by SLVWD delivered and unloaded at

the site, and all applicable taxes, is more or less than the cash allowance estimates, the Contract Price will be adjusted accordingly by Change Order.

- 23.10 Ownership of Documents and Models. All Drawings, Specifications, and copies thereof furnished to or obtained by the Contractor, and all models pertaining to the Work are and shall remain the property of SLVWD or the Engineer as they may agree. They shall not be used by the Contractor on any other project and, with the exception of one (1) contract set of Drawings and Specifications to be retained by the Contractor, shall be returned, on request and as directed, prior to final acceptance of the Work.
- 23.11 Use of Completed Portions. SLVWD shall have the right, upon written notice to the Contractor, to take possession or occupancy of and use any completed or partially completed portions of the Work, notwithstanding that the time for completing the entire Work or such portions may not have expired; but such taking possession or occupy and use shall not be deemed a waiver of any requirement of the Contract Documents or a waiver or acceptance of any Work not completed in accordance with the Contract Documents. If such prior possession, occupy, or use increases the cost of or delays the completion of uncompleted Work, or causes repair or refinishing of completed Work, the Contractor shall be entitled to such extra compensation or extension of time, or both, as agreed by SLVWD and an appropriate Change Order will be issued. The Contractor will not be required to perform housekeeping obligations in or bear utility costs for buildings or structures to the extent so occupied or used by SLVWD. If SLVWD takes possession of and places any of the machinery or equipment of the Work into continuing operation consonant with its intended final service or purpose and for his beneficial use, the period of the Contractor's guarantee, solely with respect to such machinery or equipment, shall begin on the first day of such beneficial use by SLVWD and SLVWD will bear the utility and maintenance costs for such beneficial use. Prior to SLVWD taking possession, occupancy, or use of any portion of the Work, but not as a condition or precedent to SLVWD's right thereto, SLVWD and the Contractor shall jointly inspect and determine the condition and completeness of the involved portions of the Work, shall agree upon appropriate procedures and other pertinent matters including the payment or apportioning of utility costs, and shall execute a memorandum recording the inspection determination and the procedures and matters agreed. Such possession, occupancy, or use by SLVWD under this paragraph shall not entitle the Contractor to claim or receive payment of any amounts retained or withheld by SLVWD pursuant to subparagraphs 20.4.2 and 20.5.1 unless otherwise agreed by the parties.
- 23.12 Cleaning Up. The Contractor shall at all times during the Work keep the site and premises, adjoining property, and public property free from accumulations of waste materials, rubbish, and other debris resulting from the Work, and at the completion of the Work shall remove all waste materials, rubbish, and debris from and about the site and premises as well as all tools, construction equipment and machinery, and surplus materials, and shall leave the site and premises clean and ready for occupancy by SLVWD. The Contractor shall restore to their original condition those portions of the site not designated for alteration by the Contract Documents. Paved walkways, parking areas, and roadways shall be swept and broomed clean. Cleaning up operations shall include the removal and disposal of earth that is contaminated and the filling of resulting excavations with sound compacted earth as directed and approved by SLVWD. Contamination

includes the earth in areas used for disposal of waste concrete, mortar, plaster, masonry, and like materials'; areas in which washing out concrete and plaster mixers or washing of tools and like cleaning operations have been performed; areas that have been oiled, paved, or chemically treated; and areas where waste oils, solvents, paints, solutions, or similar materials of a penetrating nature have been incorporated into the soil. SLVWD will determine the contaminated earth areas. No waste material shall be buried or disposed of on SLVWD's property unless so permitted in the Contract Documents or approved in writing by SLVWD. Before the Contractor applies for final inspection and acceptance of the Work, all items of Work shall be complete, ready to operate, and in a clean condition as determined by SLVWD.

- 23.13 SLVWD's Right to Clean Up. If the Contractor fails to satisfactorily clean up or if a dispute arises between the Contractor and any separate contractor as to their responsibility for cleaning up, SLVWD may clean up and charge the cost thereof to the Contractor for his failure, or to the several Contractors as SLVWD shall determine to be just.
- 23.14 Certificates. Each certificate, required under the Contract Documents shall be signed by the individual, office, or agent lawfully authorized to execute the certificate, and such authority shall be cited in the certificate by title, description, or other acceptable evidence. All certificates shall be sworn and notarized as to the correctness and validity of the contents, and duplicate copies shall be notarized to be true copies.
- 23.15 Excavations; Discovery of Hazardous Conditions.
See California State Requirements, Section 00800CA, Paragraph P.
- 23.16 California State Codes. The Contractor shall comply with all requirements of Section 00800CA which outlines particular State of California laws.
- 23.16.1 Wage Rates. See California State Requirements, Section 00800CA, Paragraph A.
- a. Working Hours. See California State Requirements, Section 00800CA, Paragraph D.
 - b. Apprentices. See California State Requirements, Section 00800CA, Paragraph C.
 - c. Payroll Records. See California State Requirements, Section 00800CA, Paragraph K.
 - d. Ineligible Subcontractors. See California State Requirements, Section 00800CA, Subparagraph A.3.
 - e. Penalties. See California State Requirements, Section 00800CA, Paragraph A.2.
- 23.16.2 Safety Orders. The California Construction Safety Orders in effect during the Work shall apply continuously until final acceptance of the Work.
- 23.16.3 Subcontractors. See California State Requirements, Section 00800CA, Paragraph R.

- 23.17 Substitution of Securities for Monies Withheld to Ensure Performance of Contractor. See California State Requirements, Section 00800CA, Paragraph I.
- 23.18 No Discrimination. Contractor shall not discriminate in the employment of persons upon the Contract Work because of their race, religious creed, color, national origin, ancestry, physical handicap, medical condition, marital status, sexual orientation, gender, or sex of such persons. Contractor shall cause an identical clause to be included in every subcontract for Contract Work.
- 23.20 Copyrights and Patents. The Contractor shall and does hereby hold and save SLVWD harmless from liability of any nature and kind, including costs and expenses, for or on account of any copyrighted or uncopyrighted composition, secret process, patented or unpatented invention, article or appliance, manufactured, furnished or used by him in the performance of this Contract, including their use by SLVWD unless otherwise specifically stipulated in this Contract.
- 23.21 Anti-Trust Claims. In entering into this Contract or a subcontract to supply goods, services, or material pursuant to this Contract, the Contractor or Subcontractor offers and agrees to assign to SLVWD all rights, title, and interest in and to and to all causes of action it may have under Section 4 of the Clayton Act (15 U.S.C. Section 15) or under the Cartwright Act (Chapter 2 (commencing with Section 16700) of Part 2 of Division 7 of the Business and Professions Code), arising from the purchase of goods, services, or materials pursuant to the Contract or the subcontract. This assignment shall be made and become effective at the time SLVWD tenders final payment to the Contractor, without further acknowledgment by the parties.
- 23.22 Attorneys' Fees. In the event any legal action is commenced to enforce or interpret the terms and conditions of this Agreement, the prevailing party shall, in addition to any other costs and relief, be entitled to reasonable attorneys' fees.
- 23.23 Notice of Third Party Claims. SLVWD will timely notify Contractor in the event that a claim is filed by a third party which is related to the Contract. SLVWD will notify Contractor of such claim within ten (10) business days from the date on which SLVWD is made aware of the claims. SLVWD may recover reasonable costs incurred in providing such notification.

END OF SECTION 00700

SECTION 00700A

REFERENCED PROVISIONS OF SECTION 8-1.14 OF CALTRANS' STANDARD
SPECIFICATIONS ISSUED 2010
(as referenced in General Conditions Section 21.4)

8-1.14 CONTRACT TERMINATION

8-1.14E Payment Adjustment for Termination

If the Department issues a termination notice, the Engineer determines payment for termination based on the following:

1. Direct cost for the work:
 - 1.1. Including:
 - 1.1.1. Mobilization.
 - 1.1.2. Demobilization.
 - 1.1.3. Securing the job site for termination.
 - 1.1.4. Losses from the sale of materials.
 - 1.2. Not including:
 - 1.2.1. Cost of materials you keep.
 - 1.2.2. Profit realized from the sale of materials.
 - 1.2.3. Cost of material damaged by:
 - 1.2.3.1. Act of God.
 - 1.2.3.2. Act of a public enemy.
 - 1.2.3.3. Fire.
 - 1.2.3.4. Flood.
 - 1.2.3.5. Governor-declared state of emergency.
 - 1.2.3.6. Landslide.
 - 1.2.3.7. Tsunami.
 - 1.2.4. Other credits.
2. Cost of remedial work, as estimated by the Engineer, is not reimbursed.
3. Allowance for profit not to exceed 4 percent of the cost of the work. Prove a likelihood of having made a profit had the Contract not been terminated.
4. Material handling costs for material returned to the vendor or disposed of as ordered.
5. Costs in determining the payment adjustment due to the termination, excluding attorney fees and litigation costs.

Termination of the Contract does not relieve the surety of its obligation for any just claims arising out of the work performed.

END OF SECTION 00700A

SECTION 00800

SUPPLEMENTARY CONDITIONS

MODIFICATION OF THE GENERAL CONDITIONS

- A. General. These Supplementary Conditions form a part of and modify the preceding General Conditions. Provisions and requirements of the General Conditions not so modified shall remain in full force and effect.
- B. Modifications. The Articles, paragraphs, and subparagraphs mentioned are those of the General Conditions (Section 00700).
1. Paragraph 1.17 – Engineer. Under these Contract Documents, SLVWD will act as the Engineer.
 2. Paragraph 4.2 – Time of Performance. Add the following:
 - 4.2.1 District non-working holidays:
 - Day before New Year's Day (December 31)
 - New Year's Day (January 1)
 - Martin Luther King's Birthday (third Monday in January)
 - Presidents Day (third Monday in February)
 - Memorial Day (last Monday in May)
 - Independence Day (July 4)
 - Labor Day (first Monday in September)
 - Veterans Day (November 11)
 - Thanksgiving Day (fourth Thursday in November)
 - Friday after Thanksgiving
 - Day before Christmas (December 24)
 - Christmas Day (December 25)
 - 4.2.2 Inclement weather days for Ben Lomond, CA, defined as rainfall at the site greater than one-tenth inch during a twenty-four-hour period and which prevents or impedes proper construction at the site, occur on average:

JAN – 7	FEB – 7	MAR – 9	APR – 5	MAY – 2	JUN – 1
JUL – 0	AUG – 0	SEP – 1	OCT – 2	NOV – 7	DEC – 8

3. Paragraph 5.3 – Environmental Conditions. The following documents pertain to environmental conditions:

a. None.

4. Paragraph 6.2 – Insurance. The additional insureds and insurance coverage limits required by Paragraph 6.2 of the General Conditions shall be as follows. Where greater amounts are required by Laws and Regulations, provide the greater amount.

a. Additional Insureds: In addition to Owner, include the following additional insureds as required under Paragraph 6.2.2 of the General Conditions:

1. Owner's Construction Manager (to be determined prior to award)

b. Workers' Compensation, and related coverages under Paragraph 6.2.5 of the General Conditions:

State: Statutory

Federal, if applicable (e.g., Longshoreman's): Statutory

Employer's Liability:

Bodily injury, each accident \$ 1,000,000.00

Bodily injury by disease, each employee \$ 1,000,000.00

Bodily injury/disease aggregate \$ 1,000,000.00

Foreign voluntary worker compensation Statutory

c. Contractor's Commercial General Liability under Paragraphs 6.2.6 of the General Conditions:

General Aggregate \$ 1,000,000.00

Products - Completed Operations Aggregate \$ 1,000,000.00

Personal and Advertising Injury \$ 1,000,000.00

Each Occurrence (Bodily Injury and Property Damage) \$ 1,000,000.00

d. Automobile Liability under Paragraph 6.2.6 of the General Conditions:

Bodily Injury:

Each person \$ 1,000,000.00

Each accident \$ 1,000,000.00

Property Damage:

Each accident \$ 1,000,000.00

e. Contractor's Professional Liability:

Each Claim \$ 1,000,000.00

Annual Aggregate \$ 1,000,000.00

f. Contractor's Pollution Liability under Paragraph 6.2.6 of the General Conditions:

Each Occurrence \$ _____

General Aggregate \$ _____

☒ If box is checked, Contractor is not required to provide
Contractor's Pollution Liability insurance under this Contract

g. Deductible limit for Builders' Risk "All-Risk" Completed Value Insurance under Paragraph 6.2.7 of the General Conditions: Not more than \$5,000.

5. Paragraph 8.10.1 - Water Supply. Add the following: Contractor is responsible for securing and paying District for construction water supply.
6. Paragraph 14.1 – Separate Contracts. The following Work by other Contractors may occur at the site(s) of the Work: None is scheduled.
7. Paragraph 20.9 – Approval of Final Payment. Add the following: The application will be returned if the items in Paragraph 20.8 are not submitted with the final application for payment. The Contractor may make application for final payment upon obtaining unconditional releases of claims from each sub-contractor or supplier for each preliminary notice submitted to SLVWD. After the work is complete and SLVWD receives unconditional releases from all subcontractors and suppliers, SLVWD will file a Notice of Completion with the County Recorder. After thirty-five (35) calendar days have elapsed following recording of such notice, final payment will be made to the Contractor.

END OF SECTION 00800

SECTION 00800CA

CALIFORNIA STATE REQUIREMENTS

CALIFORNIA STATE REQUIREMENTS

A. State Wage Determinations:

1. As required by Sections 1770 *et seq.* of the California Labor Code, the Contractor shall pay not less than the prevailing rate of per diem wages as determined by the Director of the California Department of Industrial Relations ("DIR"). SLVWD has obtained from the Director of the DIR the general prevailing rate of per diem wages and the general prevailing rate for holiday and overtime work in the locality in which the Public Work is to be performed for each craft, classification or type of workman needed to execute this Contract. Copies of the wage determination are on file and may be obtained by interested parties at the office of SLVWD or may be obtained from the State of California, Division of Labor Statistics and Research at (415) 557-0561. The Contractor shall post a copy of such determination at each job site.
2. The Contractor and all Subcontractors shall comply with all applicable requirements and provisions of the Labor Code, including Sections 1775 and 1776. The Contractor shall forfeit, as a penalty to SLVWD, two-hundred dollars (\$200.00), for each calendar day, or portion thereof, for each workman paid less than stipulated prevailing rates for Work done under the Contract Agreement by him, or any Subcontractor under him, in violation of the provisions of the California Labor Code. Copies of these wage determinations shall be posted and maintained at the job site by the successful bidding Contractor.
3. The Contractor shall not perform the Work with a subcontractor who is ineligible to perform work on a public works project in accordance with the requirements of Sections 1777.1 and 1777.7 of the California Labor Code.

B. Workers' Compensation:

1. In accordance with the provisions of Section 3700 of the California Labor Code, the Contractor shall secure the payment of compensation to his employees.
2. Prior to beginning work under the Contract, the Contractor shall sign and file with SLVWD the following certification:

"I am aware of the provisions of Section 3700 of the Labor Code which require every employer to be insured against liability for workers' compensation or to undertake self-insurance in accordance with the provisions of that code, and I will comply with such provisions before commencing the performance of the Work of this Contract."
3. Notwithstanding the foregoing provisions, before the Contract is executed on behalf of SLVWD, a bidder to whom a Contract has been awarded shall furnish satisfactory

evidence that it has secured in the manner required and provided by law the payment of workers' compensation.

C. Apprentices on Public Works Contracts:

1. The Contractor shall confirm to all the requirements of Sections 1777.5 and 1777.6 of the California Labor Code concerning the employment of apprentices by the Contractor or any Subcontractor under him. The Contractor shall provide SLVWD with a copy of the contract award information at the time that information is submitted to the applicable apprenticeship program. Within sixty (60) days after concluding the work pursuant to this Contract, the Contractor shall submit, and require each Subcontractor under him to submit, to SLVWD and the apprenticeship program a verified statement of the journeyman and apprentice hours performed on the Contract.
2. Section 1777.5 requires that every apprentice employed upon public works shall be paid the prevailing rate of per diem wages for apprentices in the trade to which he or she is registered and shall be employed only at the work of the craft or trade to which he or she is registered.
3. Only apprentices, as defined in section 3077 of the Labor Code, who are in training under the apprenticeship standards that have been approved by the Chief of the Division of Apprenticeship Standards and who are parties to written apprentice agreements under Chapter 4 (commencing with Section 3070) of Division 3 are eligible to be employed at the apprentice wage rate on public works. The employment and training of each apprentice shall be in accordance with either of the following:
 - a. The apprenticeship standards and apprentice agreements under which he or she is training.
 - b. The rules and regulations of the California Apprenticeship Council.
4. When the Contractor, or any subcontractor under him, employs workers in any apprenticeable craft or trade to perform Work, the Contractor and subcontractor shall employ apprentices in at least the ratio set forth in Labor Code section 1777.5 and may apply to any apprenticeship program in the craft or trade that can provide apprentices to the site of the public work for a certificate approving the Contractor under the apprenticeship standards for the employment and training of apprentices in the area or industry affected.
5. Prior to commencing Work on the Contract, the Contractor and/or subcontractor shall submit contract award information to an applicable apprenticeship program that can supply apprentices to the site of the Work. The information submitted shall include an estimate of the journeyman hours to be performed under the Contract, the number of apprentices proposed to be employed, and the approximate dates the apprentices would be employed. A copy of this information shall also be submitted to the Owner.

6. Within 60 days after concluding Work on the Contract, the Contractor and any subcontractors shall submit to the Owner, and to the apprenticeship program a verified statement of the journeyman and apprentice hours performed on the Contract. The information submitted pursuant to this section GC 7-2 shall be public.
 7. If the Contractor, in performing any of the Work under the Contract, employs journeymen or apprentices in any apprenticeable craft or trade, then the Contractor shall contribute to the California Apprenticeship Council the same amount that the director determines is the prevailing amount of apprenticeship training contributions in the area of the site of the Work. The Contractor may take as a credit for payments to the council any amounts paid by Contractor to an approved apprenticeship program that can supply apprentices to the Site of the Work. The Contractor may add the amount of the contributions in computing his or her Bid for the Contract.
 8. Contractor and any subcontractor under him shall comply with the requirements of Sections 1777.5 and 1777.6 in the employment of apprentices. The Contractor has the responsibility of compliance with these requirements for all apprenticeable occupations.
 9. Information relative to apprenticeship standards, wage schedules, and other requirements may be obtained from the Director of Industrial Relations, ex officio the Administrator of Apprenticeship, San Francisco, California, or from the Division of Apprenticeship Standards and its branch offices.
- D. Working Hours:** The Contractor shall comply with all applicable provisions of Section 1810 to 1815, inclusive, of the California Labor Code relating to working hours. The time of service of any laborer, workman, or mechanic employed on the Work shall be limited and restricted to eight (8) hours during any one (1) calendar day and forty (40) hours in any one (1) calendar week, except as otherwise provided in said sections. The Contractor shall forfeit to SLVWD as a penalty, twenty-five dollars (\$25.00) for each laborer, worker, or mechanic employed in the execution of the Work by him or any Subcontractor under him for each calendar day during which such laborer, worker, or mechanic is required or permitted to labor more than eight (8) hours in any one calendar day and forty (40) hours in any one calendar week in violation of provisions of the California Labor Code, unless such worker receives compensation for all hours worked in excess of eight (8) hours per day, at not less than 1-1/2 times the basic rate of pay.
- E. Contractor Not Responsible For Damage Resulting From Certain Acts of God:** As provided in Section 7105 of the California Public Contract Code, the Contractor shall not be responsible for the cost of repairing or restoring damage to the Work which damage is determined to have been proximately caused by an Act of God, in excess to five percent (5%) to the contracted amount, provided, that the Work damaged was built in accordance with accepted and applicable building standards and the plans and specifications of SLVWD. The Contractor shall obtain insurance to indemnify SLVWD for any damage to the Work caused by an Act of God if the insurance premium is a separate bid item in the bidding schedule for the Work. For purposes of this Section, the term "Acts of God" shall include only the following occurrences or conditions and effects: earthquakes in excess of a magnitude of 3.5 on the Richter Scale and tidal waves.

- F. Notice of Completion:** In accordance with the Sections 8182 of the California Civil Code, within fifteen (15) days after date of acceptance of the Work and after Owner receives an unconditional waiver and release form from all subcontractors and suppliers, SLVWD will file, in the County Recorder's office, a Notice of Completion of the Work.
- G. Unpaid Claims:** If at any time prior to the expiration of the period of service of a stop notice, there is served upon SLVWD a stop notice as provided in Section 3179 and 3210 of the California Civil Code, SLVWD shall, until the discharge thereof, withhold from the monies under its control so much of said monies due or to become due to the Contractor under this Contract as shall be sufficient to answer the claim stated until such stop notice and to provide for the reasonable cost of any litigation thereunder provided that if SLVWD shall, in its discretion, permit Contractor to file with SLVWD the bond referred to in Section 3196 of the Civil Code of the State of California, said monies shall not thereafter be withheld on account of such stop notice.
- H. Concrete Forms, Falsework, and Shoring:** This Contractor shall comply fully with the requirements of Section 1717 of the Construction Safety Orders, State of California, Department of Industrial Relations, regarding the design of concrete forms, falsework and shoring, and the inspection of same prior to placement of concrete. Where the said Section 1717 requires the services of a civil engineer registered in the State of California to approve design calculations and working drawings of the falsework or shoring system, or to inspect such system prior to placement of concrete, the Contractor shall employ a registered civil engineer for these purposes, and all costs therefore shall be included in the price named in the Contract for completion of the Work as set forth in the Contract Documents.
- I. Retainage from Monthly Payments:** Pursuant to Section 22300 of the California Public Contract Code, the Contractor may substitute securities for any money withheld by SLVWD to insure performance under the Contract. At the request and expense of the Contractor, securities equivalent to the amount withheld shall be deposited with SLVWD or with a state or federally chartered bank in California as the escrow agent, who shall return such securities to the Contractor upon satisfactory completion of the Contract. Alternatively, the Contractor may request and SLVWD shall make payment of retentions earned directly to the escrow agent at the expense of the Contractor. At the expense of the Contractor, the Contractor may direct the investment of the payments into securities and the Contractor shall receive the interest earned on the investments upon the same terms provided for in Section 22300 for securities deposited by the Contractor. Upon satisfactory completion of the Contract, the Contractor shall receive from the escrow agent all securities, interest, and payments received by the escrow agent from SLVWD, pursuant to the terms of Section 22300. Securities eligible for investment under Section 22300 shall include those listed in Section 16430 of the Government Code, bank or savings and loan certificates of deposit, interest-bearing demand deposit accounts, standby letters of credit, or any other security mutually agreed to the Contractor and SLVWD. The Contractor shall be the beneficial owner of any securities substituted for moneys withheld and shall receive any interest thereon. If the Contractor elects to receive interest on moneys withheld in retention by SLVWD, the Contractor shall, at the request of any Subcontractor performing more than five percent (5%) of the Contractor's total bid, make that option available to the Subcontractor regarding any moneys withheld in retention by the Contractor from the Subcontractor. If the Contractor elects to receive interest on any moneys withheld in retention by SLVWD, then a Subcontractor performing more than five percent (5%) of the

Contractor's total bid shall receive the identical rate of interest received by the Contractor on any retention moneys withheld from the Subcontractor by the Contractor, less any actual pro rata costs associated with administering and calculating that interest. In the event that the interest is a fluctuating rate, the rate for the Subcontractor shall be determined by calculating the interest rate paid during the time that retentions were withheld from the Subcontractor. If the Contractor elects to substitute securities in lieu of retention, then, by mutual consent of the Contractor and the Subcontractor, the Subcontractor may substitute securities in exchange for the release of moneys held in retention by the Contractor. The mandatory escrow agreement is included in these Contract Documents at Section 00630. SLVWD will not certify that the Contract has been satisfactorily completed until at least 30 days after filing by SLVWD of a Notice of Completion.

- J. Public Works Contractors; Assignment to Awarding Body:** In accordance with Section 7103.5 of the California Public Contract Code, the Contractor and Subcontractors shall conform to the following requirements. In entering into a public works Contract or a subcontract to supply goods, services, or materials pursuant to a public works Contract, the Contractor or subcontractor offers and agrees to assign to the awarding body all rights, title, and interest in and to all causes of action it may have under Section 4 of the Clayton Act (15 U.S.C. Sec. 15) or under the Cartwright Act (Chapter 2 (commencing with Section 16700) of Part 2 of Division 7 of the Business and Professions Code), arising from purchases of goods, services, or materials pursuant to the public works Contract or the subcontract. This assignment shall be made and become effective at the time the awarding body tenders final payment to the Contractor, without further acknowledgment by the parties.
- K. Payroll Records; Retention; Inspection; Noncompliance Penalties; Rules and Regulations:**
1. In accordance with Section 1776 of the California Labor Code, the Contractor and each Subcontractor shall keep an accurate payroll record, showing the name, address, social security number, work classification, straight time and overtime hours worked each day and week, and the actual per diem wages paid to each, journeyman, apprentice, worker, or other employee employed by him or her in connection with the work pursuant to the Contract. The certified payroll records shall be on forms provided by the Division of Labor Standards Enforcement or shall contain the same information as the forms provided by the division. In accordance with Section 1771.4 of the California Labor Code, each Contractor and Subcontractor shall furnish payroll records directly to the Labor Commission at least monthly and in a format prescribed by the Labor Commissioner. The payroll records may consist of printouts of payroll data that are maintained as computer records, if the printouts contain the same information as the forms provided by the division and the printouts are verified in the manner specified in subdivision (a) of Section 1776 of the Labor Code. Each payroll record shall contain or be verified by a written declaration that is made under penalty of perjury, stating both of the following: (1) the information contained in the payroll record is true and correct and (2) the employer has complied with the requirements of Sections 1771, 1811, and 1815 for any work performed by his or her employees on the public works project.

2. The payroll records enumerated under Paragraph K.1 shall be certified and shall be available for inspection at all reasonable hours at the principal office of the Contractor on the following basis:
 - a. A certified copy of all employees' payroll records shall be made available for inspection or furnished to the employee or his or her authorized representative on request, and will accompany each progress payment to Owner.
 - b. A certified copy of all payroll records enumerated in Paragraph K.1 shall be made available for inspection or furnished upon request to a representative of SLVWD, the Division of Labor Standards Enforcement, and the Division of Apprenticeship Standards of the Department of Industrial Relations in compliance with Section 1776 of the California Labor Code and other relevant state law.
 - c. A certified copy of all payroll records enumerated in Paragraph K.1 shall be made available upon request by the public for inspection or copies thereof made; provided, however, that a request by the public shall be made through either the body awarding the Contract, the Division of Apprenticeship Standards, or the Division of Labor Standards Enforcement. If the requested payroll records have not been provided pursuant to Paragraph K.1(b) the requesting party shall, prior to being provided the records, reimburse the costs of preparation by the Contractor, Subcontractors, and the entity through which the request was made. The public shall not be given access to the records at the principal office of the Contractor.
3. The Contractor and Subcontractors shall file a certified copy of the records, enumerated in Paragraph K.1 with the entity that requested the records within ten (10) work days after receipt of a written request.
4. Any copy of records made available for inspection as copies and furnished upon request to the public or any public agency by SLVWD, the Division of Apprenticeship Standards, or the Division of Labor Standards Enforcement shall be marked or obliterated in such a manner as to prevent disclosure of an individual's name, address, and social security number. The name and address of the Contractor awarded the Contract or the Subcontractor performing the Contract shall not be marked or obliterated.
5. The Contractor shall inform SLVWD of the location of the records enumerated under Paragraph K.1 including the street address, city and county, and shall, within five (5) working days, provide a notice of change of location and address.
6. The Contractor or Subcontractor shall have ten (10) work days in which to comply subsequent to receipt of written notice requesting the records enumerated under Paragraph K.1. In the event that the Contractor or Subcontractor fails to comply within the 10-workday period, he or she shall, as a penalty to SLVWD, forfeit one- hundred dollars (\$100.00) for each calendar day, or portion thereof, for each worker, until strict compliance is effectuated. Upon the request of the Division of Apprenticeship Standards or the Division of Labor Standards Enforcement, these penalties shall be withheld from progress payments then due. The Contractor shall

not be subject to a penalty assessment pursuant to this Paragraph K.6 due to the failure of a Subcontractor to comply with this Section K.

7. Contractor shall cause an identical clause to be included in every subcontract for work pursuant to this Contract.

L. Protection of Workers in Trench Excavations: As required by Section 6705 of the California Labor Code and in addition thereto, whenever work under the Contract that is over twenty-five thousand dollars (\$25,000) involves the excavation of any trench or trenches five (5) feet or more in depth, the Contractor shall submit for acceptance by SLVWD or by a registered civil or structural engineer, employed by SLVWD, to whom authority to accept has been delegated, in advance of excavation, a detailed plan showing the design of shoring, bracing, sloping, or other provisions to be made for worker protection from the hazard of caving ground during excavation, of such trench or trenches. If such plan varies from the shoring system standards established by the Construction Safety Orders of the Division of Occupational Safety and Health, the plan shall be prepared by a registered civil or structural engineer employed by the Contractor, and all costs therefore shall be included in the price named in the Contract for completion of the Work as set forth in the Contract Documents. Nothing in this Section shall be deemed to allow the use of a shoring, sloping, or other protective system less effective than that required by the Construction Safety Orders. Nothing in this Section shall be construed to impose tort liability on SLVWD, the Engineer, or any of their directors, officers, agents, representatives, or employees. The California Construction Safety Orders in effect during the Work shall apply continuously until final acceptance of the Work.

M. Removal, Relocation, or Protection of Existing Utilities:

1. In accordance with the provisions of Section 4215 of the California Government Code, any Contract to which a public agency as defined in Section 4401 is a party, the public agency shall assume the responsibility, between the parties to the Contract, for the timely removal, relocation, or protection of existing main or trunk line utility facilities located on the site of any construction project that is a subject of the Contract, if such utilities are not identified by the public agency in the plans and specifications made a part of the invitation for bids. The agency will compensate Contractor for the costs of locating, repairing damage not due to the failure of the Contractor to exercise reasonable care, and removing or relocating such utility facilities not indicated in the plans and specifications with reasonable accuracy and for equipment on the project necessarily idled during such work.
2. The Contractor shall not be assessed liquidated damages for delay in completion of the project, when such delay was caused by the failure of the public agency or the owner of the utility to provide for removal or relocation of such utility facilities.
3. Nothing herein shall be deemed to require the public agency to indicate the presence of existing service laterals or appurtenances when the presence of such utilities on the site of the construction project can be inferred from the presence of other visible facilities, such as buildings, meter and junction boxes, on or adjacent to the site of construction; provided, however, nothing herein shall relieve the public agency from identifying main or trunk lines in the plans and specifications.

4. If the Contractor while performing the Contract discovers utility facilities not identified by the public agency in the Contract plans and specifications, it shall immediately notify the public agency and utility in writing.
5. The public utility, where they are the owner, shall have the sole discretion to perform such repair or relocation work or permit the Contractor to do such repair or relocation work at a reasonable price.

N. Contractor License Requirements: In accordance with Section 7028.15 of the California Business and Professions Code, a licensed Contractor shall not submit a bid to a public agency unless his or her Contractor's license number and expiration date appears clearly on the bid. Any bid not containing this information, or a bid containing information which is subsequently proven false, shall be considered non-responsive and shall be rejected by the public agency.

O. Resolution of Construction Claims:

1. In accordance with Section 20104 *et seq.* of the California Public Contract Code. This paragraph O applies to all claims of \$375,000 or less which arise between the Contractor and SLVWD under this Contract for
 - a. A time extension;
 - b. Payment of money or damages arising from work done by or on behalf of the Contractor pursuant to this Contract and payment of which is not otherwise expressly provided for as the Contractor is not otherwise entitled; or
 - c. An amount the payment of which is disputed by SLVWD.
2. For any claim set out in Paragraph O1.a, b. or c. above the following requirements apply:
 - a. The claim shall be in writing and include the documents necessary to substantiate the claim. Claims must be filed on or before the date of final payment. Nothing herein is intended to extend the time limit or supersede notice requirements otherwise provide by Contract for the filing of claims.
 - b. For claims of less than fifty thousand dollars (\$50,000), SLVWD shall respond in writing to any written claim within forty-five (45) calendar days of receipt of the claim, or may request, in writing, within thirty (30) calendar days of receipt of the claim, any additional documentation supporting the claim or relating to defenses or claims SLVWD may have against the Contractor.

If additional information is thereafter required, it shall be requested and provided pursuant to this subdivision, upon mutual agreement of SLVWD and the Contractor.

SLVWD's written response to the claim, as further documented, shall be submitted to the Contractor within fifteen (15) calendar days after receipt of further documentation or within a period of time no greater than that taken by the Contractor in producing the additional information, whichever is greater.

- c. For claims over fifty thousand dollars (\$50,000) and less than or equal to three hundred seventy-five thousand dollars (\$375,000), SLVWD shall respond in writing to all written claims within sixty (60) calendar days of receipt of the claim or may request, in writing, within thirty (30) calendar days of receipt of the claim, any additional documentation supporting the claim or relating to defenses or claims SLVWD may have against the Contractor.

If additional information is therefore required, it shall be requested and provided pursuant to this subdivision, upon mutual agreement of SLVWD and the Contractor.

SLVWD's written response to the claim, as further documented, shall be submitted to Contractor within thirty (30) calendar days after receipt of the further documentation, or within a period of time no greater than that taken by the Contractor in producing the additional information or requested documentation, whichever is greater.

- d. If the Contractor disputes SLVWD's written response, or SLVWD fails to respond within the time prescribed, the Contractor may notify SLVWD, in writing, either within fifteen (15) calendar days of receipt of SLVWD's response or within fifteen (15) calendar days of SLVWD's failure to respond within the time prescribed, respectively, and demand an informal conference to meet and confer for settlement of the issues in dispute. Upon a demand, SLVWD shall schedule a meet and confer conference within thirty (30) calendar days for settlement of the dispute.
 - e. If the following meet and confer the claim or any portion remains in dispute, the Contractor may file a claim pursuant to Chapter 1 (commencing with Section 900) and Chapter 2 (commencing with Section 910) of Part 3 of Division 3.6 of Title 1 of the Government Code. For purposes of those provisions, the running of the period of time within which a claim must be filed shall be tolled from the time Contractor submits its written claim pursuant to subdivision (a) until the time the claim is denied, including any period of time utilized by the meet and confer conference.
3. The following procedures are established for all civil actions filed to resolve claims subject to this article:
- a. Within sixty (60) calendar days, but no earlier than thirty (30) calendar days, following the filing or responsive pleadings, the court shall submit the matter to nonbinding mediation unless waived by mutual stipulation of both parties. The mediation process shall provide for the selection within fifteen (15) calendar days by both parties of a disinterested third person as mediator, shall be commenced within thirty (30) calendar days of the submittal, and shall be concluded within fifteen (15) calendar days from the commencement of the mediation unless a time requirement is extended upon a good cause showing to the court. If the parties fail to select a mediator within the fifteen (15) calendar day period, any party may petition the court to appoint the mediator.

- b. If the matter remains in dispute, the case shall be submitted to judicial arbitration pursuant to Chapter 2.5 (commencing with Section 1141.10) of Title 3 of Part 3 of the Code of Civil Procedure, notwithstanding Section 1141.11 of that code. The Civil Discovery Act (Title 4 (commencing with Section 2016.101) or Part 4 of the Code of Civil Procedure) shall apply to any proceeding brought under this subdivision consistent with the rules pertaining to judicial arbitration.

Upon stipulation of the parties, arbitrators appointed for purposes of this Paragraph O.3 shall be experienced in construction law, and, upon stipulation of the parties, mediators and arbitrators shall be paid necessary and reasonable hourly rates of pay not to exceed their customary rate, and such fees and expenses shall be paid equally by the parties, except in case of arbitration where the arbitrator, for good cause, determines a different division. In no event shall these fees or expenses be paid by state or county funds.

In addition to Chapter 2.5 (commencing with Section 1141.10) of Title 3 of Part 3 of the Code of Civil Procedure, any party who after receiving an arbitration award requests a trial de novo but does not obtain a more favorable judgment shall, in addition to payment of costs and fees under that chapter, pay the attorney's fees of the other party arising out of the trial de novo.

4. SLVWD shall not fail to pay money to any portion of a claim which is undisputed except as otherwise provided in this Contract.
5. In any suit filed under Section 20104.4 of the California Public Contract Code SLVWD shall pay interest at the legal rate on any arbitration award or judgment. The interest shall begin to accrue on the date the suit is filed in a court of law.

P. Digging trenches or excavations; notice on discovery of hazardous waste or other unusual conditions; investigations; change orders; effect on Contract. Pursuant Section 7104 of the California Public Contract Code, if this Contract involves digging trenches or other excavations that extend deeper than four (4) feet below the surface, the following shall apply:

The Contractor shall promptly, and before the following conditions are disturbed, notify SLVWD in writing, of any:

1. Material that the Contractor believes may be material that is hazardous waste, as defined in Section 25117 of the Health and Safety Code that is required to be removed to a Class I, Class II, or Class III disposal site in accordance with provisions of existing law.
2. Subsurface or latent physical conditions at the site differing from those indicated by information about the site made available to bidders prior to the deadline for submitting bids.
3. Unknown physical conditions at the site of any unusual nature, different materially from those ordinarily encountered and generally recognized as inherent in work of the character provided for in the Contract.

4. SLVWD shall promptly investigate the conditions, and if it finds that the conditions do materially so differ, or do involve hazardous waste, and cause a decrease or increase in the Contractor's cost of, or the time required for, performance of any part of the work shall issue a change order under the procedures described in the Contract.
5. In the event that a dispute arises between SLVWD and the Contractor whether the conditions materially differ, or involve hazardous waste, or cause a decrease or increase in the Contractor's cost of, or the time required for, performance of any part of the work, the Contractor shall not be excused from any scheduled completion date provided for by the Contract, but shall proceed with all Work to be performed under the Contract. The Contractor shall retain any and all rights provided either by Contract or by law which pertain to the resolution of disputes and protests between the contracting parties.

Q. Retention Proceeds; Withholding; Disbursement. In accordance with Section 7107 of the Public Contracts Code with respect to all Contracts entered into on or after January 1, 1993 relating to the construction of any public work of improvement the following shall apply:

1. The retention proceeds withheld from any payment by SLVWD from the original Contractor, or by the original Contractor from any subcontractor, shall be subject to this paragraph Q.
2. The retention will be paid 60 calendar days "after" the date when Notice of Completion was filed with the County Recorder's Office. In the event of a dispute between SLVWD and the original Contractor, SLVWD may withhold from the final payment an amount not to exceed one hundred and fifty percent (150%) of the disputed amount. For the purposes of this paragraph, "completion" means any of the following:
 - a. The occupation, beneficial use, and enjoyment of a work of improvement, excluding any operation only for testing, startup, or commissioning, by SLVWD, accompanied by cessation of labor on the work of improvements.
 - b. The acceptance by SLVWD of the work of improvement.
 - c. After the commencement of a work of improvement, a cessation of labor on the work of improvement for a continuous period of 100 calendar days or more, due to factors beyond the control of the Contractor.
 - d. After the commencement of a work of improvement, a cessation of labor on the work of improvement for a continuous period of 30 calendar days or more, if SLVWD files for record a notice of cessation or a notice of completion.
3. Subject to subparagraph 4, within seven (7) days from the time that all or any portion of the retention proceeds are received by the original Contractor, the original Contractor shall pay each of its subcontractors from whom retention has been withheld, each Subcontractor's share of the retention received. However, if a retention payment received by the original Contractor is specifically designated for a

particular Subcontractor, payment of the retention shall be made to the designated Subcontractor, if the payment is consistent with the terms of the subcontract.

4. The original Contractor may withhold from a Subcontractor its portion of the retention proceeds if a bona fide dispute exists between the Subcontractor and the original Contractor. The amount withheld from the retention payment shall not exceed one hundred and fifty percent (150%) of the estimated value of the disputed amount.
5. In the event that retention payments are not made within the time periods required by this paragraph Q, SLVWD or original Contractor shall be subject to a charge of two percent (2%) per month on the improperly withheld amount, in lieu of any interest otherwise due. Additionally, in any action for the collection of funds wrongfully withheld, the prevailing party shall be entitled to attorney's fees and costs.
6. Any attempted waiver of the provisions of this section shall be void as against the public policy of this state.

R. Subcontractors.

1. In compliance with the California Public Contract Code Section 4100 *et seq.*, each bidder shall state in his bid the name and business address of each subcontractor who will perform work or a labor or render services to the Contractor in or about the construction of the Work in an amount in excess of one-half of one percent (0.5%) of the total bid amount, and the portion of the Work which will be done by each subcontractor.
2. Each portion of the Work shall be performed by an organization equipped and experienced to do the Work in the particular field, and no portion of the Work shall be reserved by the bidder or Contractor to himself unless he is so equipped and experienced.
3. Not more than one (1) subcontractor shall be listed for the same portion of the Work.
4. If a particular portion of the Work would be modified by an alternative bid or work in a bid item required by the bid, the bidder shall separately identify such portions of the Work, and list the subcontractors appropriately where they differ from those listed for the basic Work.
5. The substitution of Subcontractors shall comply with California Public Contract Code Sections 4107 and 4107.5. Prior to SLVWD approving Contractor's request for substitution, SLVWD shall give written notice to the listed Subcontractor of the Contractor's request and the reasons for the request. The listed Subcontractor will have five (5) days to submit written objections. Failure of the listed Subcontractor to submit written objections constitutes the listed Subcontractor's consent to the substitution. Requirements of General Conditions, Paragraph 2.11 and 10.2 shall also govern except where differing, in which instances the requirement of this Paragraph shall govern.

S. Notification of Third-Party Claim.

1. SLVWD shall notify the Contractor of the receipt of any third-party claim relating to the Contract within ten (10) work days of SLVWD's receipt of such claim.
2. SLVWD shall be entitled to recover its reasonable costs in providing the notification pursuant to this Paragraph S.

T. State Audit. The Contract shall be subject to the examination and audit of the State Auditor, at the request of SLVWD or as part of any audit of SLVWD, for a period of three (3) years after final payment under the Contract. The contracting parties shall be subject to that examination and audit.

U. Information Pursuant to California Labor Code Section 2810.

1. The Contractor shall complete and submit section 00648 pursuant to California Labor Code Section 2810. This form is a portion of the Contract Documents.
2. Any material change to the terms and conditions of the Contract shall be in writing, in a single document, and contain all of the provisions listed in Section 00648 that are affected by the change.

V. Public Works Contractor Registration Program: In compliance with Section 1725.5 of the California Labor Code, Contractor must be, and must require all Subcontractors be, registered with the DIR prior to execution of the Contract Agreement. Contractor and all Subcontractors who bid or work on, and/or who are awarded the Contract Agreement, must be registered with and pay an annual fee to the DIR. Neither Contractor nor any Subcontractors may be listed on the Bid Proposal unless registered with the DIR pursuant to Section 1725.5 of the Labor Code. Neither Contractor nor any Subcontractors may be awarded the Contract Agreement unless registered with the DIR pursuant to Section 1725.5 of the Labor Code. The project is subject to compliance monitoring and enforcement by the DIR. Contractor shall submit proof of current DIR registration, and shall require all Subcontractors to submit proof of current DIR registration, to SLVWD prior to commencing work on the project.

END OF SECTION 00800CA

SECTION 01 10 00

SUMMARY OF THE WORK

PART 1 - GENERAL

1.01 SECTION INCLUDES

- Description of Work
- Contractor Use of Site
- Owner Use of Facilities
- Project Meetings

1.02 DESCRIPTION OF WORK

- A. The project consists of providing new water mains and residential water services along Country Club Drive and Woodland Drive in Ben Lomond, CA with associated fittings and valves. Provide and install approximately 1260-LF of 8-inch ductile iron pipe water main, approximately 44-LF of 6-inch ductile iron pipe water main, approximately 31-LF of 4-inch ductile iron pipe water main, and reconnect 4 existing residential water services. Provide traffic control during the work.
- B. Working hours shall be as identified as weekdays 8 a.m. through 5 p.m. Note that weekend work will not be permitted.
- C. Contractor shall be aware that the site includes limited access, periods of heavy traffic, and narrow roads; Traffic control planning and execution will be important to ensure a successful project.

1.03 CONTRACTOR USE OF SITE

- A. Country Club Road and Woodland Drive are privately maintained roads. Work is limited to the right-of-way width.
- B. Country Club Road, Woodland Drive, and other roads in this neighborhood are generally not wide enough for two-way traffic. Contractor to address traffic control accordingly.
- C. All roads shall be re-opened at the end of each working day.
- D. In the event of an emergency, Contractor shall provide for safe emergency vehicle access through and across the site within five minutes of notice. This access shall include staging of steel plates or other approved trench bridging materials immediately adjacent to the open trench or other disturbed paving.
- E. Contractor shall maintain site in such a condition as to allow residents safe access through and across the site at the below times. These times to be determined with coordination with the District. Signs identifying times of resident access shall be posted at each end of the jobsite.

1. One 30-minute window between 8 a.m. and 12 p.m.
2. One 30-minute window during Contractor's break for lunch
3. One 30-minute window between 1 p.m. and 5 p.m.

F. Contractor is allowed use of future tank site parcel (APN 078-233-05) for staging and temporary storage purposes.

G. Contractor shall coordinate any additional staging and storage areas with the District per Section 01 55 00..

1.04 OWNER USE OF FACILITIES

A. Maintain service to existing customers during the work. Coordinate with District staff for scheduled outages.

1.05 PROJECT MEETINGS

A. Preconstruction Conference:

1. Prior to the commencement of Work at the site, one preconstruction conference will be held at a mutually agreed time and place which shall be attended by the Contractor's Project Manager, its Superintendent, and its Subcontractors as the Contractor deems appropriate. Other attendees will be:
 - a. Engineer.
 - b. Representatives of Owner
 - c. Representatives of Property Owner.
 - d. Governmental representatives as appropriate.
 - e. Others as requested by Engineer, Contractor, or Owner.
2. The purpose of the conference is to designate responsible personnel and establish a working relationship. Matters requiring coordination will be discussed and procedures for handling such matters established. The complete agenda will be furnished to the Contractor prior to the meeting date. However, the Contractor should be prepared to discuss all of the items listed below.
 - a. Status of Contractor's insurance and bonds.
 - b. Contractor's tentative schedules.
 - c. Processing applications for payment.
 - d. Maintaining record documents.
 - e. Critical work sequencing.
 - f. Field decisions and Change Orders.
 - g. Use of project site, office and storage areas, security, housekeeping, and Owner's needs.
 - h. Major equipment deliveries and priorities.
 - i. Contractor's assignments for safety and first aid.
 - j. Contractor's proposed traffic control plan
 - k. The Engineer will preside at the preconstruction conference and will arrange for keeping and distributing the minutes to all persons in attendance.
 - l. The Contractor and its Subcontractors should plan on the conference taking 2 hours.

B. Progress Meetings:

1. The Contractor shall attend regular on-site progress meetings at least weekly -and at other times as requested by Engineer or as required by progress of the Work. The Contractor, Engineer, and all Subcontractors active on the site must attend each meeting. Contractor may at its discretion request attendance by representatives of its Suppliers, manufacturers, and other Subcontractors.
2. The Engineer shall preside at the meetings and will arrange for keeping and distributing the minutes. The purpose of the meetings will be to review the progress of the Work, maintain coordination of efforts, discuss changes in scheduling, and resolve other problems which may develop. During each meeting, the Contractor is required to present any issues which may impact his work, with a view to resolve these issues expeditiously.

1.06 PROJECT SIGNAGE

- A. Contractor shall provide signs at each end of the project area which shall include the following:
 - a. Project Name, identifying project as San Lorenzo Valley Water District work;
 - b. District logo and website url: SLVWD.com
 - c. Contractor Name and contact information;
 - d. Contract cost of project
 - e. Anticipated dates of construction; and
 - f. Anticipated dates of limited access
- B. Project signs shall:
 - a. Be minimum 36-inches high by 48-inches wide, larger signs to be of similar proportions;
 - b. Include colors as follows:
 - Background shall be white
 - Lettering shall be black, in Arial Rounded MT Bold font
 - District logo shall be full color (Pantone colors: Teal 298c, green 360c, black BlackC) as shown on the cover sheet of this RFP
- C. Contractor shall coordinate with the District to determine sign placement prior to project start.

Something similar to Caltrans <https://dot.ca.gov/-/media/dot-media/programs/safety-programs/documents/signs/c/c47a-cally.pdf>. Once we do a standard we will have it to refer to. Added to our standard details.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION

SECTION 01 20 00

MEASUREMENT AND PAYMENT

PART 1 - GENERAL

1.01 SECTION INCLUDES

- A. Methods of Measurement
- B. Description of Bid Items

1.02 METHODS OF MEASUREMENT

- A. Materials and items of work which are to be paid for on the basis of measurement shall be measured in accordance with the method stipulated in the particular sections involved. In determining quantities, all measurements shall be made in a horizontal plane unless otherwise specified.
- B. Measurements shall be in accordance with U.S. Standard Measures. A pound is an avoirdupois pound. A ton is 2,000 pounds' avoirdupois. The unit of liquid measure is the U.S. gallon. The unit of length is feet. The unit of volume is cubic yards.
- C. Material not used from a transporting vehicle shall be determined by the ENGINEER and deducted from the certified tag.
- D. When material is to be measured and paid for on a volume basis and it would be impractical to determine the volume, or when requested by the CONTRACTOR in writing and approved by the ENGINEER in writing, the material will be weighed and converted to volume measurement for payment purposes. Factors for conversion from weight measurement to volume measurement will be determined by the ENGINEER and shall be agreed to by the CONTRACTOR before such method of measurement of pay quantities will be adopted.
- E. Full compensation for all expense involved in conforming to the above requirements for measuring and weighing materials shall be considered as included in the unit prices paid for the materials being measured or weighed and no additional allowances will be made therefore.
- F. Quantities of material wasted or disposed of in a manner not called for under the Contract; or rejected loads of material, including material rejected after it has been placed by reason of failure of the CONTRACTOR to conform to the provisions of the Contract; or material not unloaded from the transporting vehicle; or material placed outside the lines indicated on the plans or given by the ENGINEER; or material remaining on hand after completion of the Contract, will not be paid for and such quantities will not be included in the final total quantities. No compensation will be allowed for hauling rejected material.

- G. Bid items include all work necessary to complete the specific item described and not otherwise included in other bid items. The CONTRACTOR shall include in each bid item all costs required to construct the work in accordance with the Contract Documents and as identified below.

1.03 DESCRIPTION OF BID ITEMS

A. Bid Item 1: Mobilization/Demobilization.

- 1. The lump sum bid price for this item shall constitute full compensation for mobilization and demobilization including but not limited to equipment shipping and delivery, equipment set up, materials shipping and delivery, utility coordination, permitting including any required Santa Cruz County Construction Permitting, removal of equipment, and project closeout. The Mobilization/Demobilization bid item shall not be in excess of five percent (5%) of the total bid schedule. Twenty-five percent (25%) of the total Mobilization/Demobilization bid price shall be considered the cost of Demobilization and will not be paid until completion of the work.

B. Bid Item 2: Sheeting, Shoring and Bracing.

- 1. The lump sum bid price for this item shall constitute full compensation for all material, labor, equipment, tools, and services necessary to provide sheeting, shoring and bracing of excavations, trenches and grading as required in the Contract Documents. Cost shall include any engineering or geotechnical investigations performed by the CONTRACTOR.

C. Bid Item 3: Traffic Control

- 1. The lump sum bid price for this item shall constitute full compensation for all material, labor, equipment, tools, and services necessary to provide traffic control for the Work as required in the Contract Documents, and shall conform to Santa Cruz County Requirements. Price shall include, but is not limited to, signage, flagmen, lights, barricades, and pilot cars as needed.

D. Bid Item 4: 8-inch Ductile Iron Water Main.

- 1. The unit price per linear foot shall constitute full compensation for all material, labor, equipment, tools, and services necessary to provide 8-inch ductile iron water main. Price shall include, but is not limited to, thrust restraints, temporary caps or plugs, installation, disinfection, pressure testing, final connection to system, excavation, backfill, compaction, asphalt restoration and all other work or appurtenances required for a complete installation.
- 2. Measurement shall be along the final installed alignment, as measured in the field.

E. Bid Item 5: 6-inch Ductile Iron Water Main.

- 1. The unit price per linear foot shall constitute full compensation for all material, labor, equipment, tools, and services necessary to provide 6-inch ductile iron water main. Price shall include, but is not limited to, thrust restraints, temporary caps or plugs, installation, disinfection, pressure testing, final connection to system, excavation, backfill, compaction, asphalt restoration and all other work or appurtenances required for a complete installation.
- 2. Measurement shall be along the final installed alignment, as measured in the field.

F. Bid Item 6: 4-inch Ductile Iron Water Main.

1. The unit price per linear foot shall constitute full compensation for all material, labor, equipment, tools, and services necessary to provide 4-inch ductile iron water main. Price shall include, but is not limited to, thrust restraints, temporary caps or plugs, installation, disinfection, pressure testing, final connection to system, excavation, backfill, compaction, asphalt restoration and all other work or appurtenances required for a complete installation.
2. Measurement shall be along the final installed alignment, as measured in the field.

G. Bid item 7: 8-inch Resilient Wedge Gate Valve

1. The unit price per valve shall constitute full compensation for all material, labor, equipment, tools, and services necessary to provide an 8-inch resilient wedge gate valve on the new water main. Price shall include, but is not limited to, excavation, installation, thrust restraint, backfill, compaction, repaving and all other work or appurtenances required for a complete installation.

H. Bid item 8: 6-inch Resilient Wedge Gate Valve

1. The unit price per valve shall constitute full compensation for all material, labor, equipment, tools, and services necessary to provide a 6-inch resilient wedge gate valve on the new water main. Price shall include, but is not limited to, excavation, installation, thrust restraint, backfill, compaction, repaving and all other work or appurtenances required for a complete installation.

I. Bid item 9: 4-inch Resilient Wedge Gate Valve

1. The unit price per valve shall constitute full compensation for all material, labor, equipment, tools, and services necessary to provide a 4-inch resilient wedge gate valve on the new water main. Price shall include, but is not limited to, excavation, installation, thrust restraint, backfill, compaction, repaving and all other work or appurtenances required for a complete installation.

J. Bid item 10: 2-inch Resilient Wedge Gate Valve

1. The unit price per valve shall constitute full compensation for all material, labor, equipment, tools, and services necessary to provide a 2-inch resilient wedge gate valve on the new water main. Price shall include, but is not limited to, excavation, installation, thrust restraint, backfill, compaction, repaving and all other work or appurtenances required for a complete installation.

K. Bid Item 11: Hot Tap to existing 6-inch and 4-inch Mains.

1. The unit price per hot tap shall constitute full compensation for all material, labor, equipment, tools, and services necessary to provide both 6-inch on 6-inch and 4-inch on 4-inch hot taps on an existing HDPE water main. Price shall include, but is not limited to, tapping saddle, gate valve, valve can, excavation, installation, thrust restraint, backfill, compaction, repaving and all other work or appurtenances required for a complete installation.

- L. Bid Item 12: Connection to Existing 1.5-inch Mains.
1. The unit price per connection shall constitute full compensation for all material, labor, equipment, tools, and services necessary to field fit new pipe to an existing 1.5-inch galvanized steel water main. Price shall include, but is not limited to, excavation, thrust restraint, backfill, compaction, repaving and all other work or appurtenances required for a complete installation.
- M. Bid Item 13: Abandon Existing 4-inch and 1.5-inch Mains.
1. The lump sum bid price shall constitute full compensation for all material, labor, equipment, tools, and services necessary to abandon existing water mains as shown on the Drawings. Price shall include, but not be limited to, plugs, caps, fittings, grout, excavation, backfill, compaction, repaving and all other work or appurtenances required for a complete installation. CONTRACTOR to expose and cut back abandoned pipe, then plug with 2-sack slurry, in accordance with Section 020100-3.
- N. Bid Item 14: 2-inch Air-Vac Valve.
1. The unit price per valve shall constitute full compensation for all material, labor, equipment, tools, and services necessary to provide a combination air-relief and vacuum breaker valve as shown on the Drawings. Price shall include, but not be limited to, tapping saddle, corporation stop, piping, concrete pedestal, valves, enclosure, excavation, backfill, compaction and all other work or appurtenances required for a complete installation.
- O. Bid Item 15: 1-inch Residential Services
1. The unit bid price per service shall constitute full compensation for all material, labor, equipment, tools, and services necessary to replace existing water service laterals. Price shall include, but is not limited to, tapping saddle, corporation stop, PE water service lateral, meter setter or angle stop, meter box, excavation, backfill, compaction, repaving and all other work or appurtenances required for a complete installation.
 2. Item includes customer notifications with signage and door hangers.
 3. Owner shall furnish replacement water meters, if needed.
- P. Bid Item 16: Striping
1. This lump sum price shall constitute full compensation for all material, labor, equipment, tools, and services necessary to replace in kind all existing striping damaged or destroyed during construction activities. Price shall include, but is not limited to, provide striping materials, place striping, and dispose of waste.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION

SECTION 01 30 00

CONTRACTOR SUBMITTALS

PART 1 - GENERAL

1.01 GENERAL

- A. Wherever submittals are required hereunder, all such submittals by the Contractor shall be submitted to the Engineer.
- B. Prior to receiving Notice to Proceed, the Contractor shall submit a Site Specific Safety Plan addressing the requirements of Article 13 of the General Conditions.
- C. Within 14 days after the date of commencement as stated in the Notice to Proceed or at Preconstruction Conference, whichever occurs earliest, the Contractor shall submit the following items to the Engineer for review:
 - 1. A preliminary schedule of Shop Drawings, Samples, and proposed Substitutes ("Or-Equal") submittals listed in the Bid.
 - 2. A list of all permits and licenses the Contractor shall obtain indicating the agency required to grant the permit and the expected date of submittal for the permit and required date for receipt of the permit.

1.02 PRECONSTRUCTION CONFERENCE SUBMITTALS

- A. At the preconstruction conference referred to in Section 01100, "Summary of Work," the Contractor shall submit the following items to the Engineer for review:
 - 1. A preliminary schedule of Shop Drawings, Samples, and proposed Substitute ("Or-Equal") submittals listed in the Bid.
 - 2. A list of all permits and licenses the Contractor shall obtain indicating the agency required to grant the permit, the expected date of submittal for the permit, and required date for receipt of the permit.
 - 3. Construction schedule for entire project.
 - 4. A preliminary schedule of values for lump sum pay items.

1.03 SHOP DRAWINGS

- A. Shop drawings may be submitted electronically (.pdf format print or scan) via e-mail. If submitting by e-mail, confirm the receipt of large file attachments. The term "Shop Drawings" as used herein shall be understood to include detail design calculations, shop drawings, fabrication, and installation drawings, erection drawings, lists, graphs, catalog sheets, data sheets, and similar items. Whenever the Contractor is required to submit design calculations as part of a submittal, such calculations shall bear the signature and seal of an Engineer registered in the appropriate engineering branch and in the State of California, unless otherwise directed.

- B. Wherever hard copy original submittals are called for in the Contract Documents or required by the Engineer, the Contractor shall furnish to the Engineer for review, 8 copies of each shop drawing submittal.
- C. Normally, a separate transmittal form shall be used for each specific item or class of material or equipment for which a submittal is required. Transmittal of a submittal of various items using a single transmittal form will be permitted only when the items taken together constitute a manufacturer's "package" or are so functionally related that expediency indicates review of the group or package as a whole. A multiple-page submittal shall be collated into sets, and each set shall be stapled or bound, as appropriate, prior to transmittal to the Engineer.
- D. Except as may otherwise be indicated herein, the Engineer will return each submittal to the Contractor with its comments noted thereon, within 7 working days following their receipt by the Engineer. It is considered reasonable that the Contractor shall make a complete and acceptable submittal to the Engineer by the second submission of a submittal item. The OWNER reserves the right to withhold monies due to the Contractor to cover additional costs of the Engineer's review beyond the second submittal. The Engineer's maximum review period for each submittal, including all resubmittals, will be 7 working days per submittal. In other words, for a submittal that requires two resubmittals before it is complete, the maximum review period for that submittal could be 14 working days. No extension of Contract Time will be granted for delays due to resubmittals that are reviewed within the number of days specified.
- E. If a submittal is returned to the Contractor marked "NO EXCEPTIONS TAKEN," no revisions are required.
- F. If a submittal is returned to the Contractor marked "MAKE CORRECTIONS NOTED," the noted revisions must be made but resubmission of said submittal will not be required.
- G. If a submittal is returned to the Contractor marked "REVISE AND RESUBMIT," the Contractor shall revise said submittal and shall resubmit the required number of copies of said revised submittal to the Engineer.
- H. If a submittal is returned to the Contractor marked "REJECTED-RESUBMIT," the Contractor shall revise said submittal and shall resubmit the required number of copies of said revised submittal to the Engineer.
- I. Submittals which are for information only or which must be reviewed and approved by a permitting jurisdiction will be marked "RECEIPT ACKNOWLEDGED" by the Engineer.
- J. Fabrication of an item shall be commenced only after the Engineer has reviewed the pertinent submittals and returned copies to the Contractor marked either "NO EXCEPTIONS TAKEN" or "MAKE CORRECTIONS NOTED." Corrections indicated on submittals shall be considered as changes necessary to meet the requirements of the Contract Documents and shall not be taken as the basis for changes to the contract requirements.
- K. All Contractor shop drawings submittals shall be carefully reviewed by an authorized representative of the Contractor, prior to submittal to the Engineer. Each submittal shall be dated, signed, and certified by the Contractor, as being correct and in strict conformance

with the Contract Documents. In the case of shop drawings, each sheet shall be so dated, signed, and certified. No consideration for review by the Engineer of any Contractor submittals will be made for any items which have not been so certified by the Contractor. All non-certified submittals will be returned to the Contractor without action taken by the Engineer, and any delays caused thereby shall be the total responsibility of the Contractor.

- L. The Engineer's review of Contractor shop drawings submittals shall not relieve the Contractor of the entire responsibility for the correctness of details and dimensions. The Contractor shall assume all responsibility and risk for any misfits due to any errors in Contractor submittals. The Contractor shall be responsible for the dimensions and the design of connections between provided items (parts must fit together) and for the anchorage of supplied equipment when not detailed on the design drawings.

1.04 CONTRACTOR'S SCHEDULE

- A. Prepare construction schedule showing sequence of activities and proposed shutdowns.
- B. Submit a preliminary construction schedule not later than the Pre Construction Meeting.
- C. Update construction schedule on monthly basis and submit with request for Progress Payment.

1.05 RECORD DRAWINGS

- A. The Contractor shall keep and maintain, at the job site, one record set of Drawings. On these, it shall mark all project conditions, locations, configurations, and any other changes or deviations which may vary from the details represented on the original Contract Drawings, including buried or concealed construction and utility features which are revealed during the course of construction. Special attention shall be given to recording the horizontal and vertical location of all buried utilities that differ from the locations indicated, or which were not indicated on the Contract Drawings. Said record drawings shall be supplemented by any detailed sketches as necessary or directed to indicate, fully, the WORK as actually constructed. These master record drawings of the Contractor's representation of as-built conditions, including all revisions made necessary by addenda and change orders shall be maintained up-to-date during the progress of the WORK. Copies of the modified record drawings shall be submitted on completion of WORK.
- B. Record drawings shall be accessible to the Engineer at all times during the construction period. Owner may hold a progress payment amount of \$5,000 until Contract Record Drawings are up-to-date.
- C. Final payment will not be acted upon until the Contractor's record drawings have been prepared and delivered to the Engineer. Said up-to date record drawings shall be in the form of a set of Contract Documents prints with any changes from the original Contract Documents carefully plotted on the prints in red ink.
- D. Upon substantial completion of the WORK and prior to final acceptance, the Contractor shall finalize and deliver a complete set of record drawings to the Engineer for transmittal to the OWNER, conforming to the construction records of the Contractor. This set of drawings shall consist of corrected drawings showing the reported location of the WORK. The information submitted by the Contractor and incorporated by the Engineer into the

Record Drawings will be assumed to be correct, and the Contractor shall be responsible for the accuracy of such information, and for any errors or omissions which may appear on the Record Drawings as a result.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION

SECTION 01 41 00

REFERENCE STANDARDS

PART 1 - GENERAL

1.01 GENERAL

A. Titles of Sections and Paragraphs

1. Captions accompanying specification sections and paragraphs are for convenience of reference only, and do not form a part of the Specifications.

B. Applicable Publications

1. Whenever in these Specifications references are made to published specifications, codes, standards, or other requirements, it shall be understood that wherever no date is specified, only the latest specifications, standards, or requirements of the respective issuing agencies which have been published as of the date that the Work is advertised for bids, shall apply; except to the extent that said standards or requirements may be in conflict with applicable laws, ordinances, or governing codes. No requirements set forth herein or shown on the Drawings shall be waived because of any provision of, or omission from, said standards or requirements.

C. Specialists, Assignments

1. In certain instances, specification text requires (or implies) that specific work is to be assigned to specialists or expert entities, who must be engaged for the performance of that work. Such assignments shall be recognized as special requirements over which the Contractor has no choice or option. These requirements shall not be interpreted so as to conflict with the enforcement of building codes and similar regulations governing the Work; also they are not intended to interfere with local union jurisdiction settlements and similar conventions. Such assignments are intended to establish which party or entity involved in a specific unit of work is recognized as "expert" for the indicated construction processes or operations. Nevertheless, the final responsibility for fulfillment of the entire set of contract requirements remains with the Contractor.

1.02 REFERENCE SPECIFICATIONS, CODES, AND STANDARDS

- ###### **A.**
- Without limiting the generality of other requirements of the Specifications, all work specified herein shall conform to or exceed the requirements of applicable codes and the applicable requirements of the following documents.

- ###### **B.**
- All Work within this Project is subject to the requirements of the California Building Standards Code. The latest edition of the code as approved by California Building Standards Commission and used by the local agency as of the date that the Work is advertised for bids, or as adopted by the agency having jurisdiction, shall apply to the Work herein, including all addenda, modifications, amendments, or other lawful changes thereto. References herein to:

1. "Building Code" or "Uniform Building Code" shall mean the California Building Code;

2. "Mechanical Code' or "Uniform Mechanical Code" shall mean the California Mechanical Code;
 3. "Plumbing Code' or "Uniform Plumbing Code" shall mean the California Plumbing Code;
 4. "Fire Code" or "Uniform Fire Code," shall mean the California Fire Code;
 5. "Electric Code" or "National Electric Code (NEC)" shall mean the California Electrical Code.
- C. In case of conflict between codes, reference standards, drawings and the other Contract Documents, the most stringent requirements shall govern. All conflicts shall be brought to the attention of the Engineer for clarification and directions prior to ordering or providing any materials or furnishing labor. The Contractor shall bid for the most stringent requirements.
- D. The Contractor shall construct the Work specified herein in accordance with the requirements of the Contract Documents and the referenced portions of those referenced codes, standards, and specifications listed herein.
1. References in the Contract Documents to "CALTRANS Standard Specifications" shall mean the State of California Department of Transportation Standard Specifications and Standard Plans. The Contractor should be prepared to distinguish between these two references.
 2. References herein to "OSHA Regulations for Construction" shall mean Title 29, Part 1926, Construction Safety and Health Regulations, Code of Federal Regulations (OSHA), including all changes and amendments thereto.
 3. References herein to "OSHA Standards" shall mean Title 29, Part 1910, Occupational Safety and Health Standards, Code of Federal Regulations (OSHA), including all changes and amendments thereto.
 4. Applicable Safety Standards
 5. References herein to "Cal-OSHA" shall mean State of California Department of Industrial Relations, Construction Safety Orders, as amended to date, and all changes and amendments thereto.
 6. Accessibility requirements shall conform to Title 24 of the California Administration Code and ADA Guidelines.

1.03 REGULATIONS RELATED TO CONSTRUCTION ACTIVITIES.

- A. The Contractor is responsible that all Work included in the Contract Documents, regardless if shown or not, shall comply with all EPA, OSHA, RCRA, NFPA, and any other Federal, State, and Local Regulations governing construction activities, as referenced in Section 00700, General Conditions, and Section 00800CA, California State Requirements.

1.04 REGULATIONS RELATED TO HAZARDOUS MATERIALS

- A. The Contractor is responsible that all Work included in the Contract Documents, regardless if shown or not, shall comply with all EPA, OSHA, RCRA, NFPA, and any other Federal, State, and Local Regulations governing the storage and conveyance of hazardous materials, including petroleum products.

- B. Where no specific regulations exist, all chemical, hazardous, and petroleum product piping and storage in underground locations must be installed with double containment piping and tanks, or in separate concrete trenches and vaults, or with an approved lining which cannot be penetrated by the chemicals, unless waived in writing by the OWNER.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION

SECTION 01 42 00

ABBREVIATIONS OF INSTITUTIONS

PART 1 - GENERAL

1.01 GENERAL

- A. Wherever in these Specifications references are made to the standards, specifications, or other published data of the various international, national, regional, or local organizations, such organizations may be referred to by their acronym or abbreviation only. As a guide to the user of these Specifications, the following acronyms or abbreviations which may appear in these Specifications shall have the meanings indicated herein.

1.02 ABBREVIATIONS

AAMA	Architectural Aluminum Manufacturer's Association
AAR	Association of American Railroads
AASHTO	American Association of State Highway and Transportation Officials
AATCC	American Association of Textile Chemists and Colorists
ACI	American Concrete Institute
AFBMA	Anti-Friction Bearing Manufacturer's Association, Inc.
AGA	American Gas Association
AGMA	American Gear Manufacturers Association
AHAM	Association of Home Appliance Manufacturers
AI	The Asphalt Institute
AIA	American Institute of Architects
AISC	American Institute of Steel Construction
AISI	American Iron and Steel Institute
AITC	American Institute of Timber Construction
AMCA	Air Moving and Conditioning Association
ANS-	American Nuclear Society
ANSI	American National Standards Institute, Inc.

APA	American Plywood Association
API	American Petroleum Institute
APWA	American Public Works Association
ASA	Acoustical Society of America
ASAE	American Society of Agricultural Engineers
ASCE	American Society of Civil Engineers
ASHRAE	American Society of Heating, Refrigerating, and Air Conditioning Engineers
ASLE	American Society of Lubricating Engineers
ASME	American Society of Mechanical Engineers
ASQC	American Society for Quality Control
ASSE	American Society of Sanitary Engineers
ASTM	American Society for Testing and Materials
AWPA	American Wood Preservers Association
AWPI	American Wood Preservers Institute
AWS	American Welding Society
AWWA	American Water Works Association
BBC	Basic Building Code, Building Officials and Code Administrators International
BHMA	Builders Hardware Manufacturer's Association
CBM	Certified Ballast Manufacturers
CEMA	Conveyors Equipment Manufacturer's Association
CGA	Compressed Gas Association
CLPCA	California Lathing and Plastering Contractors Association
CLFMI	Chain Link Fence Manufacturer's Institute
CMA	Concrete Masonry Association
CRSI	Concrete Reinforcing Steel Institute

DCDMA	Diamond Core Drill Manufacturer's Association
EIA	Electronic Industries Association
ETL	Electrical Test Laboratories
EPA	Environmental Protection Agency
FM	Factory Mutual System
FPL	Forest Products Laboratory
HI	Hydronics Institute
APMO	International Association of Plumbing and Mechanical Officials
ICBO	International Conference of Building Officials
IEEE	Institute of Electrical and Electronics Engineers
IES	Illuminating Engineering Society
IME	Institute of Makers of Explosives
IP	Institute of Petroleum (London)
IPC	Institute of Printed Circuits
IPCEA	Insulated Power Cable Engineers Association
ISA	Instrument Society of America
ISO	International Organization for Standardization
ITE	Institute of Traffic Engineers
MBMA	Metal Building Manufacturer's Association
MPTA	Mechanical Power Transmission Association
MSS	Manufacturers Standardization Society
MTI	Marine Testing Institute
NAAMM	National Association of Architectural Metal Manufacturer's
NACE	National Association of Corrosion Engineers
NBS	National Bureau of Standards
NCCLS	National Committee for Clinical Laboratory Standards

NEC	National Electrical Code
NEMA	National Electrical Manufacturer's Association
NFPA	National Fire Protection Association
NFPA	National Forest Products Association
NLGI	National Lubricating Grease Institute
NMA	National Microfilm Association
NSF	National Sanitation Foundation
NWMA	National Woodwork Manufacturers Association
OSHA	Occupational Safety and Health Administration
PCA	Portland Cement Association
PPI	Plastics Pipe Institute
RCRA	Resource Conservation and Recovery Act
RIS	Redwood Inspection Service
RVIA	Recreational Vehicle Industry Association
RWMA	Resistance Welder Manufacturer's Association
SAE	Society of Automotive Engineers
SAMA	Scientific Apparatus Makers Association
SMA	Screen Manufacturers Association
SMACCNA	Sheet Metal and Air Conditioning Contractors National Association
SPI	Society of the Plastics Industry, Inc.
SPIB	Southern Pine Inspection Bureau
SPR	Simplified Practice Recommendation
SSA	Swedish Standards Association
SSBC	Southern Standard Building Code, Southern Building Code Congress
SSPC	Steel Structures Painting Council
SSPWC	Standard Specifications for Public Works Construction

TAPPI	Technical Association of the Pulp and Paper Industry
TFI	The Fertilizer Institute
UBC	Uniform Building Code
UL	Underwriters Laboratories, Inc.
WCLIB	West Coast Lumber Inspection Bureau
WCRSI	Western Concrete Reinforcing Steel Institute
WEF	Water Environment Federation
WIC	Woodwork Institute of California
WRI	Wire Reinforcement Institute, Inc.
WWPA	Western Wood Products Association

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION

SECTION 01 53 00

PROTECTION OF EXISTING FACILITIES

PART 1 - GENERAL

1.01 GENERAL

- A. The Contractor shall protect all existing utilities and improvements not designated for removal and shall restore damaged or temporarily relocated utilities and improvements to a condition equal to or better than they were prior to such damage or temporary relocation, all in accordance with requirements of the Contract Documents.
- B. The Contractor shall verify the exact locations and depths of existing utilities shown that will be affected by the work. Contractor shall make exploratory excavations as necessary to confirm locations shown. The depths shown for existing underground utilities are based on record drawings, limited potholing, and survey information, and are approximate only (\pm 1-foot vertical and \pm 5-feet horizontal). Where the depths are not shown, no such information was obtained during design. When such exploratory excavations show the utility location as shown to be in error, the Contractor shall immediately notify the Engineer when existing utilities are not as shown on the drawings.
- C. Prior to any excavation in the vicinity of any existing underground facilities, including all water, sewer, storm drain, gas, petroleum products, or other pipelines; all buried electric power, communications, or television cables; all traffic signal and street lighting facilities; and all roadway and state highway rights-of-way the Contractor shall notify the respective authorities representing the owners or agencies responsible for such facilities. The Contractor shall also notify Underground Service Alert-North at 1-800-227-2600 at least 2 days, but no more than 14 days, prior to such excavation.
- D. Contractor shall photograph and document all project sites before and after construction. Contractor shall provide the Engineer with site pictures before work begins. Contractor shall provide the Engineer with photographs of completed work before requesting final payment.

1.02 PROTECTION OF STREET OR ROADWAY MARKERS AND MONUMENTS

- A. The Contractor shall not destroy, remove, or otherwise disturb any existing survey markers or other existing street or roadway markers without proper authorization. No pavement breaking or excavation shall be started until all survey or other permanent marker points that will be disturbed by the construction operations have been properly referenced. All survey markers or points disturbed by the Contractor shall be restored accurately after all street or roadway resurfacing has been completed.

1.03 RESTORATION OF PAVEMENT

- A. General: All paved areas including asphaltic concrete berms cut or damaged during construction shall be replaced with similar materials and of at least equal thickness to

match the existing adjacent undisturbed areas. All pavements which are subject to partial removal shall be neatly saw cut in straight lines.

- B. Temporary Resurfacing: Wherever required by the public authorities having jurisdiction, the Contractor shall place temporary surfacing promptly after backfilling and shall maintain such surfacing for the period of time fixed by said authorities before proceeding with the final restoration of improvements. Temporary surfacing shall be replaced with permanent pavement within no more than 5 days after completion of work in an area. At no time shall the Contractor have more than 2,000 feet of trench with temporary surfacing.
- C. Restoration of Sidewalks or Private Driveways: Wherever sidewalks or private roads have been removed for purposes of construction, the Contractor shall place suitable temporary sidewalks or roadways promptly after backfilling and shall maintain them in satisfactory condition for the period of time fixed by the authorities having jurisdiction over the affected portions before proceeding with the final restoration or, if no such period of times is so fixed, the Contractor shall maintain said temporary sidewalks or roadways until the final restoration thereof has been made.

1.04 EXISTING UTILITIES AND IMPROVEMENTS

A. General

- 1. The Contractor shall protect all Underground Utilities and other improvements which may be impaired during construction operations. It shall be the Contractor's responsibility to ascertain the actual location of all existing utilities and other improvements that will be encountered in its construction operations, and to see that such utilities or other improvements are adequately protected from damage due to such operations. The Contractor shall take all possible precautions for the protection of unforeseen utility lines to provide for uninterrupted service and to provide such special protection as may be necessary. The following clearances shall be met for gas mains and electric lines encountered:
 - a. Five feet from power pole to edge of straight trench.
 - b. Three feet from edge of slope for sloped trench.
 - c. Five feet from anchor blocks.
 - d. Three feet from edge of gas main to edge of pipeline.
 - e. One-foot minimum crossing of gas main with pipeline.
 - f. A minimum of ten radial feet from the conductors on overhead power lines.
- 2. Clearances to be met for telephone are the following:
 - a. Five feet for anchor blocks and telephone poles.
 - b. Three feet for sloped trench.

B. Utilities to be Moved:

- 1. In case it shall be necessary to move the property of any public utility or franchise holder, such utility company or franchise holder will, upon request of the Contractor, be notified by the Owner to move such property within a specified reasonable time. When utility lines that are to be removed are encountered within the area of operations, the Contractor shall notify the Engineer a sufficient time in advance for the necessary measures to be taken to prevent interruption of service.
- C. Where the proper completion of the Work requires the temporary or permanent removal and/or relocation of an existing utility or other improvement which is indicated, the

Contractor shall remove and, without unnecessary delay, temporarily replace or relocate such utility or improvement in a manner satisfactory to the Engineer and the owner of the facility. In all cases of such temporary removal or relocation, restoration to former location shall be accomplished by the Contractor in a manner that will restore or replace the utility or improvement as nearly as possible to its former locations and to as good or better condition than found prior to removal. The Contractor shall arrange with the utility for utility poles to be moved whenever any of the clearances described above cannot be maintained. Contractor shall pay for such utility pole relocation. No extra compensation shall be paid to the Contractor for movement of utility poles.

D. Owner's Right of Access:

1. The right is reserved to the Owner and to the owners of public utilities and franchises to enter at any time upon any public street, alley, right-of-way, or easement for the purpose of making changes in their property made necessary by the Work of this Contract.

E. Underground Utilities Indicated:

1. Existing utility lines that are indicated or the locations of which are made known to the Contractor prior to excavation and that are to be retained, and all utility lines that are constructed during excavation operations shall be protected from damage during excavation and backfilling and, if damaged, shall be immediately repaired or replaced by the Contractor.

F. Underground Utilities Not Indicated:

1. In the event that the Contractor damages any existing utility lines that are not indicated or the locations of which are not made known to the Contractor prior to excavation, a written report thereof shall be made immediately to the Engineer.

G. Approval of Repairs:

1. All repairs to a damaged utility or improvement are subject to inspection and approval by an authorized representative of the utility or improvement owner before being concealed by backfill or other work.

H. Maintaining in Service:

1. All oil and gasoline pipelines, power, and telephone or the communication cable ducts, gas and water mains, irrigation lines, sewer lines, storm drain lines, poles, and overhead power and communication wires and cables encountered along the line of the Work shall remain continuously in service during all the operations under the Contract, unless other arrangements satisfactory to the Engineer are made with the owner of said pipelines, duct, main, irrigation line, sewer, storm drain, pole, or wire or cable. The Contractor shall be responsible for all damage due to its operations, and the provisions of this Section shall not be abated even in the event such damage occurs after backfilling or is not discovered until after completion of the backfilling.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION

SECTION 01 55 00

SITE ACCESS AND STORAGE

PART 1 - GENERAL

1.01 HAUL ROADWAYS

- A. The Contractor shall make its own investigation of the condition of available public and private roads and of clearances, restrictions, bridge load limits, and other limitations affecting transportation and ingress and egress to the site of the Work.
- B. Provide traffic control as specified in Section 01 57 00.

1.02 CONTRACTOR'S WORK AND STORAGE AREA

- A. The Contractor shall make its own arrangements for any necessary off-site storage or shop areas necessary for the proper execution of the Work.
- B. Contractor shall be responsible for the security of its equipment, materials, and facilities stored in the temporary staging and storage areas.
- C. Contractor shall not use temporary staging and storage areas for maintenance of vehicles and equipment used in constructing the Work without prior approval by the Owner.
- D. No staging or materials or equipment outside of working hours will be allowed within the County ROW or on private roads.

1.03 PARKING

- A. The Contractor shall direct its employees to park in areas that do not interfere with traffic or access to the adjacent parcels.
- B. Traffic and parking areas shall be maintained in a sound condition, free of excavated material, construction equipment, mud, and construction materials. The Contractor shall repair breaks, potholes, low areas which collect standing water, and other deficiencies.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION

SECTION 01 56 00

TEMPORARY ENVIRONMENTAL CONTROLS

PART 1 - GENERAL

1.01 EXPLOSIVES AND BLASTING

- A. The use of explosives on the Work will not be permitted.

1.02 DUST AND MUD ABATEMENT

- A. The Contractor shall furnish all labor, equipment, and means required and shall carry out effective measures wherever and as often as necessary to prevent its operation from producing dust and/or mud in amounts damaging to property, cultivated vegetation, or domestic animals, or causing a nuisance to persons living in or occupying buildings in the vicinity. The Contractor shall be responsible for any damage resulting from any dust and/or mud originating from its operations. The dust or mud abatement measures shall be continued until the Contractor is relieved of further responsibility by the Engineer.

1.03 RUBBISH CONTROL

- A. During the progress of the Work, the Contractor shall keep the site of the Work and other areas used by it in a neat and clean condition, and free from any accumulation of rubbish. The Contractor shall dispose of all rubbish and waste materials of any nature occurring at the Work site and shall establish regular intervals of collection and disposal of such materials and waste. The Contractor shall also keep its haul roads free from dirt, rubbish, and unnecessary obstructions resulting from its operations. Disposal of all rubbish and surplus materials shall be off the site of construction in accordance with local codes and ordinances governing locations and methods of disposal, and in conformance with all applicable safety laws, and to the particular requirements of Part 1926 of the OSHA Safety and Health Standards for Construction.

1.04 SANITATION

- A. Toilet Facilities: Fixed or portable chemical toilets shall be provided wherever needed for the use of employees. Toilets at construction job sites shall conform to the requirements of Part 1926 of the OSHA Standards for Construction.
- B. Sanitary and Other Organic Wastes: The Contractor shall establish a regular daily collection of all sanitary and organic wastes. All wastes and refuse from sanitary facilities provided by the Contractor or organic material wastes from any other source related to the Contractor's operations shall be disposed of away from the site in a manner satisfactory to the Engineer and in accordance with all laws and regulations pertaining thereto.

1.05 CHEMICALS

- A. All chemicals used during project construction or furnished for project operation, whether defoliant, soil sterilant, herbicide, pesticide, disinfectant, polymer, reactant or of other

classification, shall show approval of either the U.S. Environmental Protection Agency or the U.S. Department of Agriculture. Use of all such chemicals and disposal of residues shall be in strict accordance with the printed instructions of the manufacturer.

- B. All chemicals used during the project construction or furnished for project operation, whether defoliant, soil sterilant, herbicide, pesticide, fertilizer, disinfectants, polymers, reactants, fuel, oil, hydraulic fluid, detergent, paint, solvent, glue, or any other classification, shall be stored within a containment area that minimizes contact of the chemicals and the storage containers with surface waters. The Contractor shall notify the Engineer to determine if the surface water has been contaminated or may be allowed to be discharged to the storm drains or stream channels. If the surface water flows have become contaminated due to contact with the chemicals or the storage containers, the Contractor shall provide for removal and/or treatment of the surface water flows at no additional costs to the Owner. If spills occur in the containment area, the Contractor shall immediately notify the Engineer and contain and clean up the spill to prevent spilled material from entering storm drains, stream channels, or groundwater or from being absorbed by the underlying pavement or soil.

1.06 TRENCH SPOILS DISPOSAL

- A. All trench spoils shall be hauled in trucks fitted with tarps and tailgates.
- B. All trench spoils shall be disposed of at suitable sites retained by the Contractor and in compliance with fill and grading permits, copies of which shall be provided to the Engineer.
- C. If disposing of trench spoils on private property, Contractor shall provide a release of liability from property owner upon construction completion.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION

SECTION 01 57 00

TRAFFIC REGULATION

PART 1 - GENERAL

1.01 TRAFFIC CONTROL REQUIREMENTS

- A. Traffic control plans shall be approved by the District. District standards require that traffic control plans comply with relevant State and/or County requirements.
- B. Contractor shall supply and install all traffic control devices (including all warning, regulatory and guide signs) as required in Section 7-1.08, "Public Convenience," 7-1.09, "Public Safety," and 12, "Construction area Traffic Control Devices," of the CALTRANS Standard Specifications. Traffic control for road closures shall comply with Caltrans Temporary Road Closure plan TA-13 and shall be augmented as described in this section.
- C. Contractor shall furnish traffic control plans for approval by The District a minimum of five (5) full working days prior to the preconstruction meeting. The traffic control plans are subject to public review and must be approved by the District prior to any installation of traffic control devices. Submit a copy of the plans to the Engineer "For Information Only". Traffic Control Plan shall, at a minimum, address the following:
 1. Flagger location in relation to the work, including provisions to make flagger more visible in areas of tight corners and heavy vegetation along the road
 2. Placement of all signage, which may include but not be limited to:
 - Road Closed
 - Flagger Ahead
 - Wait for Pilot Car
 - One Way Traffic Ahead
 - One Lane Road Ahead
 - Steel Plates Ahead
 - Bicycles Use Full Lane
 3. Temporary road closure locations
 4. One-way traffic control areas
 5. Bicycle access
- D. The traffic control plans shall be to scale and complete for each significant portion of the work requiring road closures, lane closures, traffic detours and/or restriction of traffic movements. The traffic control plans shall indicate the work area, all proposed signs, the spacing and location of all traffic control devices (arrow boards, flagmen, barricades, cones, pylon construction markers, etc.) the limits of proposed parking prohibitions, and the width and location of any rerouted traffic lanes. If pilot cars will be needed, traffic control plan shall identify locations where pilot cars will be used, type of vehicle to be used, locations of "wait for pilot car" signage, and pilot car turnaround areas.
- E. All open trenches must be adequately delineated by use of acceptable warning signs and devices during non-construction hours. The Contractor shall devise a typical plan indicating the type and spacing of barricades, signs, arrow boards, warning lights, pylon construction markers, construction tape, etc. to be used during non-construction hours.

This plan must be submitted to the Engineer at the preconstruction meeting for review and approval.

- F. It is imperative that field traffic control be handled in such a manner as to adequately and safely direct all traffic movements in the project area. The Contractor shall not be allowed to proceed with construction at any time that, in the opinion of the Engineer, traffic control is inadequate to meet the field conditions. Traffic control measures, in addition to those indicated on the approved traffic control plans may be required as field conditions dictate.

1.02 TEMPORARY CROSSINGS

A. General:

Continuous, unobstructed, safe, and adequate pedestrian, bicycle, and vehicular access shall be provided to fire hydrants, commercial, agricultural and industrial establishments, churches, schools, parking lots, service stations, motels, fire and police stations, and hospitals. Safe and adequate public transportation stops and pedestrian crossings at intervals not exceeding 500 feet shall be provided. The Contractor shall cooperate with parties involved in the delivery of mail and removal of trash and garbage so as to maintain existing schedules for such services. Vehicular access to residential driveways shall be maintained to the property line except when necessary construction precludes such access for reasonable periods of time.

B. Temporary Bridges:

1. Wherever necessary, the Contractor shall provide suitable temporary bridges or steel plates over unfilled excavations. All such bridges or steel plates shall be maintained in service until access is provided across the backfilled excavation. Temporary bridges or steel plates for street and highway crossing shall conform to the requirements of the authority having jurisdiction in each case, and the Contractor shall adopt designs furnished by said authority for such bridges or steel plates, or shall submit designs to said authority for approval, as may be required. If Contractor does not consider temporary bridge or steel plates necessary. Contractor shall secure written approval to omit the steel plates from the Engineer prior to excavation. Steel plates or other approved bridging materials shall be staged immediately adjacent to any open trench, and equipment suitable to properly place such plates or other materials to allow access across the work site shall be immediately available any time such trenches are open. Emergency vehicle (Fire, Law Enforcement, Ambulance, EMS) access shall be provided within a maximum of 5-minutes of notification. Contractor shall identify the point of contact for emergency access and shall provide contact information (cell phone and physical location) to the District and to the Ben Lomond Fire District. Contact cell phone number shall be included on all project identification signage.

1.03 STREET USE

- A. Nothing herein shall be construed to entitle the Contractor to the exclusive use of any public street, alleyway, or parking area during the performance of the Work hereunder, and it shall so conduct its operations as not to interfere unnecessarily with the authorized work of utility companies or other agencies in such streets, alleyways, or parking areas. No street shall be closed to the public without first obtaining permission of the Engineer District. Where excavation is being performed in primary streets or highways, one lane in each direction shall be kept open to traffic at all times unless otherwise indicated. Where excavation is being performed in a one lane road and requires closure of the entire road, road closures shall be approved by the District prior to placement. Toe boards shall be

provided to retain excavated material if required by the Engineer or the agency having jurisdiction over the street or highway. Fire hydrants on or adjacent to the Work shall be kept accessible to firefighting equipment at all times. Temporary provisions shall be made by the Contractor to assure the use of sidewalks and the proper functioning of all gutters, storm drain inlets, and other drainage facilities.

- B. Do not block driveway access to adjacent properties without the consent of the affected landowner.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION

SECTION 01 57 80

CONTROL OF GROUND AND SURFACE WATER

PART 1 - GENERAL

1.01 SECTION INCLUDES

- A. Dewatering, depressurization, draining, and maintenance of excavations and foundation beds in dry and stable condition.
- B. Protection of work against surface runoff and rising flood waters.
- C. Disposal of removed water.

1.02 REFERENCES

- A. ASTM D698 - Test Methods for Moisture-Density Relations of Soils and Soil Aggregate Mixtures, Using 5.5-lb (2.49 kg) Rammer and 12-inch (304.8 mm) Drop.
- B. Federal Regulations, 29 CFR 1926, Safety and Health Regulations for Construction, Subpart P, Excavations, Occupational Safety and Health Administration (OSHA)
- C. State Water Resources Control Board, Order No. WQO-2009-009-DWQ, General Permit for Storm Water Discharges Associated with Construction and Land Disturbance Activities, with Amendments
- D. California Regional Water Quality Control Board, Central Coast Region, Order No. R3-2011-0223, NPDES Permit No. CAG993001, Waste Discharge Requirements, General Permit for Discharges with Low Threat to Water Quality
- E. Santa Cruz County Code, Chapter 7.79, Runoff and Pollution Control

1.03 DEFINITIONS

- A. Groundwater control includes both dewatering and depressurization of water-bearing soil layers.
- B. Dewatering includes lowering the water table and intercepting seepage or localized perched water zones which would otherwise emerge from slopes or bottoms of excavations and disposing of removed water. Dewatering is intended to:
 - 1. Provide a stable or relatively dry working area for material excavation and/or backfill
 - 2. Improve excavating, hauling and screening characteristics of excavated material
 - 3. Increase stability of excavated slopes.
 - 4. Prevent dislocation of material from slopes or bottoms of excavations.
 - 5. Prevent failure or heaving of the bottom of excavations.
 - 6. Reduce lateral loads on sheeting and bracing (as applicable).

- C. Depressurization includes reduction in piezometric pressure within strata not controlled by dewatering alone, as required to prevent failure or heaving of excavation bottom.
- D. Excavation drainage control includes keeping excavations free of surface and seepage water.
- E. Surface drainage control includes use of temporary drainage ditches and dikes and installation of temporary culverts and sump pumps with discharge lines as required to protect the Work from any source of surface water.
- F. Equipment and instrumentation for monitoring and control of the dewatering system includes piezometers and monitoring wells, and devices, such as flow meters, for observing and recording flow rates.
- G. Continuous groundwater control installations for linear work include well points or eductor wells at maximum 15-foot spacing or deep wells at maximum 50-foot spacing.

1.04 PERFORMANCE REQUIREMENTS

- A. Review existing reports and conduct subsurface investigations, if needed, to identify groundwater conditions and to provide parameters for design, installation and operation of groundwater control systems.
- B. Design a ground water control system, compatible with Federal Regulations 29 CFR Part 1926, producing the following results:
 - 1. Effectively reduce the hydrostatic pressure affecting excavations and lower the groundwater level at least 2 feet below the bottom of excavations.
 - 2. Develop a substantially dry and stable subgrade for subsequent construction operations.
 - 3. Preclude damage to adjacent properties, utilities and other work.
 - 4. Prevent the loss of fines, seepage, boils, quick condition, or softening of the foundation strata.
 - 5. Maintain stability of sides and bottom of excavations.
 - 6. Design of the groundwater control system shall be prepared and signed by a qualified specialist who has sufficient prior experience and knowledge to assume responsibility of an effective groundwater control system.
- C. Ground water control systems may include excavation sump pumps, single- or multiple-stage well point systems, eductor and ejector-type systems, deep wells, or combinations of these equipment types. Excavation and surface drainage may also include sump pumping.
- D. Locate ground water control and drainage systems to not interfere with utilities, construction operations, adjacent properties, or adjacent water wells.
- E. Assume sole responsibility for ground water control systems and for loss or damage resulting from partial or complete failure of protective measures and settlement or resultant damage caused by the ground water control operations. Modify ground water control systems or operations if they cause or threaten to cause damage to new construction, existing site improvements, adjacent property, or adjacent water wells, or affect potentially contaminated areas. Repair damage caused by ground water control systems or resulting from failure of the system to protect property, as required.

- F. Provide adequate number of piezometers installed at the proper locations and depths as required to record meaningful observations of the conditions affecting the excavation, adjacent structures, and water wells. For each phase of the Work, a minimum of three piezometers shall be provided along each side of the ditch excavation area.

1.05 SUBMITTALS

- A. Follow Section 01 30 00 Contractor Submittals.
- B. Ground Water and Surface Water Control Plan shall include:
 - 1. Results of subsurface investigation and description of the extent and characteristics of water bearing layers subject to ground water control.
 - 2. Names of equipment suppliers and installation Subcontractors.
 - 3. Description of proposed ground water control systems indicating arrangement, location; depth and capacities of system components along with installation details and criteria, and operation and maintenance procedures.
 - 4. Description of proposed monitoring and control system indicating depths and locations of piezometers and monitoring wells, monitoring installation details and criteria, type of equipment and instrumentation with pertinent data and characteristics.
 - 5. Description of proposed filters including types, sizes, capacities and manufacturer's application recommendations.
 - 6. Design calculations demonstrating adequacy of proposed systems for intended applications. Define potential area of influence of ground water control operation near contaminated areas.
 - 7. Operating requirements, including piezometric control elevations for dewatering and depressurization.
 - 8. Surface water control and drainage installations.
 - 9. Proposed methods and locations for disposing of removed water.
- C. Submit the following records upon completed installation:
 - 1. Installation and development reports for well points, eductors, and deep wells.
 - 2. Installation reports and baseline readings for piezometers and monitoring wells.
 - 3. Baseline analytical test data of water from monitoring wells.
 - 4. Initial flow rates.
- D. Submit the following records on a weekly basis during water control operations:
 - 1. Records of flow rates and piezometric elevations obtained during monitoring of dewatering and depressurization. Follow Paragraph 3.02, Requirements for Eductor, Well Points, or Deep Wells;
 - 2. Maintenance records for ground water control installations, piezometers, and monitoring wells.

1.06 ENVIRONMENTAL REQUIREMENTS

- A. Follow requirements of agencies having jurisdiction.
- B. Follow California Department of Water Resources and Santa Cruz County regulations for development, drilling, and abandonment of wells used in dewatering system.

- C. Obtain permits from agencies with control over the use of groundwater and matters affecting well installation, water discharge, and use of existing storm drains and natural water sources. Review and permitting process may be lengthy. Take early action on submittal process.
- D. Monitor ground water discharge for turbidity prior to discharging to local drainage ditches. Use settling tanks, stilling basins, filter bags or other measures to reduce the turbidity of discharged water to below 500 NTU.

PART 2 - PRODUCTS

2.01 EQUIPMENT AND MATERIALS

- A. Equipment and materials are at the option of Contractor as necessary to achieve desired results for dewatering. Selected equipment and materials are subject to review of the Engineer through submittals required in Paragraph 1.05, Submittals.
- B. Eductors, well points, or deep wells, where used, must be furnished, installed and operated by an experienced contractor regularly engaged in ground water control system design, installation and operation.
- C. Furnish equipment in good repair and proper operating order.
- D. Keep sufficient standby equipment and materials available to ensure continuous operation, where required.

PART 3 - EXECUTION

3.01 GROUND WATER CONTROL

- A. Perform a subsurface investigation by borings as necessary to identify water bearing layers, piezometric pressures and soil parameters for design and installation of ground water control systems. Present results in the Ground Water and Surface Water Control Plan.
- B. Provide labor and products to lower, control and handle ground water in a manner compatible with construction methods and site conditions. Monitor effectiveness of the installed system and its effect on adjacent property.
- C. Install, operate, and maintain ground water control systems following the Ground Water and Surface Water Control Plan. Notify Engineer in writing of changes made to accommodate field conditions and changes to the Work. Prepare revised drawings and calculations with such notification.
- D. Provide for continuous system operation, including nights, weekends, and holidays. Arrange for appropriate backup if electrical power is primary energy source for dewatering system.
- E. Monitor operations to verify that the system lowers ground water levels at a rate required to maintain a substantially dry excavation resulting in a stable subgrade.

- F. Where hydrostatic pressures in confined water bearing layers exist below excavation, depressurize those zones to eliminate risk of uplift or other instability of excavation or installed works. Define allowable piezometric elevations in the Ground Water and Surface Water Control Plan.
- G. Maintain water level at a minimum of 2 feet below subgrade elevation, or to elevations indicated on Drawings, unless Engineer authorizes a higher level.
- H. During backfilling, dewatering may be reduced to maintain water level a minimum of 5 feet below prevailing level of backfill. However, do not allow that water level to result in uplift pressures in excess of 80 percent of downward pressure produced by weight of structure or backfill in place.
- I. Remove system upon completion of construction or when dewatering and control of surface or groundwater is no longer required.
- J. Replace excavation performed for convenience of dewatering in foundation beds with materials as impermeable as original foundation material or as indicated on Drawings.

3.02 REQUIREMENTS FOR EDUCTOR, WELL POINTS, OR DEEP WELLS

- A. Submit a certification that the ground water control system including eductors, well points, or deep well is in compliance with the criteria of Ground Water and Surface Water Control Plan.
- B. For above-ground piping in ground water control system, include a 12-inch minimum length of clear, transparent piping between every eductor well or well point and discharge header so that discharge from each installation can be visually monitored.
- C. Install sufficient piezometers or monitoring wells to ensure that all trench or shaft excavations in water bearing materials are predrained prior to excavation. Provide separate piezometers for monitoring of dewatering and for monitoring of depressurization.
- D. Install piezometers or monitoring wells not less than one week in advance of beginning the associated excavation.
- E. Replace installations that produce noticeable amounts of sediments after development.
- F. Provide additional ground water control installations, or change the methods, in the event that the installations according to the ground water control plan does not provide satisfactory results based on the performance criteria defined by the plan and by the specification. Submit a revised plan according to Paragraph 1.06B.

3.03 MAINTENANCE AND OBSERVATION

- A. Conduct a minimum of daily maintenance and observation of piezometers or monitoring wells while the ground water control installations are operating in an area. Keep system in good condition.
- B. Replace damaged and destroyed piezometers or monitoring wells with new piezometers or wells within 48 hours.

- C. Cut off piezometers or monitoring wells in excavation areas, where exposed, only as necessary to perform observation as excavation proceeds. Continue to maintain and make observations.
- D. Remove and grout piezometers inside or outside the excavation area when ground water control operations are complete. Remove and grout monitoring wells when directed by the Engineer.

3.04 MONITORING AND RECORDING

- A. Monitor and record average flow rate of operation for each deep well, or for each wellpoint or eductor header used in dewatering system. Monitor and record water level and ground water recovery. Obtain data and record daily until steady conditions are achieved, and twice weekly thereafter.
- B. Observe and record elevation of water level daily as long as dewatering system is in operation, and weekly thereafter until the Work is completed or piezometers or wells are removed, except when Engineer determines that more frequent monitoring and recording are required. Follow Engineer's direction for increased monitoring and recording and take measures as necessary to ensure effective dewatering for intended purpose.

3.05 SURFACE WATER CONTROL

- A. Intercept surface water and divert it away from excavations through use of dikes, ditches, curb walls, pipes, sumps or other approved means. The requirement includes temporary protective works required to protect adjoining properties from surface drainage caused by construction operations.
- B. Divert surface and seepage water into sumps and pump into drainage channels, when approved by agencies having jurisdiction. Provide settling basins when required by such agencies.

END OF SECTION

SECTION 01 60 00

PRODUCTS, MATERIALS, EQUIPMENT AND SUBSTITUTIONS

PART 1 - GENERAL

1.01 DEFINITIONS

- A. The word "Products," as used herein, is defined to include purchased items for incorporation into the WORK, regardless of whether specifically purchased for the project or taken from CONTRACTOR's stock of previously purchased products. The word "Materials," is defined as products which must be substantially cut, shaped, worked, mixed, finished, refined, or otherwise fabricated, processed, installed, or applied to form units of work. The word "Equipment" is defined as products with operational parts, regardless of whether motorized or manually operated, and particularly including products with service connections (wiring, piping, and other like items). Definitions in this paragraph are not intended to negate the meaning of other terms used in the Contract Documents, including "specialties," "systems," "structure," "finishes," "accessories," "furnishings," special construction," and similar terms, which are self-explanatory and have recognized meanings in the construction industry.
- B. Neither "Products" nor "Materials" nor "Equipment" includes machinery and equipment used for preparation, fabrication, conveying and erection of the WORK.

1.02 QUALITY ASSURANCE

- A. Source Limitations: To the greatest extent possible for each unit of work, the CONTRACTOR shall provide products, materials, and equipment of a singular generic kind from a single source.
- B. Compatibility of Options: Where more than one choice is available as options for CONTRACTOR's selection of a product, material, or equipment, the CONTRACTOR shall select an option which is compatible with other products, materials, or equipment. Compatibility is a basic general requirement of product, material and equipment selections.

1.03 PRODUCT DELIVERY AND STORAGE

- A. The CONTRACTOR shall deliver and store the WORK in accordance with manufacturer's written recommendations and by methods and means which will prevent damage, deterioration, and loss including theft. Delivery schedules shall be controlled to minimize long-term storage of products at site and overcrowding of construction spaces. In particular, the CONTRACTOR shall ensure coordination to ensure minimum holding or storage times for flammable, hazardous, easily damaged, or sensitive materials to deterioration, theft, and other sources of loss.
- B. The CONTRACTOR shall provide a certificate of compliance for all materials to be incorporated in the Work.

1.04 TRANSPORTATION AND HANDLING

- A. Products shall be transported by methods to avoid damage and shall be delivered in undamaged condition in manufacturers unopened containers and packaging.
- B. The CONTRACTOR shall provide equipment and personnel to handle products, materials, and equipment, including those provided by OWNER, by methods to prevent soiling and damage.
- C. The CONTRACTOR shall provide additional protection during handling to prevent marring and otherwise damaging products, packaging, and surrounding surfaces.

1.05 STORAGE AND PROTECTION

- A. Products shall be stored in accordance with manufacturer's written instructions and with seals and labels intact and legible. Sensitive products shall be stored in weather-tight climate controlled enclosures and temperature and humidity ranges shall be maintained within tolerances required by manufacturer's recommendations.
- B. For exterior storage of fabricated products including pipe, products shall be placed on sloped supports above ground. Products subject to deterioration, including all ferrous metals, shall be covered with impervious sheet covering and heat and ventilation shall be provided to avoid condensation. PVC pipe shall be stored to avoid prolonged exposure to sunlight.
- C. Loose granular materials shall be stored on solid flat surfaces in a well-drained area and shall be prevented from mixing with foreign matter.
- D. Storage shall be arranged to provide access for inspection. The CONTRACTOR shall periodically inspect to assure products are undamaged and are maintained under required conditions.
- E. Storage shall be arranged in a manner to provide access for maintenance of stored items and for inspection.
- F. The CONTRACTOR shall comply with manufacturer's product storage requirements and recommendations.
- G. The CONTRACTOR shall maintain manufacturer-required environmental conditions continually.
- H. The CONTRACTOR shall ensure that surfaces of products exposed to the elements are not adversely affected and that weathering of finishes does not occur.
- I. For mechanical and electrical equipment, the CONTRACTOR shall provide a copy of the manufacturer's service instructions with each item and the exterior of the package shall contain notice that instructions are included.
- J. Products shall be serviced on a regularly scheduled basis, and a log of services shall be maintained and submitted as a record document prior to acceptance by the OWNER in accordance with the Contract Documents.

1.06 PROPOSED SUBSTITUTES OR "OR-EQUAL" ITEM

- A. Whenever materials or equipment are indicated in the Contract Documents by using the name of a proprietary item or the name of a particular Supplier, the naming of the item is intended to establish the type, function, and quality required. If the name is followed by the words "or equal" indicating that a substitution is permitted, materials or equipment of other suppliers may be accepted if sufficient information is submitted by the CONTRACTOR to allow the ENGINEER to determine that the material or equipment proposed is equivalent or equal to that named, subject to the following requirements:
1. The burden of proof as to the type, function, and quality of any such substitute product, material or equipment shall be upon the CONTRACTOR.
 2. The ENGINEER will be the sole judge as to the type, function, and quality of any such substitute and the ENGINEER'S decision shall be final.
 3. The ENGINEER may require the CONTRACTOR to furnish at the CONTRACTOR'S expense additional data about the proposed substitute.
 4. The OWNER may require the CONTRACTOR to furnish at the CONTRACTOR'S expense a special performance guarantee or other surety with respect to any substitute.
 5. Acceptance by the ENGINEER of a substitute item proposed by the CONTRACTOR shall not relieve the CONTRACTOR of the responsibility for full compliance with the Contract Documents and for adequacy of the substitute.
 6. The CONTRACTOR shall be responsible for resultant changes including design and construction changes and all additional costs resulting from the changes which the accepted substitution requires in the CONTRACTOR'S WORK, the WORK of its subcontractors and of other contractors, and shall effect such changes without cost to the OWNER.
- B. The procedure for review by the ENGINEER will include the following:
1. If the CONTRACTOR wishes to provide a substitute item, the CONTRACTOR shall make written application to the ENGINEER on a "Substitution Request Form."
 2. Unless otherwise provided by law or authorized in writing by the ENGINEER, the "Substitution Request Form(s)" shall be submitted within the 14 days after award of the Contract.
 3. Wherever a proposed substitute item has not been requested as specified herein, or wherever the submission of a proposed substitute material or equipment has been judged to be unacceptable by the ENGINEER, the CONTRACTOR shall provide the material or equipment indicated in the Contract Documents.
 4. The CONTRACTOR shall certify that the proposed substitute will perform adequately the functions and achieve the results called for by the general design, and be similar and of equal substance to that indicated, and be suited to the same use as that specified.
 5. The ENGINEER will evaluate each proposed substitute within a reasonable period of time.
 6. As applicable, no shop drawing submittals shall be made for a substitute item nor shall any substitute item be ordered, installed, or utilized without the ENGINEER'S prior written acceptance of the CONTRACTOR'S "Substitution Request Form."
 7. The ENGINEER will record the time required by the ENGINEER in evaluating substitutions proposed by the CONTRACTOR and in making changes by the CONTRACTOR in the Contract Documents occasioned thereby. Whether or not the ENGINEER accepts a proposed substitute, the CONTRACTOR shall reimburse the OWNER for the charges of the ENGINEER for evaluating each proposed substitute.

- C. The CONTRACTOR's "Substitution Request Forms" shall contain the following statements and information which shall be considered by the ENGINEER in evaluating the proposed substitution:
1. The evaluation and acceptance of the proposed substitute will not prejudice the CONTRACTOR's achievement of substantial completion on time.
 2. Whether or not acceptance of the substitute for use in the WORK will require a change in any of the Contract Documents to adopt the design to the proposed substitute.
 3. whether or not incorporation or use of the substitute in connection with the WORK is subject to payment of any license fee or royalty.
 4. All variations of the proposed substitute from the items originally specified will be identified.
 5. Available maintenance, repair, and replacement service will be indicated. The manufacturer shall have a local service agency (within 50 miles of the site) which maintains properly trained personnel and adequate spare parts and is able to respond and complete repairs within 24 hours.
 6. Itemized estimate of all costs that will result directly or indirectly from acceptance of such substitute, including cost of redesign and claims of other contractors affected by the resulting change.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION

SECTION 01 70 00

PROJECT CLOSEOUT

PART 1 - GENERAL

1.01 FINAL CLEANUP

- A. The Contractor shall promptly remove from the vicinity of the completed work, all rubbish, unused materials, concrete forms, construction equipment, and temporary structures and facilities used during construction. Final acceptance of the Work by the Owner will be withheld until the Contractor has satisfactorily complied with the foregoing requirements for final cleanup of the project site.

1.02 CLOSEOUT TIMETABLE

- A. The Contractor shall establish a date for acceptance of work. The date shall be established not less than one week prior to beginning any of the foregoing items, to allow the Owner, the Engineer, and their authorized representatives sufficient time to schedule attendance at such activities.

1.03 FINAL SUBMITTALS

- A. The Contractor, prior to requesting final payment, shall obtain and submit the following items to the Engineer for transmittal to the Owner:
 - 1. Written guarantees, where required.
 - 2. Operating manuals and instructions.
 - 3. Maintenance stock items; spare parts; special tools.
 - 4. Completed record drawings.
 - 5. Geospatially referenced locations of all installed facilities and equipment (i.e., GPS data)
 - 6. Certificates of inspection and acceptance by local governing agencies having jurisdiction.
 - 7. Releases from all parties who are entitled to claims against the subject project, property, or improvement pursuant to the provisions of law.

1.04 MAINTENANCE AND GUARANTEE

- A. The Contractor shall comply with the warranty requirements contained in the Construction Contract.
- B. Replacement of earth fill or backfill, where it has settled below the required finish elevations, shall be considered as a part of such required repair work, and any repair or resurfacing constructed by the Contractor which becomes necessary by reason of such settlement shall likewise be considered as a part of such required repair work unless the Contractor shall have obtained a statement in writing from the affected private owner or public agency releasing the Owner from further responsibility in connection with such repair or resurfacing.

- C. The Contractor shall make all repairs and replacements promptly upon receipt of written order from the Owner. If the Contractor fails to make such repairs or replacements promptly, the Owner reserves the right to do the Work and the Contractor and his surety shall be liable to the Owner for the cost thereof.

PART 2 - PRODUCTS (Not Used)

PART 3 - EXECUTION (Not Used)

END OF SECTION

SECTION 01 78 00

OPERATIONS AND MAINTENANCE DATA

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes: Preparation and submittal of Operation and Maintenance Manuals.

1.02 SUBMITTALS

- A. Submit Operation and Maintenance Manuals as part of the shop drawing approval process.
- B. Make additions and revisions to the Manuals in accordance with Engineer's review comments.
- C. Submit four (4) complete Manuals for each piece of equipment or system after shop drawing approval.

1.03 OPERATION AND MAINTENANCE MANUALS

- A. Preparation:
 - 1. Provide Operations and Maintenance Manuals in 3-ring binders with rigid covers. Utilize tab sheets to organize information.
- B. Contents of Operation and Maintenance Manuals:
 - 1. Cover Page: Equipment name, equipment tag number, project name, Owner's name, appropriate date.
 - 2. Table of Contents: General description of information provided within each tab section.
 - 3. Lubrication Information: Required lubricants and lubrication schedules.
 - 4. Control Diagrams:
 - a. Internal and connection wiring, including logic diagrams, wiring diagrams for control panels, ladder logic for computer based systems, and connections between existing systems and new additions, and adjustments such as calibrations and set points for relays, and control or alarm contact settings.
 - 5. Start-up Procedures: Recommendations for installation, adjustment, calibration, and troubleshooting.
 - 6. Operating Procedures:
 - a. Step-by-step procedures for starting, operating, and stopping equipment under specified modes of operation.
 - b. Include safety precautions and emergency operating shutdown instructions.
 - 7. Preventative Maintenance Procedures: Recommended steps and schedules for maintaining equipment.
 - 8. Overhaul Instructions: Directions for disassembly, inspection, repair and reassembly of the equipment; safety precautions; and recommended tolerances, critical bolt torques, and special tools that are required.

9. Parts List: Generic title and identification number of each component part of equipment; include bearing manufacturer, model and ball or roller pass frequencies for every bearing.
10. Spare Parts List: Recommended number of parts to be stored at the site and special storage precautions.
11. Drawings: Exploded view or plan and section views with detailed callouts.
12. Provide electrical and instrumentation schematic record drawings.
13. Provide approved shop and fabrication drawings.
14. Source (Factory) Quality Control Test Results: Provide copies of factory test reports as specified in the applicable equipment section.
15. Field Quality Control Test Results: After field testing is completed, insert field test reports as specified in the applicable equipment section.
16. Equipment Summary Form: Completed form in the format attached at the end of this Section. Insert Equipment Summary Form after the tab sheet of each equipment section. The manufacturer's standard form will not be acceptable.
17. Manufacturer's Warranty Documents: Provide copies of standard warranty documents with the initial O&M Manual submittal. Submit equipment specific warranties (listing serial numbers and expiration dates) at project close-out.

PART 2 - PRODUCTS (NOT USED)

PART 3 - EXECUTION (Not Used)

END OF SECTION

EQUIPMENT SUMMARY FORM

1. EQUIPMENT ITEM _____
2. MANUFACTURER _____
3. EQUIPMENT IDENTIFICATION NUMBER(S) _____

4. LOCATION OF EQUIPMENT _____
5. NAMEPLATE DATA -
 - Horsepower _____
 - Amperage _____
 - Voltage _____
 - Service Factor (S.F.) _____
 - Speed _____
 - Enclosure Type _____
 - Capacity _____
 - Other _____
6. MANUFACTURER'S LOCAL REPRESENTATIVE
 - Name _____
 - Address _____
 - Telephone Number _____
7. MAINTENANCE REQUIREMENTS _____

8. LUBRICANT LIST _____

9. SPARE PARTS (recommendations) _____

10. COMMENTS _____

SECTION 02 01 00

EXISTING FACILITIES

PART 1 - GENERAL

1.01 DESCRIPTION

- A. This section includes requirements for connection to and abandonment of existing facilities.

1.02 RELATED WORK SPECIFIED ELSEWHERE

- A. All related work specified elsewhere, or in other codes or standards, will be as last revised, unless a specific date of issuance is called out in opposition to later revision date(s).
- B. Other sections of the technical specifications, not referenced below, shall also apply to the extent required for proper performance of this work.
 - 1. Abandonment of Pipelines 02 22 20
 - 2. Trenching, Backfilling, and Compacting: 31 23 00
 - 3. Manual Valves: 33 12 16

1.03 SUBMITTALS

- A. Submit a connection plan detailing the schedule and methods for transitioning from existing to new facilities.

1.04 CONDITION OF EXISTING FACILITIES

- A. The Owner does not warranty the condition, size, material, and location of existing facilities.

1.05 LOCATION

- A. The Contractor shall be responsible for potholing and verifying in advance the location of all existing pipelines as shown on the plans. Discrepancies shall be reported to the Engineer, prior to the fabrication of, or purchase of material affected by the discrepancy.

1.06 PROTECTION OF EXISTING UTILITIES AND FACILITIES

- A. The Contractor shall be responsible for the care and protection of all existing sewer pipe, water pipe, gas mains, culverts, power or communications lines, sidewalks, curbs, pavement, or other facilities and structures that may be encountered in or near the area of the work.
- B. It shall be the duty of the Contractor to notify Underground Service Alert and each agency of jurisdiction and make arrangements for locating their facilities prior to beginning construction.

- C. In the event of damage to any existing facilities during the progress of the work, the Contractor shall pay for the cost of all repairs and protection to said facilities. The Contractor's work may be stopped until repair operations are complete.

1.07 PROTECTION OF LANDSCAPING

- A. The Contractor shall be responsible for the protection of all the trees, shrubs, irrigation systems, fences, and other landscape items adjacent to or within the work area, unless they are directed to do otherwise on the plans.
- B. In the event of damage to landscape items, the Contractor shall replace the damaged items to the satisfaction of the Engineer and the Owner, or pay damages to the property Owner as directed by the Owner.
- C. When the proposed pipeline is to be within planted or other improved areas in public or private easements, the Contractor shall restore such areas to the original condition after completion of the work. This restoration shall include grading, a placement of 5 inches of good topsoil, re-sodding, and replacement of all landscape items indicated.
- D. If the Contractor does not proceed with the restoration after completion of the work or does not complete the restoration in a satisfactory manner, the Engineer reserves the right to have the work done and to charge the Contractor for the actual cost of the restoration including all labor, material, and overhead required for restoration.

1.08 PERMITS

- A. All work shall conform to the specifications and requirements of the State of California Department of Transportation, the County, the city having jurisdiction, or the other affected agencies involved. The Contractor shall keep a copy of all the required permits in the job site and comply with all the terms and conditions of said permits. Permits shall also include any related to the abandonment of an existing water or sewer pipe.

PART 2 - MATERIALS

All materials used in making the connection or removing the facility from service shall conform to the applicable sections of these specifications.

2.01 GROUT

- A. Grout used for plugging abandoned facilities shall be Portland cement grout per Section 03 30 00

2.02 CONCRETE

- A. Concrete used for the replacement of damaged or removed facilities shall be in accordance with Section 03 30 00 and shall match the mix design of the existing facility and per the requirement of the jurisdictional agency.

PART 3 - EXECUTION

3.01 CONNECTION TO EXISTING FACILITIES

- A. All connections shall be made by the Contractor unless shown otherwise on the plans or specified herein.
- B. If multiple connections to the sewer system are anticipated, the Contractor shall submit a connection plan developed with the intent of minimizing the down time to customers.
- C. When customers are affected, the Contractor shall notify the Owner a minimum of seven working days before the time of any proposed shutdown of existing mains or services. The Owner's inspector may postpone or reschedule any shutdown operation if for any reason he feels that the Contractor is improperly prepared with competent personnel, equipment, or materials to proceed with the connection work.
- D. When no customers are affected, the Contractor shall notify the Owner a minimum of two working days before the time of any proposed shutdown of existing mains or services. The Owner's inspector may postpone or reschedule any shutdown operation if for any reason he feels that the Contractor is improperly prepared with competent personnel, equipment, or materials to proceed with the connection work.
- E. Connections shall be made only in the presence of the Owner or Owner's inspector, and no connection work shall proceed until the Engineer has given notice to proceed. If progress is inadequate during the connection operations to complete the connection in the time specified, the Engineer shall order necessary corrective measures. All costs for corrective measures shall be paid by the Contractor.
- F. The Contractor shall furnish all pipe and materials including furnishing all labor and equipment necessary to make the connections, all required excavation, backfill, pavement replacement, lights, and barricades, and may be required to include a water truck, high line hose, and fittings as part of this equipment for making the connections. In addition, the Contractor shall assist the Owner in alleviating any hardship incurred during the shutdown for connections. Standby equipment or materials may be required by the Engineer.
- G. The Contractor shall de-water existing mains, as required, in the presence of the Owner's inspector.
- H. New pipelines shall not be connected to existing facilities until the new pipelines have been successfully tested and accepted by the Owner.

3.02 REMOVAL FROM SERVICE OF EXISTING MAINS AND APPURTENANCES

- A. Existing mains and appurtenances shall be removed from service at the locations shown on the plans or as directed by the Engineer.
- B. Pipelines abandoned in place shall be drained and then sealed at each end with grout plugs. Grout shall extend a minimum of 12-inches into the pipeline and fully encase the end of the pipe.

- C. Existing pipe and appurtenances removed from the ground will require backfill and repair of surface in accordance with Section 31 23 00.
- D. Removed pipe and appurtenances shall be temporarily stockpiled on the job in a location that will not disrupt traffic or be a safety hazard, disposed of in a proper manner (as determined by the Engineer). The Contractor shall remove and dispose of all removed pipe at his own expense to a landfill permitted to accept such materials.
- E. Before excavating for installing mains that are to replace existing pipes and/or services, the Contractor shall make proper provisions for the maintenance and continuation of service as directed by the Engineer unless otherwise specified.
- F. If the meter box is to be removed from an abandoned water service, the service line is to be removed and the corporation stop closed and capped. If there is no corporation stop on the service, the adapter is to be removed and a brass plug is to be installed in the service saddle.
- G. Asbestos Cement Pipe (ACP) shall be cut, removed and disposed of in a proper manner. The Contractor shall be responsible for the proper manifesting of any and all ACP at an authorized disposal site.

3.03 CUTTING AND RESTORING STREET SURFACING.

- A. In cutting or breaking up street surfacing, the Contractor shall not use equipment that will damage adjacent pavement.
- B. All asphalt and/or Portland cement concrete surfaces shall be scored with sawing equipment of a type meeting the approval of the Owner; providing however, that any cement concrete base under an asphaltic mix surface will not be required to be scored by sawing. Existing paving surfaces shall be sawcut back beyond the edges of the trenches to form neat square cuts before repaving is commenced.
- C. Pavement, sidewalks, curbs, or gutters removed or destroyed in connection with performance of the work shall be saw cut to the nearest score marks, if any, and shall be replaced with pavement sidewalks, curbs, or gutters of the same kind, or better by the Contractor in accordance with the latest specifications, rules, and regulations and subject to the inspection of the agency having jurisdiction over the street or highway.
- D. Aggregate base shall be placed beneath the restored pavement to the thickness required by the agency having jurisdiction.

END OF SECTION

SECTION 03 10 00

CONCRETE FORMS AND ACCESSORIES

PART 1 - GENERAL

1.01 DESCRIPTION

- A. Section Includes: Formwork for concrete, with shoring, bracing and anchorage.
- B. Related Sections:
 - 1. Section 03 20 00 - Concrete Reinforcement
 - 2. Section 03 30 00 - Cast-in-Place Concrete

1.02 REFERENCES

- A. American Concrete Institute (ACI):
 - 1. ACI 117 - Standard Specifications for Tolerances for Concrete Construction and Materials.
 - 2. ACI 301 - Specifications for Structural Concrete for Buildings.
 - 3. ACI 318 - Building Code Requirements for Structural Concrete and Commentary.
 - 4. ACI 347 - Guide to Formwork for Concrete.
- 5. ASTM International (ASTM):
 - 6. ASTM C31 - Standard Practice for Making and Curing Concrete Test Specimens in the Field.
 - 7. ASTM C39 - Standard Test Method for Compressive Strength of Cylindrical Concrete Specimens.
 - 8. ASTM D994 - Standard Specification for Preformed Expansion Joint Filler for Concrete (Bituminous Type).
 - 9. ASTM D1751 - Standard Specification for Preformed Expansion Joint Filler for Concrete Paving and Structural Construction (Nonextruding and Resilient Bituminous Types).

1.03 SUBMITTALS

- A. Section 01 30 00 – Contractor Submittals, for submittal procedures
- B. Product Data: Provide data on formwork release agent or form liner proposed for use with each formed surface.
- C. Formwork Facing Materials: Data on form-facing materials proposed for smooth-form finish if different from that specified in Article 2.02.
- D. Construction and Contraction Joints: Location of construction and contraction joints proposed if different from those indicated in the Contract Documents.

- E. Testing for Formwork Removal: Data on method for determining strength of concrete for removal of formwork when a method other than field-cured cylinders (ASTM C31 and ASTM C39) is proposed.
- F. Formwork Removal Plans: Detail plans for formwork removal operations when removal of forms at concrete strengths lower than that specified in Article 3.08 is proposed.

1.04 QUALITY ASSURANCE

- A. Codes and Standards: Comply with the provisions of the following codes, specifications, and standards, except where more stringent requirements are shown or specified.
 - 1. California Building Code, current governing edition.
 - 2. ACI 318.
 - 3. ACI 347.

PART 2 - PRODUCTS

2.01 FORMWORK - GENERAL

- A. Maximum deflection of facing materials reflected on concrete surfaces exposed to public view shall be 1/240 of the span between structural members of the formwork.
- B. Formed Construction and Contraction Joints
 - 1. Locate and form construction joints that least impair strength of the structure and meet the requirements of Section 033000 - Cast-in-Place Concrete, Article 3.05.
 - 2. Unless otherwise specified or permitted, locate and detail formed construction joints to the following requirements:
 - a. Locate joints in walls and columns at the tops of footings or slabs; and
 - b. Make joints perpendicular to the main reinforcement.
 - 3. Provide keyways where indicated on Contract Documents. Unless otherwise specified, longitudinal keyways indicated on the Contract Documents, shall be a minimum of 1-1/2 in. deep in joints in walls and between walls and slabs or footings.
 - 4. Provide construction and contraction joints where indicated on the Contract Documents. Submit for acceptance the location of construction and contraction joints differing from those indicated on the Contract Documents.

2.02 FORM MATERIALS

- A. Form-facing materials: Materials for form faces in contact with concrete shall meet the requirements of "Concrete Finishing" Section 033000 - Cast-in-Place Concrete and the following requirements unless otherwise specified in Contract Documents.
 - 1. For smooth-form finish, use plywood, tempered concrete-form-grade hardboard, metal, plastic, paper, or other acceptable materials capable of producing the desired finish for form-facing materials. Form-facing materials shall produce a smooth, uniform texture on the concrete. Do not use form-facing materials with raised grain, torn surfaces, worn edges, dents, or other defects that will impair the texture of concrete surfaces. Facing materials shall be supported with studs or other backing

capable of maintaining deflections within the tolerances specified in Article 2.01 herein.

2.03 FORMWORK ACCESSORIES

- A. Use commercially manufactured accessories for formwork accessories that are partially or wholly embedded in concrete, including ties and hangers. Do not use nonfabricated wire form ties.

2.04 FORMWORK RELEASE AGENT

- A. Use commercially manufactured formwork release agents that prevent formwork absorption of moisture, prevent bond with concrete, and do not stain the concrete surfaces.

2.05 EXPANSION JOINT FILLER

- A. Pre-molded expansion joint filler shall conform to ASTM D994 or ASTM D1751.

2.06 FABRICATION AND MANUFACTURE

- A. Formwork shall be tight to prevent loss of mortar from concrete.
- B. Place 3/4-inch chamfer strips in the corners of formwork to produce beveled edges on permanently exposed surfaces unless otherwise specified. Do not bevel reentrant corners or edges of formed joints of concrete unless specified in the Contract Documents.
- C. Inspect formwork and remove deleterious material immediately before concrete is placed. Provide temporary openings where needed at the base of column and wall formwork to facilitate cleaning and inspection.
- D. Fabricate form ties so ends or end fasteners can be removed with minimum spalling at the faces of concrete.

PART 3 - EXECUTION

3.01 EARTH FORMS

- A. Where sides of excavations have been cut neat and accurate to size for pouring of concrete directly against the excavation, forms for footings will not be required. Remove loose soil prior to placing concrete.

3.02 CONSTRUCTION AND ERECTION OF FORMWORK

- A. At construction joints, lap contact surface of the form sheathing for flush surfaces exposed to view over the hardened concrete in the previous placement. Ensure formwork is sealed against hardened concrete to prevent offsets or loss of mortar at construction joints and to maintain a true surface.

- B. Provide positive means of adjustment (such as wedges or jacks) of shores and struts. Do not make adjustments in the formwork after concrete has reached its time of initial setting. Brace formwork securely against lateral deflection and lateral instability.
- C. Fasten form wedges in place after final adjustment of forms and before concrete placement.
- D. Anchor formwork to shores, supporting surfaces, or members to prevent upward or lateral movement of the formwork system during concrete placement. Form supports shall be placed on adequate foundations and have sufficient strength and bracing to prevent settlement or distortion from the weight of the concrete or other cause. Support shall rest on double wedged shim, or other approved means, so that the forms will be maintained at the proper grade.
- E. Provide runways for moving equipment and support runways directly on the formwork or structural member without resting on the reinforcing steel.
- F. All formed joints on concrete surfaces to be exposed shall be taped and shall align so joints will not be apparent on the concrete surfaces.
- G. Any movement or bellying of forms during construction shall be considered just cause for their removal and, in addition, the concrete work so affected.
- H. Bolts, rods, or other approved devices shall be used for internal form ties and shall be of sufficient quantities to prevent spreading of the forms. The ties shall be placed at least 1 inch away from the finished surface of the concrete. Bolts and rods that are to be completely withdrawn shall be coated with grease.
- I. Boards or other form materials that have been damaged or checked or warped prior to placing of concrete shall be removed from the forms and replaced with approved materials or otherwise corrected to the satisfaction of the engineer.
- J. Assign a sufficient number of men to keep watch on and maintain the forms during placing of concrete. Satisfactorily remedy any displacement or looseness of forms or reinforcement before placing of concrete. No form shall be moved or altered except as may be specifically directed.

3.03 APPLICATION - FORM RELEASE AGENT

- A. Cover surfaces of formwork with an acceptable material that will prevent bond with the concrete. A field-applied formwork release agent or a factory-applied liner may be used. If a formwork release agent is used, apply to the surfaces of the formwork in accordance with the manufacturer's recommendations before placing reinforcing steel. Do not allow formwork release agent to puddle in the forms. Do not allow formwork release agent to contact reinforcing steel or hardened concrete against which fresh concrete is to be placed.

3.04 INSERTS, EMBEDDED PARTS, AND OPENINGS

- A. Position and support expansion joint materials, waterstops, and other embedded items to prevent displacement. Fill voids in sleeves, inserts, and anchor slots temporarily with readily removable material to prevent entry of concrete into voids.
- B. Place sleeves, inserts, anchors, and embedded items required for adjoining work or for support of adjoining work before concrete placement.

3.05 FORM CLEANING

- A. Clean surfaces of formwork and embedded materials of mortar, grout, and foreign materials before concrete is placed.

3.06 FORMWORK TOLERANCES

- A. Unless otherwise specified in the Contract Documents, construct formwork so concrete surfaces conform to the tolerance limits of ACI 117. The class of surface shall conform to Article 2.02 herein.
- B. To maintain specified tolerances, camber formwork to compensate for anticipated deflections in formwork during concrete placement. Set formwork and intermediate screed strips for slabs accurately to produce designated elevations and contours of the finished surface before removal of formwork. Ensure that edge forms and screed strips are strong enough to support vibrating screeds or roller pipe screeds when the finish specified requires the use of such equipment.
- C. When formwork is cambered, set screeds to the same camber to maintain specified concrete thickness.

3.07 FIELD QUALITY CONTROL

- A. The Contractor shall verify accuracy of items, furnished under other sections of these specifications and installed under this section.

3.08 FORM REMOVAL

- A. Remove top forms on sloping surfaces of concrete as soon as removal will not allow concrete to sag. Perform needed repairs or treatment required at once and follow immediately with specified curing.
- B. Do not damage concrete during removal of formwork for columns, walls, slabs, sides of beams, and other parts not supporting the weight of the concrete. Perform needed repair and treatment required on vertical surfaces at once and follow immediately with specified curing.
- C. Vertical forms shall remain on columns, walls, pilasters for at least seven 7 days after the last concrete and until concrete has attained 3000 psi minimum per Article 3.08D and the Engineer responsible for design of the formwork has approved removal.
- D. Contractor shall request to have field cured compression test specimen taken where it is planned to remove formwork and shoring sooner than indicated above and submit detailed plans for review and acceptance. Mold cylinders in accordance with ASTM

C31, and cure them under the same conditions for moisture and temperature as used for the concrete they represent. Test cylinders in accordance with ASTM C39.

- E. In removing plywood forms, no metal pinch bars shall be used and special care to be taken in stripping. Start at top edge or vertical corner where it is possible to insert wooden wedges. Wedging shall be done gradually and shall be accompanied by light tapping of the plywood panels to crack them loose. Do not remove forms with a single jerk after it has been started at one end.
- F. Nothing herein shall be construed as relieving the Contractor of any responsibility of the safety of the structure.

END OF SECTION

SECTION 03 20 00

CONCRETE REINFORCEMENT

PART 1 - GENERAL

1.01 SUMMARY

A. Section Includes:

1. Reinforcing steel for concrete and masonry.
2. Supports and accessories for steel reinforcement.

B. Related Sections:

1. Section 03 10 00 - Concrete Forms and Accessories
2. Section 03 30 00 - Cast-in-Place Concrete

1.02 REFERENCES

A. American Concrete Institute (ACI):

1. ACI 117 - Standard Specifications for Tolerances for Concrete Construction and Materials.
2. ACI 301 - Specifications for Structural Concrete for Buildings.
3. ACI 318 - Building Code Requirements for Structural Concrete and Commentary.
4. ACI SP-66 - ACI Detailing Manual.

B. ASTM International (ASTM):

1. ASTM A82 - Standard Specification for Steel Wire, Plain, for Concrete Reinforcement.
2. ASTM A123 - Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products
3. ASTM A184 - Standard Specification for Welded Deformed Steel Bar Mats for Concrete Reinforcement.
4. ASTM A185 - Standard Specification for Steel Welded Wire Reinforcement, Plain, for Concrete.
5. ASTM A615 - Standard Specification for Deformed and Plain Billet-Steel Bars for Concrete Reinforcement.
6. ASTM A 641 - Standard Specification for Zinc-Coated (Galvanized) Carbon Steel Wire.
7. ASTM A706 - Standard Specification for Low-Alloy Steel Deformed and Plain Bars for Concrete Reinforcement.
8. ASTM A767 - Standard Specification for Zinc-Coated (Galvanized) Steel Bars for Concrete Reinforcement.
9. ASTM A775 - Standard Specification for Epoxy-Coated Steel Reinforcing Bars.
10. ASTM A780 - Standard Practice for Repair of Damaged and Uncoated Areas of Hot-Dip Galvanized Coatings.

11. ASTM A884 - Standard Specification for Epoxy-Coated Steel Wire and Welded Wire Reinforcement.
 12. ASTM A934 - Standard Specification for Epoxy-Coated Prefabricated Steel Reinforcing Bars.
 13. ASTM D3963 - Standard Specification for Fabrication and Jobsite Handling of Epoxy Coated Reinforcing Steel Bars.
 14. ASTM E329 - Standard Specification for Agencies Engaged in Construction Inspection and/or Testing.
- C. American Welding Society (AWS):
1. AWS D1.4 - Structural Welding Code - Reinforcing Steel.
- D. Concrete Reinforcing Steel Institute (CRSI):
1. CRSI (DA4) - Manual of Standard Practice.

1.03 SUBMITTALS

- A. See Section 01 30 00 – Contractor Submittals, for submittal procedures.
- B. Shop Drawings (Placing drawings)
1. Comply with requirements of ACI SP-66. Shop drawings shall also show details for congested areas and connections. Shop drawings used in field must be reviewed copies.
- C. Product Data
1. Manufacturer's catalog sheets including instructions for use and description of application and ICC/IAPMO evaluation report shall be provided on each of the following items intended for use on project:
 - a. Mechanical anchorage devices for splices.
- D. Mill Certificates
1. The Contractor shall provide Mill Certificates for each size of bar for each heat to be used on project and certify that reinforcing steel supplied for this project meet or exceed specified requirements.
 2. Mill Certificates shall include name of mill, date of rolling, date of shipping to fabricator and shall be signed by fabricator certifying that each material complies with or exceeds the specified requirements. A Mill Certificate shall be furnished with each lot of material delivered to the project and the lot shall be clearly identified in the Certificate.
 3. When Mill Certificates cannot be provided, the Contractor shall hire a professional testing laboratory to verify compliance and provide laboratory test reports. The Contractor shall pay for the cost of testing.
- E. Laboratory Test Reports
1. Laboratory test reports shall be signed by a principal of the testing agency who is a registered Civil Engineer in the State of California.

2. When required by other portions of these specifications, laboratory test reports shall be submitted for each size of bar tested for each heat to show compliance with appropriate ASTM Standards and these specifications.
- F. Welder's Certificates and WPS: Submit description of reinforcement weld locations, welding procedures, and welder certification when welding is permitted.

1.04 QUALITY ASSURANCE

- A. Perform work of this section in accordance with the current governing edition of CBC, ACI 301, ACI SP-66, ACI 318, and AWS D1.4 except as modified by the contract documents.
- B. Sampling and Testing:
 1. General
 - a. If the Owner's agent, through oversight or otherwise, has accepted material or work which is defective or contrary to specifications, this material or work, regardless of state of completion, may be rejected.
 - b. Testing agencies shall meet the requirements of ASTM E329. Testing agencies shall be accepted by the Architect/Engineer before performing any work.
 2. Testing responsibilities of Contractor:
 - a. Submit data on qualifications of proposed testing agency for acceptance. Use of testing services will not relieve the Contractor of the responsibility to furnish materials and construction in compliance with the Contract Documents.
 - b. Cooperate with and notify owner's agent at least 24 hours in advance of inspections required and shall provide samples, test pieces, and facilities for inspection at no cost to the owner.
 - c. Identify each lot of fabricated reinforcing steel to be shipped to the site by assigning an individual lot number that identifies steel by heat number and shall be tagged in such a manner that each such lot can be accurately identified at the job site.
 - d. Remove all unidentified reinforcing steel, anchorage assemblies and bar couplers received at the site.

1.05 STORAGE OF MATERIALS

- A. Store reinforcement during fabrication and at site to avoid excessive rusting or coating with grease, oil, soil, or other objectionable materials. Epoxy-coated and galvanized reinforcement shall be handled and stored by methods that will not damage the coating. Bundles shall not be dropped or dragged. Reinforcing steel shall be transported and stored in a manner that will not damage any applied coating. Since the epoxy coating is flammable, the coated reinforcement shall not be exposed to any fire or flame.

1.06 SEQUENCING AND SCHEDULING

- A. Coordinate work with all trades so as not to interfere with the work of other trades. Bring interferences between trades to Architect's/Engineer's attention and resolve before any concrete is placed.

PART 2 - PRODUCTS

2.01 REINFORCING BARS

A. Reinforcing Steel:

1. Bars for reinforcement shall conform to the requirements of ASTM A706.
2. ASTM A615, Grade 60 bars may be substituted if the actual yield strength based on mill tests does not exceed the specified yield strength by more than 18,000 psi (retest shall not exceed this value by more than an additional 3,000 psi) and the ratio of the actual ultimate tensile stress to the actual tensile yield strength is not less than 1.25.
3. Uncoated steel unless noted otherwise.

2.02 WELDING ELECTRODES

- #### **A. Welding electrodes shall be per Table 5-1 of AWS D1.4.**

2.03 MECHANICAL COUPLING DEVICES

- #### **A. Mechanical coupling devices shall develop 125 percent of the minimum yield strength of the bars spliced.**

2.04 REINFORCEMENT ACCESSORIES

- #### **A. Chairs, Bolsters, Bar Supports, Spacers: Sized and shaped for adequate support of reinforcement during concrete placement. Reinforcement supports shall conform to the requirements of ACI 301.**

2.05 OTHER MATERIALS

- #### **A. All other materials, not specifically described by these specifications but required for complete and proper placement of reinforcement shall be new, first quality of their respective kinds, and subject to the approval of the Architect/Engineer.**

2.06 FABRICATION

- #### **A. Welding of reinforcement is permitted only with the specific approval of Engineer. Perform welding in accordance with AWS D1.4. Do not weld crossing bars (tack welds) for assembly of reinforcement, supports, or embedded items.**

PART 3 - EXECUTION

3.01 EXISTING CONDITIONS

- #### **A. Prior to all work of the section, carefully inspect the installed work of other trades and verify that all work is sufficiently complete to permit the start of work under this section and that the completed work of this section will be in complete accordance with the original design and the reviewed shop drawings. In the event of discrepancy, immediately notify the Architect/Engineer in writing.**

- B. In the event conduits, pipes, inserts, sleeves, or any other items interfere with placing the reinforcement as indicated on the drawings or approved shop drawings, or as otherwise required, immediately notify the Architect/Engineer and obtain approval on procedure before placement of reinforcement is started.

3.02 BENDING

- A. Bends for reinforcing steel shall be made in accordance with ACI 301 and ACI 318. Bend bar sizes No. 3 through 5 cold only one time, provided reinforcing bar temperature is above 32 degree F. Do not field bend reinforcing steel in a manner that will injure material, cause the bars to be bent on too tight a radius, or that is not indicated as allowed on drawings or permitted by Engineer. Do not straighten bent or kinked bars for use on project without permission of Engineer. Replace bars with kinks or bends not shown on the drawings.

3.03 PLACING

- A. All reinforcement shall be placed in strict conformance with the requirements of the Contract Drawings, both as to location, position and spacing of members. It shall be supported and secured against displacement by the use of adequate and proper wire supporting and spacing devices, tie wires, etc. so that it will remain in its proper position in the finished structure. Reinforcement may not be wet set in concrete pours.
- B. Tolerances: Do not exceed the placing tolerances specified in ACI 117 before concrete is placed. Placing tolerances shall not reduce cover requirements except as specified in ACI 117.
- C. Minimum concrete cover for reinforcement shall be as indicated in the Contract Drawings. Where less than 3 inches cover is noted and concrete will be placed against soil, increase the section thickness to attain 3 inches cover.
- D. Preserve clear space between parallel bars of not less than 1 1/2 times the nominal diameter of round bars and in no case let the clear distance be less than 1 1/2 inches nor less than 1-1/3 times the maximum size of aggregate for concrete. Lap splices shall be contact lap splices in accordance with ACI 318 unless noted otherwise on the Contract Drawings. Bars shall be wired together at laps. Wherever possible, stagger splices in adjacent bars. Butt splices shall be accomplished by mechanical anchorage devices. Stagger these devices 2', unless noted otherwise on the Contract Documents.
- E. Bars shall not be cut by gas torch.

3.04 CLEANING REINFORCEMENT

- A. Take all means necessary to ensure that steel reinforcement, at the time concrete is placed around it, is completely free from rust, soil, loose mill scale, oil, paint and all coatings which will destroy or reduce the bond between steel and concrete.

END OF SECTION

SECTION 03 30 00

CAST-IN-PLACE CONCRETE

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes:
 - 1. Cast-in-place structural concrete.
 - 2. Grouting under base plates.
- B. Related Sections
 - 1. Section 03 10 00 - Concrete Forms and Accessories
 - 2. Section 03 20 00 - Concrete Reinforcement
 - 3. Section 31 23 23 - Structural Excavation

1.02 REFERENCES

- A. American Concrete Institute (ACI):
 - 1. ACI 117 - Standard Specifications for Tolerances for Concrete Construction and Materials.
 - 2. ACI 211.1 - Standard Practice for Selecting Proportions for Normal, Heavyweight, and Mass Concrete.
 - 3. ACI 301 - Specifications for Structural Concrete for Buildings.
 - 4. ACI 302.1R - Guide for Concrete Floor and Slab Construction.
 - 5. ACI 306.1 - Cold Weather Concreting.
 - 6. ACI 308R - Guide to Curing Concrete.
 - 7. ACI 318 - Building Code Requirements for Structural Concrete and Commentary.
- B. ASTM International (ASTM):
 - 1. ASTM C31 - Standard Practice for Making and Curing Concrete Test Specimens in the Field
 - 2. ASTM C33 - Standard Specification for Concrete Aggregates.
 - 3. ASTM C39 - Standard Test Method for Compressive Strength of Cylindrical Concrete Specimens.
 - 4. ASTM C42 - Standard Test Method for Obtaining and Testing Drilled Cores and Sawed Beams of Concrete.
 - 5. ASTM C94 - Standard Specification for Ready-Mixed Concrete.
 - 6. ASTM C143 - Standard Test Method for Slump of Hydraulic-Cement Concrete.
 - 7. ASTM C150 - Standard Specification for Portland Cement.
 - 8. ASTM C157 - Standard Test Method for Length Change of Hardened Hydraulic-Cement Mortar and Concrete.
 - 9. ASTM C171 - Standard Specification for Sheet Materials for Curing Concrete.

10. ASTM C173 - Standard Test Method for Air Content of Freshly Mixed Concrete by the Volumetric Method.
11. ASTM C260 - Standard Specification for Air-Entraining Admixtures for Concrete.
12. ASTM C309 - Standard Specification for Liquid Membrane-Forming Compounds for Curing Concrete.
13. ASTM C330 - Standard Specification for Lightweight Aggregates for Structural Concrete.
14. ASTM C494 - Standard Specification for Chemical Admixtures for Concrete.
15. ASTM C567 - Standard Test Method for Determining Density of Structural Lightweight Concrete
16. ASTM C618 - Standard Specification for Coal Fly Ash and Raw or Calcined Natural Pozzolan for Use in Concrete.
17. ASTM C881 - Standard Specification for Epoxy-Resin-Base Bonding Systems for Concrete.
18. ASTM C 979 - Standard Specification for Pigments for Integrally Colored Concrete.
19. ASTM C1077 - Standard Practice for Laboratories Testing Concrete and Concrete Aggregates for Use in Construction and Criteria for Laboratory Evaluation.
20. ASTM C1107 - Standard Specification for Packaged Dry, Hydraulic-Cement Grout (Non-shrink).
21. ASTM C1116 - Standard Specification for Fiber-Reinforced Concrete.
22. ASTM C1218 - Standard Test Method for Water-Soluble Chloride in Mortar and Concrete.
23. ASTM C1602 - Standard Specification for Mixing Water Used in the Production of Hydraulic Cement Concrete.
24. ASTM D1751 - Standard Specification for Preformed Expansion Joint Filler for Concrete Paving and Structural Construction (Non-extruding and Resilient Bituminous Types).
25. ASTM D4832 - Standard Test Method for Preparation and Testing of Controlled Low Strength Material (CLSM) Test Cylinders.
26. ASTM E154 - Standard Test Methods for Water Vapor Retarders Used in Contact with Earth Under Concrete Slabs, on Walls, or as Ground Cover.
27. ASTM E1155 - Standard Test Method for Determining FF Floor Flatness and FL Floor Levelness Numbers.
28. ASTM E1745 - Standard Specification for Plastic Water Vapor Retarders Used in Contact with Soil or Granular Fill under Concrete Slabs.

1.03 SUBMITTALS

- A. See Section 01 30 00 – Contractor Submittals, for submittal procedures.
- B. Product Data
 1. Manufacturer's catalog sheets including instructions for use and description of application shall be provided on each of the following materials:
 - a. Epoxies
 - b. Grout
 - c. Admixtures

- d. Curing Compounds
- e. Chemical Hardener
- f. Adhesive Anchoring System

C. Mix Designs

- 1. Mix designs shall be submitted for each class of concrete on the job and shall show names and brands of all materials, proportions, slump, strength, gradation of coarse and fine aggregates, and location to be used on job. Field test records or test data that is used to establish the average compressive strength of the mixture shall be submitted.

D. Concrete Placement Schedule: The Contractor shall submit a concrete placement schedule which shall show all proposed construction joint locations, limits of each placement sequence, order of placement and type of joint proposed at each joint location.

E. Samples: Submit to testing agency of Owner's choice sample of materials as specified and as otherwise required by Architect/Engineer, including names, sources and descriptions. Select samples to fairly represent average quality and grading of aggregates proposed for the work.

F. Certificates of Compliance

- 1. The Contractor shall provide Certificate of Compliance for each type of aggregate, cementitious material and admixture to be used in each class of concrete or a Certificate of Compliance for each class of concrete.
- 2. Certificates of Compliance for cementitious materials shall include type, manufacturing location, shipping location ; for aggregates: type, pit or quarry location, producers' name, grading, specific gravities and certification evidence not more than 90 days old; for admixtures: type, brand name, producer, manufacturer's technical data sheet, and certification data; and for water: source of supply that are used in each class of concrete and shall be signed by the concrete supplier certifying that each material item complies with, or exceeds the specified requirements. Certificates of Compliance shall be furnished 60 days in advance of any concrete pours.
- 3. When Certificates of Compliance cannot be provided, the Contractor shall hire a professional testing laboratory to verify compliance of each type of material to be used in each Class of Concrete. The cost of testing shall be paid for by the Contractor.

G. Weight and Batch Tags:

- 1. The special inspector shall be provided with a weight and batch tag upon delivery of each load of concrete.

1.04 QUALITY ASSURANCE

A. Comply with the provisions of the current governing CBC, ACI 301, and ASTM C94 except where more stringent requirements are shown or specified.

B. Sampling, Testing and Inspection:

- 1. General:
 - a. If the Owner's agent, through oversight or otherwise, has accepted material or work which is defective or contrary to specifications, this material or work, regardless of state of completion, may be rejected.

- b. Testing agencies shall meet the requirements of ASTM C1077. Testing agencies shall be accepted by the Architect/Engineer before performing any work.
- 2. Contractor:
 - a. The Contractor shall cooperate with and notify Owner's agent at least 24 hours in advance of inspection required and shall provide samples and facilities for inspection without extra charge.
 - b. The Contractor shall provide and maintain adequate facilities on the project site for safe storage and initial curing of concrete test specimens as required by ASTM C31 for the sole use of the testing agency.
 - c. Each mix design shall be verified by trial batch tests or field test records and certified to by a principal of the laboratory who is a registered Civil Engineer in the State of California and submitted to the Architect/Engineer for review. Agency field test records, in order to be acceptable, must satisfy the requirement of ACI 318 section 5.3 otherwise trial mixture meeting the requirements of ACI 318 Section 5.3 shall be made. The Contractor shall submit data on qualifications of proposed testing agency for acceptance and hire the accepted testing agency to provide trial mixture test data for each type of concrete on the job.
 - d. Prior to placing any concrete, a trial batch of each Class of concrete shall be prepared using the design mix proposed for the project. From the trial batch, specimens for determining the "Drying Shrinkage" shall be prepared by the Owner's agent.

1.05 SEQUENCING AND SCHEDULING

- A. Obtain information and instructions from other trades and suppliers in ample time to schedule and coordinate the installation of items furnished by them to be embedded in concrete so provision for their work can be made without delaying the project.
- B. Perform any coring and infill of cored holes that were required by failed test results from test panels, failure or delay in complying with these requirements, at no cost to Owner.

PART 2 - PRODUCTS

2.01 FORMWORK

- A. Comply with requirements of Section 03 10 00.

2.02 REINFORCEMENT

- A. Comply with requirements of Section 03 20 00.

2.03 CEMENTITIOUS MATERIALS

- A. Cement: ASTM C 150, Type II portland type.
- B. Fly Ash: ASTM C618, Class C.
 - 1. Fly ash may substitute for portland cement up to a maximum of 25% of total cementitious materials by weight (if used, a minimum of 15% of the total cementitious materials by weight.)

- a. Substitutions that combine fly ash and ground granulated blast-furnace slag are limited to a combined total of 50% of the total cementitious material by weight with fly ash no more than 25% of the total cementitious materials by weight.
 - b. Reduce slag and fly ash substitution rates by at least 50% for cold weather concreting as defined in ACI 306.1.
- C. Ground-granulated Blast-furnace Slag: ASTM C989 grades 100 or 120
 - 1. Ground-granulated Blast-furnace Slag may substitute for Portland cement up to a maximum of 50% of the total cementitious material by weight.
- D. Use cementitious materials that are of the same brand and type and from the same plant of manufacture as the cementitious materials used in the concrete represented by the submitted field test records or used in the trial mixtures.
- E. Color Additives: ASTM C 979, synthetic or natural mineral-oxide pigments or liquid coloring admixtures, temperature stable and nonfading.

2.04 AGGREGATES

- A. Aggregates for hard rock concrete shall conform to ASTM C33.
- B. Aggregates used for entire project shall be obtained from the same sources and have the same size ranges as the aggregates used in the concrete represented by submitted historical data or used in trial mixtures.

2.05 WATER

- A. Mixing Water for concrete shall be clean and free from deleterious amounts of acids, alkalis or organic materials.

2.06 CHEMICAL ADMIXTURES

- A. Do not use chemicals that contain calcium chloride or will result in total soluble chloride ions in hardened concrete at ages from 28 to 42 days contributed from water, aggregates, cementitious materials, and admixtures in excess of 0.15 percent by weight of cement. Measure water-soluble chloride-ion content in accordance with ASTM C1218. Admixtures containing chloride salts shall not be used where concrete is poured on top of the metal deck. Calcium chloride or any admixture containing chloride ions shall not be used in drilled piers.
- B. Air Entrainment Admixture: ASTM C260.
 - 1. Acceptable Products subjected to compliance with requirements:
 - a. Sika Aer; Sika Corporation.
 - b. MB-VR or MB-AE; Master Builders.
 - c. Darex AEA; W.R. Grace.
- C. High Range Water Reducing and Retarding Admixture: ASTM C 494 Type G.
- D. High Range Water Reducing Admixture (Super Plasticizer): ASTM C494 Type F.
 - 1. Acceptable Products subjected to compliance with requirements:
 - a. WRDA19; W.R. Grace.

- b. Sikament; Sika Chemical Corporation.
 - c. Pozzolith 400; Master Builders.
- E. Water Reducing and Retarding Admixture: ASTM C494 Type D.
 - 1. Acceptable Products subjected to compliance with requirements:
 - a. Pozzolith 300-R; Master Builders.
 - b. Daratard; W.R. Grace.
 - c. Plastiment; Sika Chemical Corporation.
- F. Water Reducing Admixture: ASTM C494 Type A.
 - 1. Acceptable Products subjected to compliance with requirements:
 - a. Eucon WR-75; Euclid Chemical Company.
 - b. Pozzolith 344; Master Builders.
 - c. Plastocrete 160; Sika Chemical Corporation.
- G. Admixtures used in concrete shall be the same as those used in the concrete represented by the submitted field test records or used in the trial mixtures.

2.07 ACCESSORY MATERIALS

- A. Non-Shrink Grout:
 - 1. ASTM C1107 Grade B or C, pre-mixed, high strength, Metallic or non-metallic flowable grout, which does not shrink as it cures. Water-soluble chloride ion content of grout less than 0.06 percent chloride ion by weight of cement when tested in accordance with ATM C1218.
 - a. Minimum Compressive Strength at 7 Days: 5000 psi.
 - b. Subject to compliance with requirements provide one of the following:
 - 1) Metallic:
 - a) Embeco 636; Master Builders.
 - b) Sikagrout 212; Sika Chemical Company.
 - c) Metallic Spec. Grout; The Burke Company.
 - 2) Non-Metallic:
 - a) Masterflow 928; Master Builders.
 - b) SonogROUT 10K; Sonneborn-Contech.
 - c) Sure-Grip High Performance Grout; Dayton Superior Corporation.
- B. Waterproofing Paper: ASTM C171.
- C. Liquid Membrane Curing Compound: ASTM C309 or ASTM C1315.
- D. Post-installed anchoring systems:
 - 1. Adhesive anchoring system
 - a. Adhesive anchoring system shall be HILTI-HY 150 MAX-SD (ESR-3013) or approved equal with a current ICC/IAPMO evaluation report.
 - 2. Expansion anchors and screw anchors
 - a. Expansion anchors shall be HILTI KWIK BOLT TZ (ESR-1917), or approved equal with a current ICC/IAPMO evaluation report. Screw anchors shall be Simpson Titen HD (ESR-2713) or approved equal with a current ICC/IAPMO evaluation report.

2.08 BONDING AND JOINTING PRODUCTS

- A. Epoxy Bonding System: Epoxies shall be a two component material for use on dry or damp surfaces and shall conform to the requirements of ASTM C881. Epoxy bonding agents and adhesives shall be used in strict accordance with manufacturer's recommendations.
 - 1. Acceptable Products subjected to compliance with requirements:
 - a. Sikadur Armatec 110; Sika Chemical Corporation or equal.
- B. Joint Filler: Non-extruding, resilient asphalt impregnated fiberboard or felt, complying with ASTM D 1751, and width/depth as indicated.

2.09 CONCRETE MIX DESIGN

- A. Admixtures: Where admixtures are used they shall be added as recommended in ACI 211.1 for normal weight concrete and at rates recommended by manufacturer. Admixtures are subject to the engineer's review.
- B. Normal Weight Concrete Mix Requirements:
 - 1. Shall be made with aggregates for hard rock concrete.
 - 2. Minimum Compressive Strength, f'_c , when tested in accordance with ASTM C39 at 28 days: As scheduled below.
 - 3. Minimum Cementitious Material Content:
 - a. For concrete used in floors and slab-on-grades, cementitious material content shall not be less than indicated in following table:

Nominal maximum size of aggregate, in	Minimum cementitious material content, sacks
1-1/2	6
1	6
3/4	6
1/2	6.5
 - 4. Maximum Water-Cement Ratio: As scheduled below. Significant volume of liquid admixtures should be considered as part of the mixing water.
 - 5. Maximum Aggregate Size: Nominal maximum size of coarse aggregate shall not exceed three-fourths of the minimum clear spacing between reinforcing bars, one-fifth of the narrowest dimension between sides of forms, or one-third of the thickness of slabs or toppings.

Concrete Class	Minimum 28-day Compressive Strength f'_c	Maximum Water/ Cementitious Material Ratio	
		Non-Air Entrained	Air Entrained
Class A	3000 psi	0.55	0.55
Lean Concrete (CLSM)/(CDF)	300 psi		

- C. Controlled Low Strength Material (CLSM)/Controlled Density Fill (CDF) Mix Requirements:

1. Shall be made with aggregates conforming to ASTM C33.
 2. Minimum Compressive Strength, f'_c , when tested in accordance with ASTM D4832 at 28 days: As scheduled above.
 3. Minimum Cementitious Material Content: 2 sacks.
 4. Maximum Water-Cement Ratio: Sufficient to produce a fluid workable mixture without segregation of the aggregate when placed.
- D. Concrete Mix Designs: The following table presents a schedule of classes of concrete, maximum aggregate, maximum slump and air content for each type of concrete, which shall be as follows:
- | Concrete Element | Class of Concrete | Max. Size Aggregate | Max./Min Slump (inch) at point of discharge |
|-------------------------------|-------------------|---------------------|---|
| Foundation Walls and footings | A | 1-1/2 | 3/1 |
| Slabs on Grade and Mat Slab | A | 1 | 4/1 |
| Structural Backfill | Lean | 1-1/2 | 6/1 |
| Yard Concrete Walks & Curbs | F | 3/4 | 4/1 |
- E. Determine the slump by ASTM C143. Slump shall not exceed 3 inches for any concrete placement where top of surface slopes more than 2%. When use of a Type I or II plasticizing admixture conforming to ASTM C1017 or when a Type F or G high-range water-reducing admixture conforming to ASTM C494 is permitted to increase the slump of concrete, concrete shall have a slump of 2 to 4 in. before the admixture is added and a maximum slump of 8 in. at the point of delivery after the admixture is added unless otherwise specified.
- F. Add an air entraining agent to the concrete to provide specified amounts of entrained air per table below unless noted otherwise. Measure air content at the point of delivery in accordance with ASTM C173. Tolerance is plus/minus 1.5%. For specified compressive strengths above 5000 psi, the air contents indicated in the following table may be reduced by 1%.

Nominal maximum aggregate size, in	Air content, Percent
1/2	7
3/4	6
1	6
1-1/2	5.5

2.10 MIXING

- A. Use ready-mixing concrete complying with ASTM C94 and with the requirements of Contract Documents. Mix for a period of not less than ten (10) minutes; at least three (3) minutes of mixing period shall be immediately prior to discharging at the job.
- B. CLSM shall be placed in the work within 3 hours after introduction of the cement to the aggregates.

PART 3 - EXECUTION

3.01 EXAMINATION

- A. Verify lines, levels, and dimensions before proceeding with work of this section.

3.02 WEATHER REQUIREMENTS

- A. Reinforcement, forms and ground which concrete will contact shall be completely free of frost.
- B. When the average of the highest and lowest temperature during the period from midnight to midnight is expected to drop below 40 °F for more than three successive days, deliver concrete to meet the following minimum temperatures immediately after placement:
 - 1. 55 °F for sections less than 12 in. in the least dimension;
 - 2. 50 °F for sections 12 to 36 in. in the least dimension;
 - 3. 45 °F for sections 36 to 72 in. in the least dimension; and
 - 4. 40 °F for sections greater than 72 in. in the least dimension.
- C. The temperature of concrete as placed shall not exceed these values by more than 20 °F. These minimum requirements may be terminated when temperatures above 50 °F occur during more than half of any 24 h duration.
- D. The temperature of concrete as placed shall not exceed 90 °F. When temperature of steel reinforcement, Embedments, or forms is greater than 120 °F, fog steel reinforcement, Embedments, and forms with water immediately before placing concrete. Remove standing water before placing concrete.
- E. Do not begin to place or continue to place concrete while rain, sleet, or snow is falling unless adequate protection is provided and, when required, acceptance of protection is obtained. Do not allow rain water to increase mixing water or to damage the surface of the concrete.

3.03 CONVEYING AND PLACING CONCRETE

- A. All concrete shall be mixed, delivered and discharged in accordance with the requirements of ASTM C94. All concrete shall be placed, finished and cured and all other pertinent construction practices shall be in accordance with the requirements of ACI 301.
- B. Notify Architect/Engineer not less than 48 hours prior to commencement of placement operations.
- C. Before placing, clean mixing and conveying equipment, clean forms and space to be occupied by concrete and wet forms. Remove ground water until completion of work.
- D. Place no concrete in any unit of work until all formwork has been completely constructed, all reinforcements secured in place, all items to be built into concrete are in place, and form ties at constructions joints tightened.
- E. Slabs and beams shall not be subjected to occupant or storage loads exceeding 20 psf until specified strength is reached (28 days minimum).

- F. Concrete shall be placed so that a uniform appearance of surfaces will be obtained. The concrete will be free of all rock pockets, honeycombs and voids.
- G. The subgrade must be moist when the concrete is placed for floor slab to prevent excessive loss of water from the concrete mix.
- H. Pumping of concrete may require admixtures to increase slump beyond the maximum slump listed. Admixtures are subject to the engineer's review.
- I. Carry on concreting, once started, as a continuous operation until the section of approved size and shape is completed. Make pour cut-offs of approved detail and location.
- J. Handle concrete as rapidly as practicable from mixer to place of deposit by methods which prevent separation or loss of ingredients. Deposit as nearly as practicable in final position to avoid re-handling or flowing. Do not drop concrete freely where reinforcing bars will cause segregation, impact the soil face of excavations nor drop freely more than eight feet. Use hoppers, chutes or trunks of varying length so that the free unconfined fall of concrete shall not exceed eight feet. Deposit to maintain a plastic surface approximately horizontal. In walls, deposit in horizontal layers not over eighteen inches deep. In pouring columns, walls or thin sections of considerable heights, use openings in forms, elephant trunks, tremies or other approved devices which permit concrete to be placed without segregation or accumulation of hardened concrete on forms or metal reinforcement above the level of the concrete. Install so concrete will be dropped vertically.
- K. Consolidating: All concrete shall be placed with mechanical vibration unless noted otherwise. Employ as many vibrators and tampers as necessary to secure the desired results. Minimum: one per each 20 cubic yards of concrete placed per hour. Eliminate the following practices: Pushing of concrete with vibrator; external vibration of forms; allowing vibrator to vibrate against reinforcing steel where steel projects into green concrete; allowing vibrator to vibrate contact faces of forms. Vibrators shall function at a minimum frequency of 3600 cycles per minute when submerged in concrete. Supplement vibration by forking and spading along the surfaces of the forms and between reinforcing whenever flow is restricted. Drilled piers shall be vibrated only to a depth of 3 times the pier diameter measured from the top of pier.

3.04 CONSTRUCTION JOINTS

- A. Location and details of construction joints shall be as indicated on drawings, specified, or as approved by the Architect/Engineer. Locate so as not to impair the strength of the structure.
- B. Sandblast all construction joints using coarse sand or waterblast to clean and roughen entire surface of joint, exposing coarse aggregate solidly embedded in mortar matrix uniformly. Clean forms and reinforcing of drippings. Clear away debris by compressed air.

3.05 CONCRETE FINISHING

- A. Finishing Formed Surfaces: Finish per requirements of ACI 301.

1. Use grout-cleaned finish for permanently exposed formed surfaces except foundation surfaces and smooth-rubbed finish for exposed foundation surfaces.
 2. Use medium broom finish for the surface finish of all slabs.
- B. Finishing Unformed Surfaces: Finish per requirements of ACI 301. Start finishing after bleeding of concrete is finished. The presence of bleed water is detected visually but when concrete surface is getting dry fast and rate of evaporation is so high, place a clear plastic sheet over a section of the concrete to block evaporation and to allow observation of bleeding.
- C. Measure slabs for slabs-on-ground to verify compliance with the tolerance requirements of ACI 117 as specified below:
1. 1/4 inch in 10 ft in accordance with the "10-ft straight edge method" in ACI 117.

3.06 CONTROL JOINTS

- A. Control joints shall be made by sawcutting slab with the Soff-Cut system or approved equal as soon as the surface is firm enough so that it will not be damaged by the blade, usually within 2 to 4 hours after final finishing (no later than 8 hours after placement). Cut 1/4 depth of slab thickness not less than 1 inch.

3.07 CURING AND PROTECTION

- A. Comply with requirements of ACI 301. Immediately after placement, protect concrete from premature drying, excessively hot or cold temperatures, and mechanical injury.
- B. Maintain concrete with minimal moisture loss at above 50 F for the period of time necessary for hydration of cement and hardening of concrete.
1. Normal concrete: At least the first 7 days after placement.
 2. High early strength concrete: At least the first 3 days after placement.
- C. Curing methods shall comply with ACI 308R.
- D. Curing compounds conforming to ASTM C309 or ASTM C1315 shall be applied in accordance with the recommendations of the manufacturer and shall not be used on any surface against which additional concrete or other cementitious finishing materials are to be bonded, where epoxy flooring is called for, where concrete topping is to receive waterproofing membrane, where not recommended by integral color maker, nor on surfaces where such curing is prohibited by the project specifications.
- E. Unformed concrete surfaces: Start curing as soon as the bleed water sheen has disappeared and before surface is dry.
1. Initial Curing: If surface drying starts before initial set of concrete, keep concrete continuously moist up to final set of concrete by fog spray. Time of initial set is also known as the vibration limit where concrete cannot be properly consolidated after reaching initial set. Before initial set, the concrete is not stiff enough to support the weight of a finisher or finishing machine. Water from fogging should be removed or allowed to evaporate before finishing.
 2. Final Curing: Begin immediately after finishing. If finishing is completed but concrete has not reached final set, keep concrete continuously moist by fog spray, a liquid-

applied evaporation reducer spray, or liquid membrane-forming curing compound spray. Water from fogging should be removed or allowed to evaporate before finishing. After final set of concrete, curing shall be accomplished by one of the following materials or method:

- a. Ponding, continuous fogging, or continuous sprinkling;
 - b. Application of a curing compound.
 - c. Application of mats or fabric kept continuously wet.
 - d. Application of sheet materials conforming to ASTM C171.
 - e. Other moisture-retaining covering as reviewed by Architect/Engineer.
- F. Formed concrete surfaces: Steel forms and all wood forms in contact with the concrete shall be kept wet until they are removed. After formwork removal cure concrete by one of the method in final curing.
- G. Remove protection in such a manner that the maximum decrease in temperature measured at the surface of the concrete in a 24 hr period shall not exceed the following:
1. 50 °F for sections less than 12 in. in the least dimension;
 2. 40 °F for sections from 12 to 36 in. in the least dimension;
 3. 30 °F for sections 36 to 72 in. in the least dimension; or
 4. 20 °F for sections greater than 72 in. in the least dimension.
- H. Measure concrete temperature using a method acceptable to the Architect/Engineer, and record the concrete temperature. When the surface temperature of the concrete is within 20 °F of the ambient or surrounding temperature, protection measures may be removed.

3.08 PATCHING AND CLEANING

- A. After forms are removed, remove projecting fins, form ties, nails, etc. not necessary for the work or cut back one inch from the surface. Joint marks and fins in exposed work shall be smoothed off and cleaned as directed by the Architect/Engineer.
- B. Repair defects in concrete work as directed by the Engineer and per ACI 301. Chip voids and stone pockets to a depth of one inch or more as required to remove all unsound material. Voids, surface irregularities, chipped areas, etc., shall be filled by patching, gunite or rubbing, as directed by the Architect/Engineer. Repaired surfaces shall duplicate appearance of unpatched work.
- C. Clean exposed concrete surfaces and adjoining work stained by leakage of concrete to approval of Architect/Engineer.

3.09 CLEANUP

- A. Clean up all concrete and cement work on completion of this portion of the work, except protective coatings or building papers shall remain until floors have completely cured or until interior partitions are to be installed.

3.10 GROUTING

- A. Bearing plates and channels: The space between plates and channels bearing against masonry or concrete shall be filled with grout when required by the Engineer. The grout

shall be mixed and placed in strict accordance with manufacturer's instructions. Care shall be taken in the grouting to ensure that there are no voids or air pockets, and that there is full bearing between the bearing plates and channels and the grout.

3.11 POST INSTALLED ANCHORS

- A. Installation of anchors and adhesive including drilling, cleaning of holes and torque shall be in accordance with the current ICC/IAPMO evaluation report. Post installed anchors shall be used only in applications permitted by the Evaluation Report. Anchors shall use washer sized to prevent crushing of the attached member at installation torque.

3.12 FIELD QUALITY CONTROL

- A. Engineer Review: The Engineer or Owner's Inspector shall inspect the surfaces between plates and channels, bearing on masonry and concrete to determine if grouting of space is necessary. If grouting of space is necessary, the Owner's Inspector shall inspect the grouting procedure.
- B. Acceptance of concrete strength:
 - 1. Standard molded and cured strength specimens: Test results from standard molded and cured test cylinders shall be evaluated separately for each specified concrete mixture. For evaluation, each specified mixture shall be represented by at least five tests. The strength level of concrete will be considered satisfactory when the averages of all sets of three consecutive compressive strength test results molded and cured in accordance with the requirements of ASTM C31 equal or exceed f_c and no individual strength test result falls below f_c by more than 500 psi when f_c is 5000 psi or less, or by more than $0.10f_c$ when f_c is more than 5000 psi.
 - 2. Core tests: Where required by the Engineer, cores shall be obtained in accordance with ASTM C42. The location of cores shall be determined by the Engineer. If, before testing, cores show evidence of having been damaged subsequent to or during removal from the structure, replacement cores shall be taken. Strength level of concrete in the area represented by core tests will be considered adequate when the average compressive strength of the cores is equal to at least 85% of f_c , and if no single core is less than 75% of the specified compressive strength f_c .
- C. When the strength of field-cured cylinders is less than 85% of companion laboratory- cured cylinders, evaluate current operations and provide corrective procedures for protecting and curing in-place concrete.
- D. Field Acceptance of concrete: Concrete within the specified limits of air-entrainment, slump and temperature shall not be used in the work.
- E. Additional Tests: The Owner's agent will make additional tests of in-place concrete when test results indicate specified concrete strengths and other characteristics have not been attained in the structure or deficiencies in protection and curing has occurred, as directed by Engineer. Owner's agent may conduct tests to determine adequacy of concrete by cored cylinders complying with ASTM C42, or by other methods as directed. Contractor shall pay for such tests conducted, other additional testing as may be required, and cost of repairing areas of structure tested when unacceptable concrete is verified.

3.13 DEFECTIVE CONCRETE

- A. General: Work considered to be defective may be ordered by the Architect/Engineer to be replaced in which case the Contractor shall remove the defective work at his expense. Work considered to be defective shall include, but not be limited to, the following:
 - 1. Concrete in which defective or inadequate reinforcing steel has been placed.
 - 2. Concrete in incorrectly formed, or not conforming to details and dimensions on the drawings or with the intent of these documents, or concrete the surfaces of which are out of plumb or level.
 - 3. Concrete below specified strength.
 - 4. Concrete not meeting the maximum allowable drying shrinkage requirements.
 - 5. Concrete containing wood, cloth, or other foreign matter, rock pockets, voids, honeycombs, cracks or cold joints not scheduled or indicated on the drawings.

3.14 CORRECTION OF DEFECTIVE WORK

- A. The Contractor shall, at his expense, make all such corrections and alleviation measures as directed by the Engineer.
- B. Concrete work containing rock pockets, voids, honeycombs, cracks or cold joints not scheduled or indicated on the drawings, shall be chipped out until all unconsolidated material is removed.
- C. Secure approval of chipped-out areas before patching. Patch per ACI 301-latest governing edition.

END OF SECTION

SECTION 036 00 0

GROUTS

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes:
 - 1. Concrete mortar.
 - 2. Grout.
 - 3. Dry pack mortar.
 - 4. Non-shrink grout.
 - 5. Epoxy grout.
 - 6. Non-shrink epoxy grout.

1.02 REFERENCES

- A. American Society for Testing and Materials (ASTM):
 - 1. C 109 - Test Method for Compressive Strength of Hydraulic Cement Mortars (using 2 inch or 50 millimeter cube specimens).
 - 2. C 531 - Test Method for Linear Shrinkage and Coefficient of Thermal Expansion of Chemical-Resistant Mortars, Grouts, Monolithic Surfacing, and Polymer Concretes.
 - 3. C 579 - Test Method for Compressive Strength of Chemical-Resistant Mortars and Monolithic Surfacing.
 - 4. C 827 - Test Method for Change in Height at Early Ages of Cylindrical Specimens from Cementitious Mixtures.
 - 5. C 939 - Test Method for Flow of Grout for Preplaced-Aggregate Concrete (Flow Cone Method).
 - 6. C 1090 - Test Method for Measuring Change in Height of Cylindrical Specimens from Hydraulic-Cement Grout.
 - 7. C 1107 - Standard Specification for Packaged Dry, Hydraulic-Cement Grout (Non-shrink).
 - 8. C 1181 - Test Methods for Compressive Creep of Chemical-Resistant Polymer Machinery Grouts.

1.03 SUBMITTALS

- A. Non-shrink Grout and Non-shrink Epoxy Grout: Submit manufacturer's literature and certified test data prior to installation.

1.04 DELIVERY, STORAGE, AND HANDLING

- A. All materials shall be delivered to the jobsite in their original, unopened packages or containers, clearly labeled with the manufacturer's product identification and printed instructions.

- B. All materials shall be stored in a cool dry place and in accordance with the manufacturer's recommendations.
- C. All materials shall be handled in accordance with the manufacturer's instructions.

1.05 PROJECT/SITE CONDITIONS

- A. Refer to manufacturer's literature or contact the manufacturer for any special physical or environmental limitations that may be required for use of products.

1.06 WARRANTIES

- A. Non-shrink Grout: The manufacturer shall warranty that the non-shrink grout will never go below its initial placement volume when tested in accordance with ASTM C 1107.
- B. Non-shrink Epoxy Grout: The manufacturer shall warranty that non-shrink epoxy grout will show negligible shrinkage or expansion when tested in accordance with ASTM C 531.

PART 2 - PRODUCTS

2.01 MATERIALS

- A. Concrete Mortar:
 - 1. General: Consist of concrete mixture with coarse aggregate removed and water quantity adjusted as required.
 - 2. At Exposed Concrete Surfaces Not to Be Painted or Submerged in Water: White cement.
- B. Grout:
 - 1. Consist of mixture of Portland cement and sand.
- C. Dry-pack Mortar:
 - 1. Consist of mixture of Portland cement and sand.
- D. Non-shrink Grout:
 - 1. Non-shrink grout shall be a preportioned and prepackaged cement-based mixture. It shall contain no metallic particles such as aluminum powder and no metallic aggregate such as iron filings. It shall require only the addition of potable water.
 - 2. Potable water for pre-soaking, mixing, and curing shall be clean and free of oils, acids, alkalis, organics, and any other deleterious matter.
 - 3. Bleeding: Non-shrink grout shall be free from the emergence of mixing water from within or the presence of water on its surface.
 - 4. Non-shrink grout shall be in accordance with ASTM C 1107.
 - 5. Consistency: Non-shrink grout shall remain at a minimum flowable consistency for at least 45 minutes after mixing at 45 degrees Fahrenheit to 90 degrees Fahrenheit when tested in accordance with ASTM C 230. If at a fluid consistency, it shall be verified in accordance with ASTM C 939.

6. Dimensional Stability (height change): Non-shrink grout shall be in accordance with ASTM C 1107, volume-adjusting Grade B or C at 45 degrees to 90 degrees. It shall show 90 percent or greater bearing area under bases or baseplates.
 7. Compressive Strength: Non-shrink grout shall show minimum compressive strengths at 45 degrees Fahrenheit to 90 degrees Fahrenheit in accordance with ASTM C 1107 for various periods from the time of placement, including 5,000 pounds per square inch at 28 days when tested in accordance with ASTM C 109 as modified by C 1107.
 8. Manufacturers: One of the following or equal:
 - a. Five Star Products, Inc., Fairfield, CT, Five Star Grout.
 - b. Master Builders, Inc., Cleveland, OH, Masterflow 928.
 - c. L&M Construction Chemicals, Inc., Omaha, NE, CRYSTEX.
- E. Epoxy Grout:
1. Consist of mixture of epoxy and sand.
 2. Sand: Clean, bagged, graded, and kiln dried silica sand.
- F. Non-shrink Epoxy Grout:
1. Non-shrink epoxy grout shall be a 100 percent solids, premeasured, prepackaged system containing a two-component thermosetting epoxy resin and inert aggregate.
 2. Consistency: Non-shrink epoxy grout shall maintain a flowable consistency for at least 45 minutes at 70 degrees Fahrenheit.
 3. Dimensional Stability (height change):
 - a. Non-shrink epoxy grout shall have negligible shrinkage or expansion (less than 0.0006 in/in) when tested in accordance with ASTM C 531.
 4. Compressive Strength: Non-shrink epoxy grout shall show a minimum compressive strength of 10,000 pounds per square inch at 24 hours and 14,000 pounds per square inch at 7 days when tested in accordance with ASTM C 579, Method B.
 5. Compressive Creep: The compressive creep for non-shrink epoxy grout shall not exceed 0.0027 in/in when tested under a 400 pounds per square inch constant load at 140 degrees Fahrenheit in accordance with ASTM C 1181.
 6. Thermal Capability: The coefficient of thermal expansion for non-shrink epoxy grout shall not exceed 0.000018 inches per inch per degree Fahrenheit when tested under ASTM C 531, Method B.
 7. Manufacturers: One of the following or equal:
 - a. Five Star Products, Inc., Fairfield, CT, Five Star Epoxy Grout.
 - b. Master Builders, Inc., Cleveland, OH, Masterflow 648 CP Plus.
 - c. L&M Construction Chemicals, Inc., EPOGROUT.

2.02 MIXES

- A. Concrete Mortar Mix:
1. Use water-cement ratio that is no more than that specified for concrete being repaired.
 2. At Exposed Concrete Surfaces Not to Be Painted or Submerged in Water: Use sufficient white cement to make color of finished patch match that of surrounding concrete.
- B. Grout Mix:

1. For Concrete Repair: Mix in same proportions used for concrete being repaired, with only sufficient water to give required consistency for spreading.
 2. For Spreading over the Surfaces of Construction or Cold Joints: Mix with no more water used than allowed by water-cement ratio specified for concrete.
 3. For Other Applications: Mix in proportions by weight of one-part cement to four parts of concrete sand.
- C. Dry-pack Mortar Mix: Use only enough water so that resulting mortar will crumble to touch after being formed into ball by hand.
- D. Non-shrink Grout: Mix in accordance with manufacturer's installation instructions such that resulting mix has fluid or flowable consistency and is suitable for placing by pouring.
- E. Epoxy Grout:
1. Mix in accordance with manufacturer's installation instructions for mixing.
 2. Proportioning:
 - a. For horizontal work, consist of mixture of one-part epoxy as specified in Section 03 63 00 with not more than 2 parts sand.
 - b. For vertical or overhead work, consist of 1-part epoxy gel as specified in Section 03 63 00 with not more than 2 parts sand.
- F. Non-shrink Epoxy Grout: Mix in accordance with manufacturer's installation instructions.

PART 3 - EXECUTION

3.01 EXAMINATION

- A. Inspect concrete surfaces to receive grout or mortar and verify that they are free of ice, frost, dirt, grease, oil, curing compounds, paints, impregnations and all loose material or foreign matter likely to affect the bond or performance of grout or mortar.
- B. Inspect baseplate and anchor systems for rust, oil, and other deleterious substances that may affect the bond or performance of grout.
- C. Confirm that newly placed concrete has been cured sufficiently to attain its design strength and limit further shrinkage.
- D. Verify that temperature of cementitious or epoxy grout does not exceed manufacturer's recommendations.

3.02 PREPARATION

- A. Surface Preparation:
1. Roughen all concrete surfaces by heavy sandblasting, chipping, or other mechanical means to assure bond. Loose or broken concrete shall be removed.
 2. All grease, oil, dirt, curing compounds, laitance, and other deleterious materials that may affect bond that were identified in the inspection process shall be completely

removed from concrete and bottoms of baseplates. All metal surfaces should have a 2 to 3 mil peak-to-valley profile for epoxy grouts.

3. For cementitious mortars and grouts, concrete surfaces shall be saturated surface dry. Any standing water shall be removed prior to placing grouts.
4. For epoxy grouts, do not wet concrete surfaces with water. Instead, where required, wet surfaces with epoxy for horizontal work or epoxy gel for vertical or overhead work prior to placing epoxy grouts.

B. Forms and Headboxes for Grouts (Cementitious or Epoxy):

1. Forms for grouts shall be built of material with adequate strength to withstand the placement of grouts.
2. Forms must be rigid and liquid tight. All cracks and joints shall be caulked with an elastomeric sealant. All forms shall be lined with polyethylene for easy grout release. Forms carefully waxed with two coats of heavy-duty paste wax shall also be acceptable.
3. Forms shall be 4 to 6 inches higher than the baseplate on one side of the baseplate configuration when using head pressure for placement.
4. A sufficient number of headboxes shall be built to facilitate placement of grouts.
5. Air relief holes a minimum 1/8 inch in diameter shall be provided when required by a baseplate configuration to avoid entrapping air underneath.

3.03 APPLICATION

A. Cement Mortar and Grout:

1. For Defective Concrete Repair:
 - a. Filling: Filling of voids around items through the concrete.
 - b. Grout Spreading: Spread over construction joints, cold joints, and similar type items.
2. Concrete Surfaces:
 - a. Apply epoxy bonding agent to clean, roughened, and dry surfaces before placing mortar or grout.
3. Placing:
 - a. Exercise particular care in placing Portland cement mortar or grout since they are required to furnish structural strength or impermeable water seal or both.
 - b. Do not use cement mortar or grout that has not been placed within 30 minutes after mixing.

B. Epoxy Grout:

1. Apply in accordance with manufacturer's installation instructions.
2. Use where specified herein or where indicated on the Drawings.

3.04 PLACEMENT

- A. The CONTRACTOR shall make arrangements to have a grout manufacturer's representative present for a preconstruction meeting and during initial grout placement. Grout shall only be installed after the final equipment alignment is correct and accepted by the ENGINEER.
1. Grouts shall be mixed in accordance with the manufacturer's recommendations.

2. A mortar mixer with moving paddles shall be used for mixing grouts. For cementitious grouts, pre-wet the mixer and empty out excess water before beginning mixing.
3. Cementitious Grouts:
 - a. Non-shrink cementitious grout shall be added to a premeasured amount of water that does not exceed the manufacturer's maximum recommended water content.
 - b. Mix cementitious grouts per manufacturer's instructions for uniform consistency.
 - c. Grouts may be dry packed, flowed, or pumped into place. All baseplate grouting shall take place from one side of a baseplate to the other to avoid trapping air. Do not overwork grouts.
 - d. Do not re-temper grout by adding more water after stiffening.
 - e. Hydrostatic head pressure shall be maintained by keeping the level of the grout in the headbox above the bottom of the baseplate. The headbox should be filled to the maximum level and the grout worked down to top of baseplate.
4. Epoxy Grouts:
 - a. Epoxy grouts shall be mixed in complete units. Do not vary the ratio of components or add solvent to change the consistency of the mix.
 - b. Pour the hardener into the resin and mix for at least one minute and until each mixture is uniform in color. Pour the chemical components into the mortar mixer wheelbarrow and add the aggregate. Mix until aggregate is uniformly wetted. Overmixing will cause air entrapment in the mix.
 - c. All epoxy grout shall be flowed into place using a headbox. All grouting shall take place from one side of a baseplate to the other in a continuous flow to avoid trapping air.
 - d. Hydrostatic head pressure shall be maintained by keeping the level of grout in headboxes above the bottom of baseplates. Headboxes shall be filled to the maximum level and grout worked down to the bottom of baseplates.
 - e. Epoxy grouts shall not be cut back after setting. The final level of grout will be as installed with all chamfer edges built into the formwork.

3.05 CURING

A. Cementitious Grouts:

1. Grouts must be cut back to the lower edge of baseplates after reaching initial set. Provide a 45-degree angle cut back.
2. Clean equipment and tools as recommended by the grout manufacturer.
3. Cure Grouts in accordance with manufacturer's specifications and recommendations. Keep grout moist for a minimum of 3 days. The method needed to protect grouts will depend on temperature, humidity, and wind. Wet burlap, a soaker hose, sun shading, ponding and, in extreme conditions, a combination of methods shall be employed.
4. Grouts shall be maintained above 40 degrees Fahrenheit until they have attained a compressive strength of 3,000 pounds per square inch or above 70 degrees Fahrenheit for a minimum of 24 hours to avoid damage from subsequent freezing.

B. Epoxy Grouts:

1. Cure grouts in accordance with manufacturers' specifications and recommendations. Do not wet cure epoxy grouts.
2. Consult the manufacturer for appropriate cure schedule. In no case should any surface in contact with grout be allowed to fall below 50 degrees Fahrenheit for a minimum of 48 hours after placement.

3. Equipment and tools shall be cleaned immediately with a strong liquid detergent and water solution before grout hardens.

3.06 FIELD QUALITY CONTROL

- A. Non-shrink cementitious grouts shall be tested for 24-hour compressive strength in accordance with ASTM C 109.
- B. Non-shrink grouts shall be tested for 24-hour compressive strength in accordance with ASTM C 579 (Method B).

END OF SECTION

SECTION 03 63 00

EPOXIES

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes:
 - 1. Epoxy.
 - 2. Epoxy gel.
 - 3. Epoxy bonding agent.

1.02 REFERENCES

- A. American Society for Testing and Materials (ASTM):
 - B. D 638 - Test Method for Tensile Properties of Plastics.
 - C. D 695 - Test Method for Compressive Properties of Rigid Plastics.
 - D. D 790 - Test Methods for Flexural Properties of Unreinforced and Reinforced Plastics and Electrical Insulating Materials.

1.03 SYSTEM DESCRIPTION

- A. Performance Requirements:
- B. Provide epoxy materials that are new and use them within shelf life limitations set forth by manufacturer.
- C. Perform and conduct work of this Section in neat orderly manner.

1.04 SUBMITTALS

- A. Product Data: Submit manufacturer's data completely describing epoxy materials.
- B. Quality Control Submittals:
 - 1. Manufacturer's installation instructions.

PART 2 - PRODUCTS

2.01 MATERIALS

- A. Epoxy: Water-insensitive two-part type low viscosity epoxy adhesive material containing 100 percent solids and meeting or exceeding following characteristics when tested in accordance with standards specified: Manufacturers: One of the following or equal:
 - 1. Master Builders, Inc., Concessive Standard LVI.

2. Sika Chemical Corp., Sikadur 35 Hi-Mod LV.

Physical Characteristic	Test Method	Required Results
Tensile Strength	ASTM D 638	8,000 pounds per square inch at 14 days and 77 degrees Fahrenheit cure.
Flexure Strength	ASTM D 790	11,000 pounds per square inch at 14 days and 77 degrees Fahrenheit cure.
Compressive Strength	ASTM D 695	16,000 pounds per square inch at 24 hours and 77 degrees Fahrenheit cure.
Bond Strength	---	Concrete shall fail before failure of epoxy.
Gel Time In 5-Mil Film	---	Four hours maximum at 77 degrees Fahrenheit.
Elongation	ASTM D 638	1 percent minimum at 14 days and 77 degrees Fahrenheit.

- B. Epoxy Gel: Manufacturers: One of the following or equal:

1. Sika Chemical Corp.'s, Sikadur 31, Hi-Mod Gel.

- C. Epoxy Bonding Agent: Manufacturers: One of the following or equal:

1. Master Builders, Inc., Concessive 1001 Liquid LPL.
2. Sika Chemical Corp.'s, Sikadur 32, Hi-Mod.

PART 3 - EXECUTION

3.01 INSTALLATION

- A. Install and cure epoxy materials in accordance with manufacturer's installation instructions.
- B. Epoxy:
1. Apply in accordance with manufacturer's installation instructions.
- C. Epoxy Gel:
1. Apply in accordance with manufacturer's installation instructions.
 2. Use for vertical or overhead work, or where high viscosity epoxy is required.
 3. Epoxy gel used for vertical or overhead work may be used for horizontal work.
- D. Epoxy Bonding Agent:
1. Apply in accordance with manufacturer's installation instructions.
 2. Bonding agent will not be required for filling form tie holes or for normal finishing and patching of similar sized small defects.

END OF SECTION

SECTION 05 50 00

METAL FABRICATIONS

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes: Miscellaneous metal fabrications including:
 - 1. Handrails and Guardrails.
 - 2. Manhole Frames and Covers.
 - 3. Gratings and Covers.
 - 4. Splash Guards.
 - 5. Miscellaneous Metals: Includes aluminum, stainless steel, structural steel.
 - 6. Associated accessories to the above items.
- B. Related Sections:
 - 1. Section 09 90 00 – Painting and Coating.

1.02 REFERENCES

- A. Aluminum Association (AA):
 - 1. Specification M32-C22-A41 - Aluminum Finishes.
- B. American Association of State Highway and Transportation Officials (AASHTO):
 - 1. Standard Specifications for Highway Bridges.
- C. American Society for Testing and Materials (ASTM):
 - 1. A 36/A 36M - Specification for Carbon Structural Steel.
 - 2. A 48 - Specification for Grey Iron Castings.
 - 3. A 53 - Specification for Pipe, Steel, Black and Hot-Dipped, Zinc-Coated, Welded and Seamless.
 - 4. A 123 - Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products.
 - 5. A 167 - Specification for Stainless and Heat-Resisting Chromium-Nickel Steel Plate, Sheet, and Strip.
 - 6. A 240 - Specification for Heat-Resisting Chromium and Chromium-Nickel Stainless Steel Plate, Sheet, and Strip for Pressure Vessels.
 - 7. A 269 - Specification for Seamless and Welded Austenitic Stainless Steel Tubing for General Service.
 - 8. A 276 - Specification for Stainless Steel Bars and Shapes.
 - 9. A 307 - Specification for Carbon Steel Bolts and Studs, 60,000 PSI Tensile Strength.
 - 10. A 320 - Specification for Alloys - Steel Bolting Materials for Low-Temperature Service

11. A 325 - Specification for Structural Bolts, Steel, Heat Treated, 120/105 ksi Minimum Tensile Strength
 12. A 489 - Specification for Carbon Steel Lifting Eyes.
 13. A 490 - Specification for Steel Structural Bolts, Alloy Steel, Heat-Treated, 150 ksi Minimum Tensile Strength.
 14. A 500 - Specification for Cold-Formed Welded and Seamless Carbon Steel Structural Tubing in Rounds and Shapes.
 15. A 501 - Specification for Hot-Formed Welded and Seamless Carbon Steel Structural Tubing.
 16. A 568 - Standard Specification for Steel, Sheet, Carbon, Structural, and High-Strength, Low-Alloy, Hot-Rolled and Cold-Rolled
 17. A 570/A 570M - Specification for Steel, Sheet and Strip, Carbon. Hot-Rolled, Structural Quality.
 18. A 635/A 635M - Specification for Steel, Sheet and Strip, Heavy-Thickness Coils, Carbon, Hot-Rolled.
 19. A 653/A 653M - Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-coated (Galvannealed) by the Hot-Dip Process.
 20. B 209 - Specification for Aluminum and Aluminum-Alloy Sheet and Plate.
 21. B 221 – Aluminum Alloy, Extruded Bars, Rods, Wire, Profiles and Tubes.
 22. B 429 - Specification for Aluminum-Alloy Extruded Structural Pipe and Tube.
- D. American National Standards Institute (ANSI):
1. A14.3 - Ladders-Fixed: Safety Requirements.
 2. 531 Metal Bar Grating Manual
- E. American Welding Society (AWS).
- F. International Conference of Building Officials (ICBO):
1. Uniform Building Code (UBC), latest edition.
- G. Occupational Safety and Health Administration (OSHA).

1.03 QUALITY ASSURANCE

- A. Regulatory Requirements: Except as modified by the requirements specified herein and detailed on the plans, the installation of fabricated metal work shall conform to the "Uniform Building Code" (UBC).

1.04 SUBMITTALS

- A. Shop Drawings: Submit for handrails and guardrails, including details on connection attachments, gates, kick plates, ladders, and angles.
1. Indicate profiles, sizes, connection attachments, reinforcing, anchorage, size and type of fasteners, and accessories.
 2. Include erection drawings, elevations, and details where applicable.
 3. Indicate welded connections using standard AWS welding symbols. Indicate net weld lengths.

- B. Quality Control Submittals:
1. Design Data.
 2. Test Reports:
 - a. Manufacturers' calculations showing that gratings and covers will meet specified load-bearing and deflection requirements for each size grating or cover for each type of installation.
 - b. Reports of tests performed.

PART 2 - PRODUCTS

2.01 GENERAL

- A. Materials: Unless otherwise specified or indicated on the Drawings, structural and miscellaneous metals shall conform with the standards of the ASTM, including the following:

Item	ASTM Standard No.	Class, Grade Type or Alloy No.
Cast Iron		
Cast Iron	A 48	Class 40B
Steel		
Galvanized sheet iron or steel	A 653	Coating G90
Black steel, sheet or strip	A 569 A 570	--
Coil (plate)	A 635	--
Structural plate, bars, rolled shapes, and miscellaneous items	A 36	--
Standard bolts, nuts, and washers	A 307	--
High strength bolts, nuts, and hardened flat washers	A 325 A 490	--
Eyebolts	A 489	Type 1
Tubing, cold-formed	A 500	--
Tubing, hot-formed	A 501	--
Steel pipe	A 53	Grade B
Stainless steel		
Plate, sheet and strip	A 167	Type 304 or 316*
Bars and shapes	A 276	Type 304 or 316*
Bolts and threaded rods	A 320	Type 304 or 316*

Item	ASTM Standard No.	Class, Grade Type or Alloy No.
Aluminum		
Sheet aluminum-flashing	B 209	Alloy 5005-H14, 0.032 inches minimum thickness
Sheet aluminum-structural	B 209	Alloy 6061-T6
Structural aluminum	B 308 B 209	Alloy 6061-T6
Extruded aluminum	B 221	Alloy 6063-T42
* Use Type 304L or Type 316L if material will be welded.		

1. Stainless steels are designated by type or series defined by ASTM.
2. Where stainless steel is welded, use low-carbon stainless steel.

2.02 MANHOLE FRAMES AND COVERS

A. Material:

1. Gray iron castings, ASTM A 48, Class 30-B.
2. Stainless steel, ASTM A 276.

B. Type: Heavy-duty traffic type, with combined set weight of minimum 265 pounds.

1. Machine horizontal and vertical bearing surfaces to fit neatly, with easily removable cover bearing firmly in frame without rocking.

C. Frame:

1. Bottom flange type.
2. Approximately 4-1/2-inches frame height.
3. 24-inch diameter clear inside dimension, unless otherwise indicated on the Drawings.
4. Approximately 32-inches bottom flange outside diameter.

D. Cover:

1. Skid-resistant grid pattern design stamped with name of utility service provided by manhole, such as "ELECTRICAL," "STORM", "SEWER," "TELEPHONE," or "WATER."
2. Solid type without ventilation holes.

E. Finish: Unpainted.

2.03 MISCELLANEOUS METAL

- A. Miscellaneous Aluminum: Fabricate aluminum products, not covered separately herein, in accordance with the best practices of the trade and field assemble by riveting or bolting. Do not weld or flame cut.

- B. Miscellaneous Cast Iron:
 - 1. General:
 - a. Tough, gray iron, free from cracks, holes, swells, and cold shuts.
 - b. Quality such that hammer blow will produce indentation on rectangular edge of casting without flaking metal.
 - c. Before leaving the foundry, clean castings and apply 16 mils dry film thickness coating of coal-tar epoxy, unless otherwise specified or indicated on the Drawings.
- C. Miscellaneous Stainless Steel:
 - 1. Provide miscellaneous stainless steel items not specified herein as indicated on the Drawings or specified elsewhere. Fabricate and install in accordance with the best practices of the trade.
- D. Miscellaneous Structural Steel:
 - 1. Provide miscellaneous steel items not specified herein as indicated on the Drawings or specified elsewhere. Fabricate and install in accordance with the best practices of the trade.

PART 3 - EXECUTION

3.01 EXAMINATION

- A. Verification of Conditions: Contractor shall examine work in place to verify that it is satisfactory to receive the work of this Section. If unsatisfactory conditions exist, do not begin this work until such conditions have been corrected.

3.02 INSTALLATION

- A. Install products as indicated on the Drawings, and in accordance with shop drawings and manufacturer's printed instructions, as applicable except where specified otherwise.

END OF SECTION

SECTION 09 90 00

PAINTING AND COATING

PART 1 - GENERAL

1.01 DESCRIPTION

- A. This section includes the materials and application of painting and coating systems for buried and exposed surfaces.
- B. All articles to be painted or coated will be painted or coated in the place of manufacture, unless field painting and coating is absolutely necessary. The Engineer will make the determination. In the event that the paint or coating is damaged in the field, it will be touched up in the same manner as the original paint or coating applied in the place of manufacture.

1.02 RELATED WORK DESCRIBED ELSEWHERE

- A. All related work specified elsewhere, or in other codes or standards, will be as last revised, unless a specific date of issuance is called out in opposition to later revision date(s).
- B. Other sections of the technical specifications, not referenced below, shall also apply to the extent required for proper performance of this work.
 - 1. Ductile-Iron Pipe and Fittings: 33 11 13.15
 - 2. Manual Valves 33 12 16
 - 3. Underground Facilities Identification: 33 05 26
 - 4. Automatic Valves 40 92 13

1.03 SUBMITTALS

- A. Submit a Paint Plan for all proposed surfaces. The plan shall identify all materials and procedures, including proposed paint systems, names and experience of personnel to perform the work, proposed surface preparation specifications, required physical and environmental conditions to perform the work and proposed test methods and reporting for both factory and field applications. The plan shall also include proposed maintenance requirements for all surfaces. Samples of field applied paint and coating finishes, colors, and covering shall also be provided. The paint plan and all samples shall be provided at least 60 days prior to start of such finishing operations.

1.04 APPROVED MANUFACTURERS

- A. All materials shall be as manufactured by the companies listed herein or approved equal.
 - 1. Tnemec,
 - 2. Carboline,
 - 3. Dunn-Edwards,

4. International Protective Coatings,
5. Rust-Oleum Corporation,
6. 3M Minnesota Mining and Manufacturer

1.05 COATINGS

- A. All specified materials must meet and comply with National Sanitation Foundation (NSF) and California current air quality regulations governing architectural and industrial coatings.
- B. Organic Zinc Primer
 - Tnemec 90-97
 - Carboline 621
 - Rust-Oleum 7400 System Zinc Chromate Primer
 - Devoe CC 302V
 - International Protective Coatings – Interzinc 52
- C. Epoxy Coating
 1. Field Applied
 - Tnemec Series N69 Epoxoline II
 - Carboline 187
 - Rust-Oleum 9100 High Performance Epoxy Devoe
 - BR235H International Protective Coatings – Interguard
 - 475HS
 2. Field or Factory Applied
 - Tnemec Series 140 NSF 61
 - International Protective Coatings – Interline 850 or 925
 - Devoe BR235H
 3. Factory Applied
 - 3M Scotchkote 206N Fusion Bonded Epoxy
 4. Manholes and Lift Stations, Field Applied
 - Raven 405
 - Hydro-Pox GL 212
 - Elastuff 120 hydrophobic Polyurethane Elastomer with Uni-Tile Sealer
- D. Polyurethane
 - Tnemec Series 1075
 - Carboline 134 HS VOC
 - Devoe 379H
- E. Bituminous Mastic Epoxy
 - Carboline 300M
 - Tnemec Series 46H413
 - Rust-Oleum Devoe Devtar SA
- F. Acrylic Primer
 - International Intercryl 520
 - Tnemec Series 26 TyCRYL
 - Rust-Oleum Devoe Devflex 4020

- G. Acrylic Polymer
Tnemec Series 1029

1.06 PAINT SCHEDULE

- A. Aboveground or exposed facilities shall be color-coded per APWA Uniform Color Code for domestic water, recycled water facilities, or wastewater facilities.
- B. Domestic Water System
 - 1. Piping and Equipment: Safety Blue
 - 2. Public Fire Hydrants: Safety Yellow, unless different color is required by local fire jurisdiction. Comply with fire jurisdiction.
 - 3. Private Fire System: Safety Red
 - 4. Guard Posts / Bollards: Safety Yellow

1.07 PERMITS

- A. All work shall conform to the specifications and requirements of the State of California Department of Transportation, the County, the city having jurisdiction, or and other agencies involved. The contractor shall keep a copy of all the required permits in the job site and comply with all the terms and conditions of said permits.

PART 2 - MATERIALS

2.01 ZINC PRIMER

- A. All primer shall contain not less than 79.60% zinc in dry film.
- B. Primer shall be of a different color than the outer coating.

2.02 BITUMINOUS MASTIC

- A. Bituminous mastic shall be coal-tar pitch based.
- B. Bituminous mastic shall have a minimum of 68% solids by volume.

2.03 EPOXY COATING FOR WATER SYSTEM

- A. Epoxy shall meet current local air quality standards and shall not be less than 65% solids.
- B. All coatings and pigments to be used on domestic water services shall have NSF approval for use with domestic water.

PART 3 - EXECUTION

3.01 SURFACE PREPARATION

- A. Do not sandblast or prepare more surface area than can be coated in one day. Remove all sharp edges, burrs, and weld spatter. Do not sandblast epoxy-coated pipe that has already been factory coated.
- B. Surface preparation shall conform with the SSPC specifications as described below:

Solvent Cleaning	SP-1
Hand Tool Cleaning	SP-2
Power Tool Cleaning	SP-3
White Metal Blast Cleaning	SP-5
Commercial Blast Cleaning	SP-6
Brush-Off Blast Cleaning	SP-7
Pickling	SP-8
Near-White Blast Cleaning	SP-10
- C. Wherever the words “solvent cleaning,” “hand tool cleaning,” “wire brushing,” or “blast cleaning” or similar words are used in these specifications or in paint manufacturer’s specifications, they shall be understood to refer to the applicable SSPC (Steel Structure Painting Council, Surface Preparation Specifications, ANSI A159.1) specifications listed above.

3.02 PAINTING SYSTEMS

- A. All materials of a specified painting system, including primer, intermediate, and finish coats, shall be produced by the same manufacturer. Thinners, cleaners, driers, and other additives shall be as recommended by the paint manufacturer for the particular coating system.
- B. Deliver all paints to the job site in the original, unopened containers.

3.03 SURFACES NOT TO BE COATED

- A. The following surfaces shall not be painted and shall be protected during the painting of adjacent areas:
 1. Mortar-coated pipe and fittings
 2. Stainless steel
 3. Metal letters
 4. Nameplates
 5. Grease fittings
 6. Brass and copper, submerged
 7. Buried pipe, unless specifically required in the piping specifications
 8. Bronze meters and strainers

3.04 PROTECTION OF SURFACES NOT TO BE PAINTED

- A. Remove, mask, or otherwise protect hardware, lighting fixtures, switch plates, aluminum surfaces, machined surfaces, couplings, shafts, bearings, nameplates on machinery, and other surfaces not intended to be painted. Provide drop cloths to prevent paint materials from falling on or marring adjacent surfaces. Protect working parts of mechanical and

electrical equipment from damage during surface preparation and painting process.
Mask openings in motors to prevent paint and other materials from entering the motors.

3.05 FIELD TOUCH UP OF MANUFACTURER-APPLIED PRIME COATS

- A. Surfaces that are primed at the place of manufacture shall receive a field touch-up of organic zinc primer to cover all scratches or abraded areas.

3.06 BITUMINOUS MASTIC

- A. Buried metal (flanges, non-stainless steel nuts and bolts, flexible couplings, exposed reinforcing steel, etc.) shall be coated with a minimum of 20 mils of bituminous mastic.
- B. All surfaces coated with bituminous mastic shall be covered with 8 mil polyethylene wrap per Section 331113.15, after applying the bitumastic.

3.07 EPOXY COATING OF METAL

- A. Only those metal surfaces specifically called out shall be epoxy coated.
- B. Epoxy lining and coating of valves shall be per AWWA C550 and Section 331216 Manual Valves. All valves shall be lined and coated by manufacturer.
- C. Surfaces to be epoxy coated shall follow the surface preparation requirements as recommended by the manufacturer.
- D. Surfaces shall be coated with organic zinc primer to a dry film thickness of 3 mils.
- E. Apply two coats of epoxy paint (4 mils each) to the primed surface. The manufacturer's recommended drying time between coats shall be followed.
- F. Prepare multiple-component coatings using all of the contents of the container for each component as packaged by the paint manufacturer. Do not use partial batches. Do not use multiple-component coatings that have been mixed beyond their pot life. Provide small quantity kits for touch up painting and for painting other small areas. Mix only the components specified and furnished by the paint manufacturer. Do not intermix additional components for reasons of color or otherwise, even within the same generic type of coating.

3.08 EPOXY COATING OF CONCRETE

- A. Only those metal surfaces specifically called out shall be epoxy coated.
- B. Surfaces to be epoxy coated shall follow the surface preparation requirements as recommended by the manufacturer.
- C. Apply one or more coats of epoxy paint as needed to achieve a uniform coating thickness of 70 mils, minimum. The manufacturer's recommended drying time between coats shall be followed.
- D. Prepare multiple-component coatings using all of the contents of the container for each component as packaged by the paint manufacturer. Do not use partial batches. Do not

use multiple-component coatings that have been mixed beyond their pot life. Provide small quantity kits for touch up painting and for painting other small areas. Mix only the components specified and furnished by the paint manufacturer. Do not intermix additional components for reasons of color or otherwise, even within the same generic type of coating.

3.09 DRY-FILM THICKNESS TESTING

- A. Measure coating thickness specified for metal surfaces with a majestic-type dry-film thickness gage. Test the finish coat (except zinc primer and galvanizing) for holidays and discontinuities with an electrical holiday detector, low-voltage, wet-sponge type. Measuring equipment shall be provided by the contractor. Provide detector as manufactured by Tinker and Razor or K-D Bird Dog. Provide dry-film thickness gage as manufactured by Mikrotest or Elcometer. Check each coat for the correct dry-film thickness. Do not measure within eight hours after application of the coating.
- B. If the item has an improper finish color or insufficient film thickness, the surface shall be cleaned and top coated with the specified paint material to obtain the specified color and coverage. Visible areas of chipped, peeled, or abraded paint shall then be primed and finish coated in accordance with the specifications. Work shall be free of runs, bridges, shiners, laps, or other imperfections.

3.10 WARRANTY INSPECTION

- A. Warranty inspections shall be conducted during the eleventh (11th) month following completion of all coating work. Personnel present during the pre-construction meeting shall be present at this inspection. All defective work shall be repaired per the approved work plan as submitted by the contractor.

END OF SECTION

SECTION 22 05 53

UNDERGROUND FACILITIES IDENTIFICATION

PART 1 - GENERAL

1.01 DESCRIPTION

- A. This section describes special identification, markings, materials and their installation procedures for underground water, sewer and recycled water facilities.

1.02 RELATED WORK SPECIFIED ELSEWHERE

- A. All related work specified elsewhere, or in other codes or standards, will be as last revised, unless a specific date of issuance is called out in opposition to later revision date(s).
- B. Other sections of the technical specifications, not referenced below, shall also apply to the extent required for proper performance of this work.
 - 1. Ductile Iron Pipe and Fittings: 33 11 13.15
 - 2. Automatic Valves: 40 92 13
 - 3. Manual Valves: 33 12 16
 - 4. Fire Hydrants: 40 05 81.13

1.03 APPROVED MANUFACTURERS

- A. Warning Tape and Pipe Sleeves
 - 1. Griffolyn, Division of Reef Industries
 - 2. Terra Tape, Division of Reef Industries
 - 3. T. Christy Enterprises, Inc.
- B. Witness Markers
 - 1. Carsonite Water Line Markers
 - 2. Or approved equal

1.04 IDENTIFICATION

- A. Ductile iron pipe (DIP) shall be encased within an 8-mil polyethylene sleeve per Section 33 11 13.15. Sleeves for potable water pipe shall be blue with the words "POTABLE WATER" or "DOMESTIC WATER" stenciled in 2-inch black letters. Sleeves for recycled water pipe shall be purple with the words "RECYCLED WATER" stenciled in 2-inch black letters.
- B. HDPE pipe carrying potable water shall be black with blue stripe(s), or shall be installed with a blue 8-mil polyethylene sleeve as for DIP.

- C. PVC pipe carrying potable water shall be blue in color or shall be installed with a blue 8-mil polyethylene sleeve as for DIP.
- D. All water service lateral lines shall be colored polyethylene, colored PVC or copper-encased within a color-coded 8-mil polyethylene sleeve. Pipe or sleeve shall be blue in color for all domestic water services and purple in color for all recycled water services.

1.05 VALVE BOXES

- A. Valve boxes for domestic water systems shall be as specified in Section 33 12 16.
- B. All valve boxes installed in unpaved areas (open space areas) shall be marked with a witness pole, in addition to the above referenced markings.

1.06 COLOR AND PAINTING SCHEDULE

- A. Comply with the APWA Uniform Color Code for underground utilities.
- B. Domestic water facilities shall be blue, with the exception of fire hydrants which shall be painted as specified in Section 40 05 81.13. Witness poles for domestic water lines, valves and appurtenances shall be blue.

PART 2 - MATERIALS

2.01 BURIED PIPING WARNING TAPE

- A. Plastic warning tape shall be an inert plastic film specifically formulated for prolonged underground use. The minimum thickness shall be 4 mils and the minimum width of the tape shall be 6 inches. Printing shall be a minimum of 2-inch block letters.
- B. Warning tape for domestic water pipelines shall be blue with black printing having the words "CAUTION: DOMESTIC WATER-LINE BURIED BELOW."

PART 3 - EXECUTION

3.01 INSTALLATION OF PIPE WARNING TAPE

- A. Warning tapes shall be installed a minimum 1-foot above and centered on the pipe. The warning tape shall be installed continuously for the length of the pipe and shall be fastened to valve stem casings or other vertical appurtenances by plastic adhesive tape.

3.02 INSTALLATION OF WITNESS MARKERS

- A. Witness markers shall be installed over pipe in unpaved open-space areas at intervals not greater than 200 feet. Place markers at appurtenances, including but not limited to valves, air release/vacuum breaks, dead ends, inflection points and tees.
- B. Witness markers shall be embedded into the soil at least 18-inches and shall be equipped with a barb or other such device to secure it in the surrounding soil.

END OF SECTION

SECTION 22 11 13

COPPER, BRASS, AND BRONZE PIPE FITTINGS AND APPURTENANCES

PART 1 - GENERAL

1.01 DESCRIPTION

- A. This section includes materials and installation of copper, brass, and bronze pipe, fittings and appurtenances.

1.02 APPROVED MANUFACTURERS

- A. All materials shall be the appropriate model number specified as manufactured by the companies listed herein or approved equal.

- B. Copper Tubing

- 1. Cambridge Lee

- C. Service Saddle

- 1. Ford
 - 2. Jones
 - 3. Mueller
 - 4. A.Y. McDonald

- D. Corporation Stop

- 1. Ford
 - 2. Jones
 - 3. Mueller
 - 4. A.Y. McDonald

- E. Meter/Angle Stop

- 1. Ford
 - 2. Jones
 - 3. Mueller
 - 4. A.Y. McDonald

- F. Insulating Pipe Bushings, Unions, or Couplings

- 1. Pipeline Coating and Engineering Co.
 - 2. 1566 East Slauson Avenue, Los Angeles
 - 3. Smith Blair
 - 4. Pipe Seal and Insulator Company

PART 2 - MATERIALS

2.01 COPPER TUBING

- A. Copper tubing shall conform to the requirements of ASTM B 88 for seamless copper water tube. Piping located aboveground or suspended within vaults shall be Type L. Buried piping shall be Type K. Copper pipe shall be of domestic manufacture. Compression joints for connections are allowed if approved by the Engineer.
- B. If indicated in soils report, all copper lines shall be encased within an 8-mil polyethylene sleeve. Sleeves shall be color coded per Section 33 05 26.

2.02 BRASS PIPE, NIPPLES, AND FITTINGS

- A. Short threaded nipples, brass pipe and fittings shall conform to ASTM B 43, regular wall thickness, except that nipples and pipe of sizes 1-inch and smaller shall be extra strong. Threads shall conform to ANSIB2.1.

2.03 BRONZE APPURTENANCES

- A. All items specified herein shall be manufactured of bronze conforming to ASTM B 62, "Composition Brass or Ounce Metal Castings."
- B. All size service saddles shall be of the double-strap type for any type of pipe. The straps (or bails) shall be flat and shall be manufactured of bronze for ACP and of stainless steel for C900 PVC and ductile iron pipe. The body shall be manufactured of bronze and shall be tapped for an iron pipe thread. The seal with the pipe shall be affected with either a rubber gasket or an O-ring.
- C. Corporation stops shall be ball valve type and shall be manufactured of bronze. The inlet fitting shall be a male iron pipe thread when used with saddle and the outlet connection shall be a compression type.
- D. Copper setters shall be for 1-inch and 2-inch meter sizes or as approved by the Engineer and using lead free solder. The inlet and outlet service line connections shall be for 1-inch services and for horizontal connections using compression type connections. A dual purpose type connection may be used for the outlet service line connection. The meter connection shall have a key type inlet and outlet valve. When using a copper setter that is sized larger than the meter, use appropriate adaptors as approved by the Engineer. Copper setters shall be 15-inches in height with a lock wing.

PART 3 - EXECUTION

3.01 COPPER TUBING AND FITTINGS

- A. Cut tubing square using a cutter designed for cutting copper tubing and remove burrs. Clean both the inside and outside of fitting and pipe ends with steel wool and muriatic acid. Prevent annealing of fittings and tubing when making connections. Do not miter joints for elbows or notch straight runs of pipe for tees.

- B. Threads of fittings shall receive a liberal coating of pipe thread compound conforming with the requirements of ASTM B88, Type K.
- C. Any damage to the fitting including but not limited to evidence of overtightening, misaligned threads, burring or scarring of machined faces, or any evidence of leakage shall be cause for rejection. If a leak is found to be caused by debris, the debris shall be cleared and the fitting visually inspected for damage before being charged. If the leak recurs upon charging of the line, the fitting shall be removed and replaced whether or not the cause can be determined.
- D. Bends in soft copper tubing shall be long sweep. Shape bends with shaping tools. Form bends without flattening, buckling, or thinning the tubing wall at any point.
- E. Buried piping shall be installed with some slack to provide flexibility in the event of a load due to settlement, expansion or contraction. A MINIMUM COVER OF 24 INCHES BELOW THE FINISHED STREET GRADE SHALL BE ADHERED TO. The tubing is to be bedded and covered with sand or select material as determined by the Engineer.
- F. All domestic service laterals shall be 1-inch minimum size copper tubing. End connections shall be compression type.
- G. All 2-inch size services shall be installed with straight lengths of soft copper water tube Type K. End connections shall be compression type.
- H. The service line shall extend perpendicular to the centerline of the street from the water main to the meter stop or structure, except in a cul-de-sac, where the service shall run in a straight line from the water main to the meter stop.
- I. The service line shall be placed within an 8-mil polyethylene sleeve, color-coded for the type of service. The ends and splices in the sleeve shall be sealed with 20-mil tape.

3.02 SERVICE SADDLE

- A. The service saddle shall be no closer than 18 inches to a valve, coupling, joint, or fitting.
- B. The surface of the pipe shall be filed to remove all loose material and to provide a hard, clean surface before placing the service saddle.
- C. The service saddle shall be tightened per manufacturer's recommendation. Care shall be used to prevent damage or distortion of either the corporation stop or service saddle by over tightening.
- D. The tap into the pipe shall be made in accordance with the pipe manufacturer's recommendation.

3.03 INSTALLING FLANGE BOLTS AND NUTS

- A. Lubricate bolt threads with anti-seize compound prior to installation.
- B. Set flanged pipe with the flange bolt holes straddling the pipe horizontal and vertical centerlines.

3.04 INSULATING BUSHINGS AND UNIONS

- A. Pipe or fittings made of nonferrous metals shall be isolated from ferrous metals by nylon insulating pipe bushings, union, or couplings.

3.05 BACKFILL MATERIAL

- A. The pipe zone material for all service laterals shall be compacted sand per Section 31 23 00.

END OF SECTION

SECTION 22 11 19

CHLORINATION OF DOMESTIC WATER MAINS AND SERVICES FOR DISINFECTION

PART 1 - GENERAL

1.01 DESCRIPTION

- A. This section describes requirements for disinfection of domestic water mains, services, appurtenances and connections by chlorination and all requirements for bacterial testing of the facilities, and obtaining subsequent clearances for operations issued by the District and all state and local health agencies having jurisdiction.

1.02 RELATED WORK SPECIFIED ELSEWHERE

- A. All related work specified elsewhere, or in other codes or standards, will be as last revised, unless a specific date of issuance is called out in opposition to later revision date(s).
- B. Other sections of the technical specifications, not referenced below, shall also apply to the extent required for proper performance of this work.
 - 1. General Piping Requirements: 33 11 00

1.03 REFERENCED STANDARD

- A. All domestic water mains, water services, attached appurtenances, and connections, if any, shall be disinfected in accordance with AWWA C601, C651-14 and as specified herein.

1.04 APPLICATION

- A. Before being placed in service or connected to existing facilities, all facilities shall be disinfected using hypochlorite (chlorine). Chlorine may be applied by direct liquid chlorine feed, or calcium hypochlorite tablets per AWWA C651.

1.05 RETESTING

- A. Retesting of the system may be required if 90 days have passed between the date of testing and acceptance by the District.

1.06 SUBMITTALS

- A. The Contractor shall submit a Disinfection Plan per Section 01 30 00. The Disinfection Plan shall address trench treatment, flushing, chlorination, sampling and bacteriological testing procedures, and dechlorination procedures per Section 22 11 23 and AWWA C651. The Contractor shall submit this plan 7 working days prior to beginning this work.

PART 2 - MATERIALS

2.01 HYPOCHLORITE TABLETS

- A. Calcium hypochlorite or sodium hypochlorite tablets shall have an average weight of 0.009 pounds each and shall contain not less than 70% of available chlorine.

2.02 LIQUID CHLORINE

- A. Liquid Chlorine shall conform to AWWA C651 4.1.1 or AWWA C651 4.1.2.

PART 3 - EXECUTION

3.01 PROCEDURE

- A. Contractor shall notify the District two (2) working days prior to chlorination of facilities.
- B. All required corporation stops and other plumbing materials necessary for chlorination or flushing of the main shall be installed by and at the expense of the contractor.
- C. All mains shall be thoroughly flushed prior to disinfection. Only the direct chlorine gas fuel method shall be used if contaminating material has entered the line.
- D. Every service connection served by a main being disinfected shall be tightly shutoff at the curb stop before water is turned into the main. Care shall be taken to expel all air from the main and services during the filling operation.
- E. Clean all pipe, fittings and valves and swab with chlorine disinfection prior to assembly.
- F. Water shall be fed slowly into the pipeline with chlorine applied in amounts to produce a dosage of not less than 50 ppm nor more than 100 ppm in all sections of the pipeline and appurtenances.
- G. Open and close valves in lines being disinfected several times during the contact period to disinfect gates.
- H. Treated water shall be retained in the system for a minimum of 24 hours and shall contain a chlorine residual of not less than 25 ppm at the end of the retention period in all sections being disinfected.

3.02 CONCURRENT TESTING

- A. Disinfecting the mains and appurtenances, hydrostatic testing, and preliminary retention may run concurrently for the required 24-hour period, but in the event there is leakage and repairs are necessary, additional disinfection shall be made by injection of chlorine solution into the line as provided hereinafter.

3.03 ADDITIONAL DISINFECTION

- A. If the tests are not satisfactory the contractor shall provide additional disinfection as required by AWWA C651.

3.04 FLUSHING

- A. After chlorination, the water shall be flushed from the line, in accordance with AWWA C651, at its extremities until the replacement water tests are equal chemically and bacteriologically to those of the permanent source of supply. The chlorinated water may be used later for testing other lines, or if not so used, shall be disposed of by the contractor, as designated in AWWA C651, Section 6.2. The contractor shall be responsible for all costs to dechlorinate the water and shall obtain all permits before discharging water into storm drain or watercourse. Discharging shall be in accordance with State and local regulations. The District will not be responsible for loss or damage resulting from such disposal.

3.05 BACTERIOLOGICAL TESTING

- A. The sampling and bacteriological testing procedure for the newly disinfected facilities shall be in accordance with AWWA C651, Section 5.1. The sampling and bacteriological testing procedure for main repairs shall be in accordance with AWWA C651, Section 4.7. The contractor shall provide sampling containers approved by the District and the contractor shall notify the District two (2) working days prior to collecting samples. A District representative shall be present during the collection of the samples. The contractor shall deliver the samples to a California DDW approved testing laboratory. The contractor shall be required to provide the District with signed copies of all test results and chain of custody documents.
- B. All mains and services must successfully pass bacteriological tests prior to connecting to the existing system. Services must be tested per the following procedure. A minimum of 10 percent of water services or 1 water service lateral, whichever is greater, must be tested. If this first water service test fails, then a minimum of 20 percent of water services or 2 water service laterals, whichever is greater, must be tested.

3.06 CUTTING INTO EXISTING MAINS

- A. Following the opening of an existing domestic water main, the interior of all accessible pipes and fittings shall be swabbed with a hypochlorite solution. The drained portion of the existing line and any new section shall be flushed from two directions toward the cut-in, if possible.

END OF SECTION

SECTION 31 05 16

PRECAST CONCRETE STRUCTURES

PART 1 - GENERAL

1.01 DESCRIPTION

- A. This section includes the materials, manufacture, and installation of precast concrete vaults, vault frames and covers.

1.02 RELATED WORK SPECIFIED ELSEWHERE

- A. All related work specified elsewhere, or in other codes or standards, will be as last revised, unless a specific date of issuance is called out in opposition to later revision date(s).
- B. Other sections of the technical specifications, not referenced below, shall also apply to the extent required for proper performance of this work.
 - 1. 31 23 00 Trenching, Backfilling and Compacting
 - 2. 03 30 00 Cast-in-Place Concrete

1.03 REFERENCES

- A. Standard Specifications of the State of California Department of Transportation, 2018 Edition.
- B. ASTM C478, Specification for Precast Reinforced Concrete Manhole Sections.
- C. ASTM A159, Specification for Automotive Gray Iron Castings.
- D. ASTM A48, Specification for Gray Iron Castings.
- E. ASTM A536, Specification for Ductile Iron Castings.
- F. ASTM C913, Specification for Precast Concrete Water and Wastewater Structures

1.04 APPROVED MANUFACTURERS

- A. Precast Vaults
 - 1. Christy
 - 2. Utility Vault
 - 3. Jensen Precast
- B. Meter Boxes
 - 1. Christy
- C. Joint Sealing Compound
 - 1. Henry Company (Ram-Nek)

- 2. Conseal
- D. Waterproofing
 - 1. Grace Dehydratine 4
- E. Lids and Covers
 - 1. Christy
 - 2. Utility Vault
 - 3. Phoenix Iron Works

1.05 SUBMITTALS

- A. Provide submittals in accordance with Section 01 30 00.
- B. Provide shop drawings or catalog cut sheets showing dimensions of units to be provided. Submit manufacturer's product literature.

1.06 FRAMES AND COVERS

- A. All precast sections shall be provided with fabricated aluminum or steel frames and covers as specified or shown on the drawings and shall be built up so that the cover is flush with the surrounding surface unless otherwise specified on the drawings or by the District representative in the field.

1.07 METER BOXES

- A. Precast concrete meter boxes for meters 2-inch and smaller shall be purchased and installed by the contractor unless noted otherwise. Meter box lid shall be polymer type.
- B. Sizes shall be as specified on the standard drawings for the various sizes and types of services.

1.08 VAULTS

- A. The contractor shall provide precast concrete vaults for meter installations 3-inch and larger and other applications as shown on the Contract Drawings.

PART 2 - MATERIALS

2.01 PRECAST CONCRETE VAULT

- A. Precast concrete vaults and covers shall be manufactured in a plant especially designed for that purpose and shall conform to the shapes and dimensions indicated on the plans.
- B. Design loads shall consist of dead load, live load, impact, and in addition, loads due to water table and any other loads which may be imposed upon the structure. Live loads shall be for H-20 per AASHTO standard specifications for highway bridges. Design wheel load shall be 16 kips. The live load shall be that which produces the maximum shears and bending moments in the structure.

- C. Concrete shall be Class A conforming to Section 03 30 00.
- D. Vault floor shall be treated such that a non-skid surface is provided.
- E. Vault floor shall contain grooved channels to convey drainage to a sump area.
- F. Wall openings shall be sized to permit sealing the annular space with a mechanical seal (Calpico Pipe Lynx, EnPro Corporation Link-Seal, or approved substitute).

2.02 VAULT BASES

- A. Concrete used in pouring the manhole base shall be Class A concrete per section 03 30 00, Cast-in-Place Concrete.
- B. Precast bases are acceptable in lieu of field-formed bases with the approval of the Engineer.

2.03 METER BOX COVERS

- A. All meter box covers shall be furnished with rectangular reading lids.
- B. Concrete meter box covers shall be installed in all locations.

2.04 VAULT FRAMES AND COVERS

- A. Vault frames and covers shall be fabricated aluminum with stainless steel hardware.
- B. Covers shall be fabricated with supports to resist deflection.
- C. All covers shall be hinged providing access to the entire vault. Covers shall have spring hydraulic assists.
- D. All covers shall be equipped with a hold-open mechanism with safety chains.
- E. All covers shall be equipped with a flush, locking device with locking eyes up.
- F. All frames and covers shall be equipped with a "ladder up" to provide access assistance.
- G. All covers must be H20 traffic rated for equipment or vehicle loading, unless specified otherwise by the District Engineer.

2.05 GASKET SEALS

- A. Preformed plastic sealing gaskets conforming to Federal Specification SS-S-210A; Ram-Nek or equal.

2.06 JOINT SEALING COMPOUND

- A. Compound shall be Quik-Seal by Associated Concrete Products; Ram-Nek by Henry Company; or approved equal.

2.07 CEMENT-MORTAR GROUT

- A. Grout for watertight joints between precast sections shall be composed of one part Portland cement to two parts of clean, well-graded sand of such size that all passes a No. 8 sieve. Cement, aggregate and water for mortar shall conform to the applicable provisions of section 03 30 00.

2.08 EPOXY GROUT

- A. Epoxy grout shall be used in repairing manhole, vault and concrete base surfaces. Epoxy grout shall be made with epoxy and sand. The sand shall be clean, bagged, graded and kiln-dried silica sand. The prepared grout shall wet the concrete surface and provide proper adhesion, or a coat of epoxy shall be applied prior to placing epoxy grout. The epoxy bonding compound shall be as specified in Section 03 30 00.

PART 3 - EXECUTION

3.01 EARTHWORK

- A. Excavation and backfill for precast concrete vaults shall be in accordance with Section 31 23 00 and the requirements herein.
- B. The contractor shall prepare an excavation large enough to accommodate the structure and permit grouting of openings and backfilling operations.
- C. The bottom of the structure shall be placed on 12- inches of compacted, crushed rock sub-base, graded level and to the proper elevation as shown on the plans, unless otherwise indicated by the Engineer.

3.02 INSTALLATION

- A. Openings or "knockouts" in precast concrete vaults shall be located as shown on the drawings and shall be sized sufficiently to permit passage of the largest dimension of pipe and/or coupling flange. Upon completion of installation, all voids or openings in the vault walls around pipes shall be filled with 3,000-psi concrete or mortar, using an approved epoxy for bonding concrete surfaces.
- B. After the structure and all appurtenances are in place and approved, backfill shall be placed such that finished grade is sloped away from vault (in unpaved areas) or such that vault is flush with finished grade (in paved areas) to the original ground line or to the limits designated on the plans, unless otherwise indicated by the Engineer.
- C. All joints between precast concrete vault sections shall be made watertight using preformed mastic material. The sealing compound shall be installed according to the manufacturer's recommendations to provide a watertight joint which remains impermeable throughout the design life of the structure. All joints shall be filled with dry-pack non-shrink grout.
- D. Frames and covers shall be built up so that the cover is flush with the surrounding surface unless otherwise specified on the drawings or by the Owner's representative in the field. The contractor is responsible for placing the cover at the proper elevation where paving is to be installed and shall make all necessary adjustments so that the cover meets these requirements.

3.03 METER BOXES

- A. Boxes shall be set true to line and to the grade of the top of the curb, sidewalk, or surrounding graded area.
- B. Meter boxes are not to be set until fine grading for landscape grading has been completed.
- C. Retaining walls may be required around meter boxes installed on slopes as determined by the Owner's representative.

END OF SECTION

SECTION 31 05 19.13

GEOTEXTILE

PART 1 - GENERAL

1.01 DESCRIPTION

- A. This section includes: Geotextile, also called filter fabric, in applications such as soil material separation and subgrade stabilization.

1.02 REFERENCES

- A. AASHTO M 288 - Standard Specification for Geotextiles.
- B. ASTM
 - 1. D 4491 – Standard Test Methods for Water Permeability of Geotextiles by Permittivity.
 - 2. D 4533 – Standard Test Method for Trapezoid Tearing Strength of Geotextiles.
 - 3. D 4632 – Standard Test Method for Breaking Load and Elongation of Geotextiles (Grab Method).
 - 4. D 4751 – Test Method for Determining Apparent Opening Size of a Geotextile.
 - 5. D 6241 – Standard Test Method for Static Puncture Strength of Geotextiles and Geotextile-Related Products Using a 50-mm Probe.
- C. Corps of Engineers, COE CW - 02215 - Geotextiles Used as Filters.

1.03 SUBMITTALS

- A. Follow Section 01 30 00 – Contractor Submittals.
- B. Submit the standard manufacturer's catalog sheets and other pertinent information.

PART 2 - PRODUCTS

2.01 GEOTEXTILE

- A. Provide a geotextile (filter fabric) designed for use in geotechnical applications. The filter fabric shall provide a permeable layer or media while retaining the soil matrix.
- B. Use fabric which meets the physical requirements for Separation, High Survivability Level installation conditions as defined in AASHTO M 288.

2.02 WOVEN GEOTEXTILE FOR USE AS STABILIZATION FABRIC

- A. Geotextile for use as stabilization fabric shall be TenCate Mirafi 600X or approved equal.
- B. Properties:

1. Material: Woven, nonbiodegradable, fabric consisting only of continuous chain polymer filaments or yarns, at least 85 percent by weight polyolefin, polyesters or polyamide, formed into a dimensionally stable network.
2. Chemical Resistance: Inert to commonly encountered chemicals and hydrocarbons over a pH range of 3 to 12.
3. Physical Resistance: Resistant to mildew and rot, ultraviolet light exposure, insects and rodents.
4. Minimum Test Values:

Property	Value (Min.)	Test Method
Grab Tensile Strength	315 lbs.	ASTM D 4632
Grab Tensile Elongation	15%	ASTM D 4633
Trapezoidal Tear Strength	113 lbs.	ASTM D 4533
CBR Puncture Strength	900 lbs.	ASTM D 6241
Apparent Opening Size	40 sieve (0.43 mm)	ASTM D 4751
Permittivity (sec-1)	0.05	ASTM D 4491
Flow Rate	4.0 gpm/sq-ft	ASTM D 4491

PART 3 - EXECUTION

3.01 INSTALLATION

- A. Install geotextiles as shown on the Drawings and as per manufacturer's instructions.

END OF SECTION

SECTION 31 23 00

TRENCHING, BACKFILLING AND COMPACTING

PART 1 - GENERAL

1.01 DESCRIPTION

- A. This section includes materials, testing, and installation for trench excavation, backfilling, and compacting.

1.02 RELATED WORK SPECIFIED ELSEWHERE

- A. All related work specified elsewhere, or in other codes or standards, will be as last revised, unless a specific date of issuance is called out in opposition to later revision date(s).
- B. Other sections of the technical specifications, not referenced below, shall also apply to the extent required for proper performance of this work.

1.03 TESTING FOR COMPACTION

- A. Determine the density of soil in place by the use of a sand cone, drive tube, or nuclear tester.
- B. Determine laboratory moisture-density relations of existing soils by ASTM D 1557.
- C. Determine the relative density of cohesionless soils by ASTM D 2049.
- D. Sample backfill materials by ASTM D 75.
- E. Express "relative compaction" as the ratio, expressed as a percentage of the in place dry density to the laboratory maximum dry density.
- F. Compaction shall be deemed to comply with the specifications when no test falls below the specified relative compaction.
- G. The Owner will secure the service of a soils tester and pay the cost of initial testing. The Contractor will be responsible for the cost of all retests in failed areas. Test results will be furnished by the Owner's tester.

1.04 DEFINITIONS

- A. Pavement Zone. The pavement zone includes the asphalt concrete and aggregate base pavement section placed over the trench backfill.
- B. Street Zone. The street zone is the top 18 inches of the trench or depth determined by the jurisdictional agency immediately below the pavement zone in paved areas.

- C. Trench Zone. The trench zone includes the portion of the trench from the top of the pipe zone to the bottom of the street zone in paved areas or to the existing surface in unpaved areas.
- D. Pipe Zone. The pipe zone shall include the full width of trench from the bottom of the pipe or conduit to a horizontal level 12 inches above the top of the pipe. Where multiple pipes or conduits are placed in the same trench, the pipe zone shall extend from the bottom of the lowest pipes to a horizontal level 12 inches above the top of the highest or topmost pipe.
- E. Pipe Bedding. The pipe bedding shall be defined as a layer of material immediately below the bottom of the pipe or conduit and extending over the full trench width in which the pipe is bedded. Thickness of pipe bedding shall be as shown on the drawings or as described in these specifications for the particular type of pipe installed.

1.05 EXCESS EXCAVATED MATERIAL

- A. The Contractor shall make the necessary arrangements for and shall remove and dispose of all excess excavated material unless indicated differently in the special provisions for any job.
- B. It is the intent of these specifications that all surplus material not required for backfill or fill shall be properly disposed of by the Contractor at his expense at a proper disposal site.
- C. No excavated material shall be deposited on private property unless written permission from the owner thereof is secured by the Contractor. Before the Owner will accept the work, the Contractor shall file a written release signed by all property owners with whom he has entered into agreements for disposing excess excavated material, absolving the Owner from any liability connected therewith.
- D. The Contractor shall obtain a haul route permit from the city or agency having jurisdiction.

1.06 SAFETY

- A. All excavations shall be performed, protected, and supported as required for safety and in the manner set forth in the operation rules, orders, and regulations prescribed by the Division of Industrial Safety of the State of California.
- B. Barriers shall be placed at each end of all excavations and at such places as may be necessary along excavations to warn all pedestrians and vehicular traffic of such excavations. Lights shall also be placed along excavations from sunset each day to sunrise of the next day until such excavation is entirely refilled.
- C. No trench or excavation shall remain open during non-working hours. The trench or excavation shall be covered with steel plates, spiked in place, or secured with temporary A.C. pavement around the edges, or backfilled. A security fence shall be installed around the work area during non-working hours.
- D. The Contractor shall notify the Owner of all work-related accidents which may occur to persons or property at or near the project site, and shall provide the Owner with a copy of all accident reports. All accident reports shall be signed by the Contractor or its authorized

representative and submitted to the Owner's authorized representative within twenty-four (24) hours of the accident's occurrence.

1.07 ACCESS

- A. Unobstructed access must be provided to all driveways, water valves, hydrants, or other property or facilities that require routine use.

1.08 PERMITS

- A. All work shall conform to the specifications and requirements of the State of California Department of Transportation, the city having jurisdiction, and/or other agencies involved. The Contractor shall keep a copy of all the required permits in the job site and comply with all the terms and conditions of said permits.

1.09 SLOPE PROTECTION

- A. Slope protection shall be installed where shown on the plans. The installation of the slope protection shall be considered a part of the work, and the Contractor shall include the expense in his cost.

PART 2 - PRODUCTS

2.01 NATIVE EARTH BACKFILL

- A. Native earth, segregated from topsoil, shall be used for trench zone backfill.

2.02 IMPORTED BACKFILL MATERIAL

- A. Whenever the excavated material is not suitable for backfill, the Contractor shall arrange for and furnish suitable imported backfill material that is capable of attaining the required relative density.
- B. The Contractor shall dispose of the excess trench excavation as specified in the preceding section. Backfilling with imported material shall be done in accordance with the methods described herein.

2.03 GRANULAR MATERIAL

- A. Granular material shall be defined as soil having a minimum sand equivalent of 30 as determined in accordance with State of California, Division of Highways, Test "California 217," with not more than 20% passing a 200-mesh sieve.

2.04 IMPORTED SAND

- A. Imported sand shall have a minimum sand equivalent of 30 per State of California, Division of Highways, Test "California 217" with 100% passing a 3/8 inch sieve and not more than 20% passing a 200-mesh sieve. Certification that the sand meets this requirement shall be provided.

2.05 CRUSHED ROCK AND GRAVEL

- A. Crushed rock shall be the product of crushing rock or gravel. Fifty percent of the particles retained on a 3/8-inch sieve shall have their entire surface area composed of faces resulting from fracture due to mechanical crushing. Not over 5% shall be particles that show no faces resulting from crushing. Less than 10% of the particles that pass the 3/8-inch sieve and are retained on the No. 4 sieve shall be weatherworn particles. Gravel shall not be added to crushed rock.
- B. Gravel shall be defined as particles that show no evidence of mechanical crushing, are fully weatherworn, and are rounded. For pipe bedding, where gravel is specified, crushed rock may be substituted or added.
- C. Where crushed rock or gravel is specified in the bedding details on the plans, the material shall have the following gradations:

Sieve Size	1-1/2 Inch Max % Passing	1-inch Max % Passing	3/4 Inch Max % Passing
2"	100		
1-1/2"	90 – 100	100	
1"	20 – 55	90 – 100	100
3/4"	0 – 15	60 – 80	90-100
1/2"	-	-	30 – 60
3/8"	0 – 5	0 – 15	0 – 20
No. 4	-	0 – 5	0 – 5
No. 8	-	-	-

2.06 SAND-CEMENT SLURRY

- A. 1-Sack sand cement slurry shall consist of one sack (94 pounds) of Portland cement per cubic yard of sand and sufficient moisture for workability.
- B. 2-Sack sand cement slurry shall consist of two sacks (188 pounds) of Portland cement per cubic yard of sand and sufficient moisture for workability.

2.07 AGGREGATE BASE AND SUBBASE

- A. Aggregate base shall be Class 2 Aggregate Base (AB) as specified in Section 26 of the Standard Specifications, State of California, Department of Transportation, 2018 edition, 1-1/2-inch maximum unless otherwise indicated on the Drawings.

2.08 ASPHALT CONCRETE

- A. Asphalt concrete pavement shall be Type A Hot Mix Asphalt specified in Section 39 of the Standard Specifications, State of California, Department of Transportation, 2018 edition.

PART 3 - EXECUTION

3.01 COMPACTION REQUIREMENTS

- A. Compaction tests shall be performed at random depths and at 200-foot intervals and as directed by the Engineer.
- B. If the backfill fails to meet the specified relative compaction requirements, the Contractor shall rework the backfill until the requirements are met. The Contractor shall make all necessary excavations for density tests as directed by the Engineer. The compaction requirements of the city having jurisdiction or Caltrans shall prevail in all public roads. The Contractor will be responsible for the cost of all additional compaction tests in the reworked areas.
- C. Unless otherwise shown on the drawings or otherwise described in the specifications for the particular type of pipe installed, relative compaction in pipe trenches shall be as described below:
 - 1. Pipe zone and pipe base: 95% relative compaction
 - 2. Trench zone not beneath paving: 95% relative compaction
 - 3. Trench zone to street zone in paved areas: 95% relative compaction
 - 4. Street zone in paved areas: per agency requirements or 95% relative compaction. The most stringent agency requirements shall prevail
 - 5. Rock refill material for foundation stabilization: 90% relative density
 - 6. Rock refill for over excavation: 90% relative density

3.02 MATERIAL REPLACEMENT

- A. Removal and replacement of any trench and backfill material which does not meet the specifications shall be the Contractor's responsibility.

3.03 CLEARING AND GRUBBING

- A. Areas where work is to be performed shall be cleared of all trees, shrubs, rubbish, and other objectionable material of any kind which, if left in place, would interfere with the proper performance or completion of the contemplated work, would impair its subsequent use, or would form obstructions therein.
- B. Organic material from clearing and grubbing operations will not be incorporated in the trench backfill.
- C. Organic material from clearing and grubbing operations will be disposed of at a proper waste disposal facility.

3.04 SIDEWALK, PAVEMENT, AND CURB REMOVAL

- A. Saw cut bituminous or concrete pavements regardless of their thickness, and curbs and sidewalks prior to excavation for the structure in accordance with the requirements of the city, or agency having jurisdiction. Curbs and sidewalks that are damaged in the course of construction are to be cut and removed from joint to joint.
- B. Haul removed pavement and concrete materials from the site to a proper disposal facility. These materials are not permitted for use as trench backfill. If the material to be removed exceeds 50 cubic yards, the Contractor shall obtain a haul route permit from the city(s) having jurisdiction.

3.05 TRENCHING AND TUNNELING

- A. Excavation for pipe, fittings, and appurtenances shall be open trench to the depth and in the direction necessary for the proper installation of the facilities as shown on the plans.
- B. Trench banks shall be kept as near to vertical as possible and shall be properly braced and sheeted.
- C. Horizontal directional drilling, where used, shall be per Section 33 05 23.
- D. Tunneling will not be permitted.
- E. The use of a jack and bore may be employed for crossings.

3.06 BRACING

- A. The Contractor's design and installation of bracing and shoring shall be consistent with the rules, orders, and regulations of the State of California Construction Safety Orders.
- B. Excavations shall be so braced, sheeted, and supported that they will be safe such that the walls of the excavation will not slide or settle and all existing improvements of any kind, either on public or private property, will be fully protected from damage.
- C. The sheeting, shoring, and bracing shall be arranged so as not to place any stress on portions of the completed work until the general construction thereof has proceeded far enough to provide ample strength.
- D. Care shall be exercised in the drawing or removal of sheeting, shoring, bracing, and timbering to prevent the caving or collapse of the excavation faces being supported.

3.07 TRENCH WIDTHS

- A. Excavation and trenching shall be true to line so that a clear space of not more than 8 inches or less than 6 inches in width is provided on each side of the largest outside diameter of the pipe in place measured at a point 12 inches above the top of the pipe. For the purpose of this article, the largest outside diameter shall be the outside diameter of the bell on bell and spigot pipe or the pipe collar.
- B. Where the sewer trench width, measured at a point 12 inches above the top of the bell of the pipe, is wider than the maximum set forth above, the trench area around the pipe shall be backfilled with crushed rock, Class B concrete, or slurry to form a cradle for the pipe at the discretion of the Engineer.

3.08 LENGTH OF OPEN TRENCH

- A. The maximum allowable length of open trench shall be 400 feet, or the distance necessary to accommodate the amount of pipe installed in a single day, whichever is less. Within developed areas, the length of open trench may be restricted as determined by the encroachment permit from the city or the agency having jurisdiction.

3.09 GRADE

- A. Excavate the trench to the lines and grades shown on the drawings with allowance for pipe thickness and for pipe base or special bedding.
- B. The trench bottom shall be graded to provide a smooth, firm, and stable foundation that is free from rocks and other obstructions and shall be at a reasonably uniform grade.

3.10 CORRECTION OF OVER EXCAVATION

- A. Where excavation is inadvertently carried below the design trench depth, suitable provision shall be made by the Contractor to adjust the excavation, as directed by the Engineer, to meet requirements incurred by the deeper excavation.
- B. Over excavations shall be corrected by backfilling with approved bedding material, graded crushed rock or gravel and shall be compacted to provide a firm and unyielding subgrade or foundation, as directed by the Engineer.

3.11 DEWATERING

- A. The Contractor shall provide and maintain at all times during construction ample means and devices with which to promptly remove and properly dispose of all water from any source entering the excavations or other parts of the work. De-watering shall be done by methods that will ensure a dry excavation and preservation of the final lines and grades of the bottoms of excavations. Dewatering methods may include well points, sump points, suitable rock or gravel placed below the required bedding for drainage and pumping, temporary pipelines, and other means, all subject to the approval of the Engineer. Water shall be discharged in accordance with the requirements of the project's NPDES permit.
- B. In no event shall the sanitary sewer system be used as drains for dewatering the construction trenches.
- C. Dewatering shall commence when groundwater is first encountered and shall be continuous until such times as water can be allowed to rise. No concrete shall be poured in water, nor shall water be allowed to rise around the concrete or mortar until it has set at least eight hours.

3.12 FOUNDATION STABILIZATION

- A. Whenever the trench bottom does not afford a sufficiently solid and stable base to support the pipe or appurtenances, the Contractor shall excavate to a depth below the design trench bottom, as directed by the Engineer, and the trench bottom shall be backfilled with 3/4-inch rock and compacted to provide uniform support and a firm foundation.
- B. Where rock is encountered, it shall be removed to a depth at least 6 inches below grade and the trench shall be backfilled with 3/4-inch crushed rock to provide a compacted foundation cushion.
- C. If excessively wet, soft, spongy, unstable, or similarly unsuitable material is encountered at the surface upon which the bedding material is to be placed, the unsuitable material shall be removed to a depth as determined in the field by the Engineer and replaced by crushed rock.

3.13 EXCAVATED MATERIAL

- A. All excavated material shall not be stockpiled in a manner that will create an unsafe work area or obstruct sidewalks or driveways. Gutters shall be kept clear or other satisfactory measures shall be taken to maintain street or other drainage.
- B. In confined work areas, the Contractor may be required to stockpile the excavated material off-site, as determined by the project permits.

3.14 PLACING PIPE BEDDING

- A. Place the thickness of pipe bedding material over the full width of trench necessary to produce the required bedding thickness when the material is compacted to the specified relative density. Grade the top of the pipe bedding ahead of the pipe to provide firm, uniform support along the full length of pipe.
- B. Excavate bell holes at each joint to permit assembly and inspection of the entire joint.

3.15 BACKFILLING WITHIN PIPE ZONE

- A. Backfill per the detailed piping specification for the particular type of pipe and per the following.
- B. After pipe has been installed in the trench, place pipe zone material simultaneously on both sides of the pipe, keeping the level of backfill the same on each side. Carefully place the material around the pipe so that the pipe barrel is completely supported and that no voids or uncompacted areas are left beneath the pipe. Use particular care in placing material on the underside of the pipe to prevent lateral movement during subsequent backfilling.
- C. Compact material placed within 12 inches of the outer surface of the pipe by hand tamping only.

3.16 BACKFILL WITHIN TRENCH ZONE

- A. Compact per the detailed piping specification for the particular type of pipe and per the following.
- B. Push the backfill material carefully onto the backfill previously placed in the pipe zone. Do not permit free fall of the material until at least 2 feet of cover is provided over the top of the pipe. Do not drop sharp, heavy pieces of material directly onto the pipe or the tamped material around the pipe.
- C. The remaining portion of the trench to the street zone or ground surface, as the case may be, shall be backfilled, compacted and/or consolidated by approved methods to obtain the specified relative compaction.
 - 1. Compaction using vibratory equipment, tamping rollers, pneumatic tire rollers, or other mechanical tampers shall be done with the type and size of equipment necessary to accomplish the work. The backfill shall be placed in horizontal layers of such depths as are considered proper for the type of compacting equipment being used in relation to the backfill material being placed. Each layer shall be evenly spread, properly moistened, and compacted to the specified relative density. The Contractor shall repair or replace

any pipe, fittings, manholes, or structures damaged by the Contractor's operations as directed by the Engineer.

2. Consolidation of backfill performed by flooding, poling, or jetting shall obtain a relative compaction of the backfill material at least equal to that specified. When flooding, poling, or jetting methods are used, material for use as backfill shall be placed and consolidated in layers not exceeding 3-feet thick. Flooding, poling, or jetting methods shall be supplemented by the use of vibratory or other compaction equipment when necessary to obtain the required relative compaction. Care shall be taken in all consolidating operations to prevent the movement or floating of the pipe. Consolidation methods shall not be used where the backfill material is not sufficiently granular to be self-draining during and after consolidation, or where foundation materials may be softened or otherwise damaged by the quantities of water applied. The Contractor shall rectify any misalignment of the pipe because of consolidation operations as directed by the Engineer.

- D. If the excavated native material is too wet to achieve the required compaction, provide imported backfill or sand-cement slurry within the trench zone.

3.17 BACKFILL WITHIN STREET ZONE

- A. The street zone within roadbed areas shall be compacted using approved hand, pneumatic, or mechanical type tampers to obtain the required relative compaction.
- B. All work shall be done in accordance with the requirements and to the satisfaction of the city or the agency having jurisdiction.
- C. Flooding and jetting will not be permitted in this Zone.

3.18 SIDEWALK, PAVEMENT, AND CURB REPLACEMENT

- A. Replace bituminous and concrete pavement, curbs, and sidewalks damaged or removed during construction in accordance with the requirements of the city or the agency having jurisdiction.

3.19 SLOPE PROTECTION

- A. Where cutoff walls or concrete anchors are required, they shall be in accordance with the plans, with a minimum thickness of 12 inches. The wall shall extend at least 12 inches to undisturbed material on each side of the trench as excavated. Cemented rubble and concrete surface slope protection shall be a minimum of 4-inches thick.
- B. Wall or anchors shall be placed with a minimum horizontal spacing of:
 1. Not over 36 feet center to center on grades 25% to 35%
 2. Not over 24 feet center to center on grades 35% to 50%
 3. Not over 16 feet center to center on grades 50% and over
- C. Material used for construction of cutoff walls or concrete anchors shall consist of cast-in-place reinforced concrete or reinforced hollow unit masonry. When reinforced hollow unit masonry is used, all cells in the block shall be filled solidly with grout. A No. 4 reinforcing bar shall be placed in vertically in each row of cells and No. 9-gage wall mesh shall be

placed in each horizontal joint. In addition, a bond beam shall be placed at the top with two No. 4 bars.

- D. Where cutoff walls or concrete anchors are constructed of reinforced concrete, they shall have No. 4 reinforcing bars placed at 6-inches on center each way in the center of the wall. The bars shall extend full length and height of the wall.

END OF SECTION

SECTION 32 12 16

ASPHALT PAVING AND SEALS

PART 1 - GENERAL

1.01 SUMMARY

- A. Section Includes:
- B. Asphalt Paving
- C. Fog Seal
- D. Slurry Seal
- E. Related Sections:
 - 1. Section 31 23 00 – Trenching, Backfilling and Compacting

1.02 REFERENCES

- A. Standard Specifications, State of California, Department of Transportation (CalTrans), 2015 Edition (State Standard Specifications)

1.03 DESCRIPTION

- A. The Contractor shall pave or repave all road surfaces within public Right-of -Ways, private right-of-ways, driveways, drainage courses, and other surfaces as provided for in the Contract Documents. Except as provided for in the Contract Documents, all paving materials shall be constructed of asphalt concrete or an asphaltic emulsion, with or without aggregate.
- B. Paint binder (tack coat) shall be applied to the vertical surface of all structures to which new asphalt concrete will abut. Additionally, where the Contract Documents provide for the placement of new asphalt concrete over existing pavement surfaces, a tack coat shall be applied to the surface of the old pavement. Where called for in the Contract Documents, the surface of aggregate base shall receive a prime coat of liquid asphalt immediately prior to commencing paving operations.
- C. Miscellaneous areas shall be those areas or structures called for in the Contract Documents to be surfaced or constructed of asphalt concrete. Such areas shall include but not be limited to, drainage ditches, equipment pads, walkways, and asphalt dikes.
- D. Asphalt Dikes - Asphalt dikes shall be constructed to the line and grade provided for in the Contract Documents. Asphalt dikes whose continuous length exceeds 5 linear feet shall be constructed by the use of an extrusion machine.

1.04 FOG SEAL

- A. Where provided for in the Contract Documents, the Contractor shall apply a fog seal that covers the repaved trench section and the adjacent street pavement. The Engineer shall determine the limits of the fog seal application. Such fog seal shall be constructed in accordance with the provisions of Section 37, "Bituminous Seals" of the State Standard Specifications. The exact proportion of water to asphaltic emulsion shall be determined by the Contractor up to a maximum of one-part water to one-part asphaltic emulsion.

1.05 SLURRY SEAL COAT

- A. Where provided for in the Contract Documents, the Contractor shall construct a seal coat of asphaltic emulsion and screenings that covers the repaved trench section and the adjacent street pavement. The Engineer shall determine the limits of the seal coat application. Such seal coat shall be constructed in accordance with the provisions of Section 37, "Bituminous Seals" of the State Standard Specifications for a double seal coat. A Certificate of Compliance shall be submitted for all materials used in constructing the double seal coat.

1.06 SUBMITTALS

- A. Provide submittals in accordance with Section 01 30 00, Contractor Submittals.
- B. Submit certificates of compliance for materials provided under this section.

PART 2 - PRODUCTS

2.01 ASPHALT CONCRETE PAVEMENT

- A. Asphalt concrete pavement shall be in accordance with the provisions of Section 39, "Hot Mix Asphalt" of the State Standard Specifications and this Section. Except as provided for in the Contract Documents, a Certificate of Compliance shall be submitted in lieu of the testing and reporting requirements of the State Standard Specifications.
- B. Aggregate - Except as provided for in the Contract Documents, all asphalt concrete used in the construction of asphalt concrete pavements shall be Type "B" meeting the gradation requirements for ½-inch maximum, medium of Section 39-1.02E, "Aggregate" of the State Standard Specifications.
- C. Asphalt Binder - Asphalt binder for asphalt concrete shall be a steam refined asphalt, Grade PG 64-10, conforming with the requirements of Section 92, "Asphalts" of the State Standard Specifications. The percentage of asphalt binder in asphalt concrete pavement shall be between 5-½ percent and 6 percent by weight.
- D. Asphalt Concrete for Miscellaneous Areas - The gradation of aggregate for surfacing of miscellaneous areas shall be the same as for other areas. The percentage of asphalt binder shall be increased by 1-percent by weight over that percentage for asphalt concrete placed in roadways.

2.02 COLD-MIX ASPHALT CONCRETE

- A. General - Cold-mix asphalt concrete used in temporary paving applications shall be a plant mixed product conforming with the requirements of this Section. Cold-mix may be supplied directly from the batch plant or stockpiled on the job-site.
- B. Aggregate - Aggregate shall meet the following gradation requirements:

Sieve Size	Percentage Passing
½-inch	100
¼ - inch	95-100
No. 4	58-72
No. 8	34-48
No. 30	18-32
No. 50	13-23
No. 200	2-9

- C. Asphalt Binder - Asphalt binder for cold-mix asphalt shall be Type SC-800 in accordance with the requirements of Section 93, "Liquid Asphalts" of the State Specifications. The percentage of asphalt binder shall be between 4.8 and 7.5 percent.

2.03 PAINT BINDER AND PRIME COAT

- A. Paint Binder (Tack Coat) - Paint binder shall be Type RS-1 asphaltic emulsion conforming with the provisions of Section 94, "Asphaltic Emulsions" of the State Standard Specifications.
- B. Prime Coat - Prime coat shall be Type SC-70 liquid asphalt conforming with the provisions of Section 93, "Liquid Asphalts" of the State Standard Specifications.

PART 3 - EXECUTION

3.01 ASPHALT PAVING

- A. Upon completion of all underground construction, including but not limited to trench backfill and aggregate base, the Contractor shall construct the final asphalt concrete surface. Such asphalt concrete surface shall be of the same depth, or greater, as the existing surface material. In no case shall the new asphalt concrete be less than 2-inches in depth.
- B. All valve boxes, manholes, monument boxes, and other adjustable structures shall be brought to grade prior to placing the final lift of asphalt concrete. Where the distance between the edge of the new pavement and the existing edge of pavement, existing curb or gutter lip, or asphalt dike is less than 2 linear feet, the existing pavement shall be removed and replaced to the edge of pavement, existing curb or gutter lip or asphalt dike.
- C. All temporary paving material, loose aggregate base, and other deleterious material shall be removed from the trench of the underlying surface. The surface of the aggregate base or sand cement slurry backfill and all abutting surfaces shall be prepared by spraying with a paint binder at a rate of 0.25 gallons per square yard. The Contractor shall prevent overspray onto adjacent pavement surfaces and other surfaces not scheduled to be paved. Paint binder shall not be tracked out of the work area by vehicles or equipment.

- D. Hot asphalt concrete shall be placed in the area to be paved and compacted by the use of rollers or vibratory plate type compaction equipment. The use of vibratory plate compaction equipment shall be limited to projects whose area totals less than 100 square feet and/or those areas where insufficient space is available for the operation of vibratory rollers. All spreading and compacting operations shall be in accordance with the provisions of Section 39, "Hot Mix Asphalt" of the State Standard Specifications except that tolerances for trench repairs will be measured by the use of a straight edge of sufficient length to span the full width of the trench plus 2-feet on each side of the trench line.
- E. If the total depth of asphalt paving exceeds 2-½ inches, the asphalt shall be laid in a minimum of 2 lifts with the maximum lift equaling 2-½ inches. The minimum thickness of any lift of asphalt concrete shall be equal to twice the maximum size aggregate in the asphalt concrete mix. Each lift shall be fully compacted and finished prior to placing the next lift except that the grade tolerances shall apply for the final lift only.
- F. All new asphalt concrete surfaces shall be abutted to adjoining surfaces along a neat sawcut line. In no case shall new asphalt be feathered over existing surface material, placed against damaged surfaces, or over or against any material not adequately prepared as defined herein. The final surface of the asphalt concrete shall be no more than ¼-inches above the adjacent existing surface nor shall the final surface be below the level of the adjacent surface. In areas of paving other than trench repairs, the plane of the surface shall not vary more than ¼-inches above or below the average plane of the surface when measured with an 8-foot straight edge.
- G. Skin patching shall not be considered an acceptable method of achieving the tolerances herein. Skin patching is hereby defined as a mix of asphaltic concrete whose maximum aggregate size is less than or equal to the No. 4 sieve used to fill depressions in the pavement plane.
- H. The final lift of asphalt concrete shall be placed in one continuous operation as the final order of work for the project. Where trenches do not form an unbroken line throughout the project, asphalt concrete may be placed in one continuous operation for each continuous trench, subject to the prior approval of the Engineer.
- I. All paving not conforming with the provisions of these specifications, the Contract Documents, or any public agency having jurisdiction over the work shall be immediately removed and replaced in accordance with the provisions of these specifications, the Contract Documents, and the directions of such agencies having jurisdiction over the work.

3.02 FOG SEALING

- A. Fog seal shall be constructed in accordance with the provisions of Section 37, "Bituminous Seals" of the State Standard Specifications, to the limits shown on the Drawings, listed in the Encroachment Permit, or as indicated by the Engineer.

3.03 SLURRY SEALING

- A. Slurry seal coat shall be constructed in accordance with the provisions of Section 37, "Bituminous Seals" of the State Standard Specifications for a double seal coat, to the limits shown on the Drawings, listed in the Encroachment Permit, or as indicated by the Engineer.

END OF SECTION

SECTION 33 05 09.43

HOT TAP CONNECTIONS

PART 1 - GENERAL

1.01 DESCRIPTION

- A. This section describes materials, requirements and procedures for hot tap (system under pressure) connections to existing distribution systems.

1.02 RELATED WORK SPECIFIED ELSEWHERE

- A. Existing Facilities 02 01 00
- B. Chlorination of Domestic Water Mains for Disinfection 22 11 23
- C. Hydrostatic Testing of Pressure Pipelines 33 05 05.31
- D. Copper, Brass and Bronze Pipe, Fittings and Appurtenances 22 11 13
- E. Manual Valves 33 12 16

1.03 APPROVED MANUFACTURERS

- A. Service Saddles and Corporation Stops
 - 1. See Section 22 11 13
- B. Tapping Sleeves
 - 1. Mueller JCM 432
- C. Tapping Valves
 - 1. See Resilient Seated Wedge Gate Valves Section 33 12 16
- D. Direct Tap
 - 1. All taps into existing pipes will be made through a service saddle, tapping sleeve, welded nozzle or welded coupling. Saddles are required for all taps. Direct taps are not permitted.

PART 2 - MATERIALS

2.01 SERVICE SADDLES AND CORPORATION STOPS

- A. Service saddles and corporation stops shall comply with Section 22 11 13.

2.02 TAPPING SLEEVES

- A. Tapping sleeves onto pipelines 12-inch and smaller shall be full circle cast iron with mechanical joint end glands or fabricated stainless steel or as approved by District Engineer.
- B. Gaskets shall be Bunz-N rubber with a wide cross section.
- C. Tapping sleeves onto 14-inch and larger ACP shall be fabricated steel with mechanical joint ends. All fabricated parts shall be epoxy coated per Section 09 90 00. All bolts and trim hardware shall be Type 316 stainless steel.

2.03 TAPPING VALVES

- A. Tapping valves shall be flanged resilient seat wedge gate valves per Section 33 12 16.

PART 3 - EXECUTION

3.01 NOTIFICATION

- A. The contractor shall provide proper notification to the District inspector prior to making a hot tap connection.

3.02 VERIFICATION

- A. The contractor shall pothole the proposed connection to verify the outside diameter, location and type of pipe to be tapped.

3.03 SURFACE PREPARATION

- A. The pipe barrel to be tapped shall be thoroughly cleaned with a wire brush to provide a smooth, hard surface for the saddle, sleeve or nozzle.

3.04 SERVICE SADDLE AND CORPORATION STOP

- A. Service saddles and corporation stops will be installed onto ACP, DIP or PVC mains in accordance with the manufacturer's accordance and Section 22 11 13. The outlet shall be oriented to comply with the intended use of the service connection.

3.05 TAPPING SLEEVES

- A. The tapping sleeve shall be installed in accordance with the manufacturer's instructions and to the satisfaction of the District representative.
- B. The pipe barrel shall be thoroughly cleaned with a wire brush to provide a smooth, hard surface for the sleeve.
- C. The sleeve shall be supported independent of the pipe during the tapping operation.
- D. The sleeve shall be pressure tested in the presence of the District representative prior to tapping.
- E. Thrust blocks shall be provided at the tapping sleeve per Standard Plan W-17 03 30 00.

3.06 TAPPING VALVE

- A. The tapping valve shall be installed on the tapping sleeve or weld nozzle per Section 33 12 16. All flange bolts shall be Type 316 stainless steel.

3.07 HOT TAP

- A. The hot tap into the existing pipe shall be made using the appropriate type of cutting machine and shell cutting bit for the material being tapped.
- B. The company performing the hot tap must be approved by the District. The tapping machine shall be operated per the manufacturer's operating instructions.
- C. Proper care shall be taken to prevent cutting material from entering the pipeline. The tapping coupon must be extracted.

3.08 EXTERIOR COATING REPAIR

- A. The exterior bituminous or mortar coating on steel or iron pipe shall be repaired in accordance with the manufacturer's directions and/or Section 09 90 00.

3.09 DISINFECTION

- A. The interior of the tapping valve and connecting piping shall be sprayed with a sodium hypochlorite solution prior to connection.

END OF SECTION

SECTION 33 11 00

GENERAL PIPING REQUIREMENTS

PART 1 - GENERAL

1.01 SUMMARY

- A. Section includes:
 - 1. General requirements for piping systems, including pipe, joints, fittings, and valves.
 - 2. Pressure testing
- B. Related Sections:
 - 1. Section 02 01 00 – Existing Facilities
 - 2. Section 09 90 00 – Painting and Coating
 - 3. Section 31 23 00 – Trenching, Backfilling and Compacting
 - 4. Section 33 11 13.15 – Ductile Iron Pipe and Fittings
 - 5. Section 33 11 13.90 – Thrust Restraint
 - 6. Section 33 31 13 – Sanitary Sewer Pressure Piping
 - 7. Section 33 12 16 – Manual Valves
 - 8. Section 40 92 13 – Automatic Valves

1.02 REFERENCE STANDARDS

- A. American National Standards Institute (ANSI)
 - 1. ANSI A13.1 – Piping and Piping Systems
 - 2. ANSI A31.1 – Power Piping ASME
 - 3. NSF 61 – Listing of Certified Drinking Water System Components – Health Effects
- B. American Society of Mechanical Engineering (ASME) – Boiler and Pressure Vessel Code
- C. California Plumbing Code (CPC)
- D. American Waterworks Association (AWWA)
 - 1. [AWWA C116 Protective Fusion-Bonded Epoxy Coatings for the Interior and Exterior Surfaces of Ductile-Iron and Gray-Iron Fittings](#)
 - 2. AWWA C210 – Liquid-Epoxy Coating Systems for the Interior and Exterior of Steel Water Pipelines
 - 3. AWWA C600 Installation of Ductile Iron Water Mains and Their Appurtenances
 - 4. AWWA C605 Underground Installation of PVC and Molecularly Oriented PVC Pressure Pipe and Fittings
 - 5. [AWWA C900 PVC Pressure Pipe and Fabricated Fittings](#)
 - 6. AWWA C906 Polyethylene (PE) Pressure Pipe and Fittings, 4 Inch through 65 Inch

1.03 SUBMITTALS

- A. Submit in accordance with Section 01 30 00.
- B. Catalog cuts and product information showing materials and dimensions.
- C. Hydrostatic testing plans
- D. Operation and Maintenance manuals

PART 2 - MATERIALS

2.01 PIPE, FITTINGS, AND GASKETS

- A. Replacement of any pipe, fitting, and gasket shall be in-kind or equal.
- B. Ductile Iron Pipe and Fittings shall be as specified in Section 33 11 13.15.
- C. Mechanical joint restraints shall be EBAA Megalug or equal.

2.02 VALVES

- A. Valves shall be as specified in Section 33 12 16 and Section 40 92 13.
- B. Multiple brands for same type of valve will not be accepted.

2.03 BOLTED, SLEEVE-TYPE COUPLINGS

- A. Couplings shall meet AWWA C19 and NSF 61.
- B. Unrestrained sleeve couplings
 - 1. Hymax
 - 2. Romac series 501
 - 3. Or approved equal
- C. Restrained sleeve couplings
 - 1. EBAA series 3800 Mega Coupling
 - 2. Or approved equal
- D. Flange Adapters
 - 1. Romac series FCA
 - 2. EBAA series 1000 EZ Flange
 - 3. Or approved equal
- E. Restrained flange adapters
 - 1. Romac Series RFCA

2. EBAA series 2100 Megaflange
3. Or approved equal

2.04 COATINGS

- A. All above-ground pipe, valves and fittings shall be epoxy-coated, colored green for sewer service per Section 09 90 00.
- B. New equipment shall receive final finish coats at the factory in accordance to AWWA C116. Each coat of paint shall be of the consistency as specified by the paint manufacturer, or thinned as necessary, and applied in accordance with the manufacturer's written instructions. Work shall be free from "runs", "bridges", "shiners", or other imperfections. Care shall be taken to obtain a uniform, unbroken coating over welds, edges and corners. Weld splatter shall be removed and all welds neutralized with thinner. Blasted surfaces shall be coated within four hours of being sandblasted. All dust shall be removed from surfaces prior to coating.
- C. All surfaces to be coated or painted shall be in the specified condition to receive the material before any coating or painting is performed. Follow manufacturer's instructions. During and after final application of protective coatings, all metal surfaces shall be checked mechanically with an Elcometer, Mikrotest, or other approved dry film thickness gage to insure that the specified dry film thickness has been attained. Coating testing and repair of damages, flawed areas, holidays, or mishaps shall conform to applicable AWWA standards.
- D. Care shall be taken to prevent damage to coated surfaces during shipment. Any coatings damaged during shipment shall be refinished as the original at no extra cost to the Owner.
- E. Coatings shall be guaranteed for a period of one year following the date of final acceptance by the Owner.

2.05 BURIED PIPING WARNING TAPE

- A. Plastic warning tape shall be an inert plastic film specifically formulated for prolonged underground use. The minimum thickness shall be 4 mils and the minimum width of the tape shall be 6 inches. Printing shall be a minimum of 2-inch block letters.
- B. Warning tape for domestic water pipelines shall be blue with black printing having the words "CAUTION: DOMESTIC WATER-LINE BURIED BELOW."
- C. Warning tape for sanitary sewer pipes shall be green with black printing having the words "CAUTION: SANITARY SEWER BURIED BELOW."
- D. Warning tape for recycled water pipelines shall be purple with black printing having the words "CAUTION: RECYCLED WATER-LINE BURIED BELOW."

PART 3 - EXECUTION

3.01 GENERAL

- A. Location: Install piping to the line and grade as shown on the Drawings, except for adjustments to avoid existing features.
- B. Confirm dimensions at the Project Site prior to pipe fabrication.
- C. Contractor shall take all measures necessary to maintain the existing sewer mains and services in operation until completion of the pipeline construction.

3.02 PIPING INSTALLATION

- A. Trenching
 - 1. The Contractor shall bear full responsibility for safety related to his trenching operations.
 - 2. Trenching, bedding, and backfill operations including but not limited to, pavement cutting and restoration, excavation, shoring, and steel plates shall be in accordance with Section 31 23 00. Insofar as practicable and at all times on grades in excess of 1-foot horizontal to 10-feet vertical (10 percent), trenching and pipe-laying operations shall proceed uphill from the lowest point with the bell end leading.
- B. Daily Limits - The Contractor shall excavate only that length of trench in which he can safely and properly install pipe and backfill daily. No trenches may be left open when the Contractor is not actively prosecuting work related to that trench. To facilitate the prosecution of the work, the Contractor may request to use plates to cover open trenches. The use of steel plates shall be dependent upon the prior approval of the Engineer.
- C. Handling and Placing
 - 1. Handle pipe, fittings, and appurtenances in such a manner as to insure delivery to the Project Site in a sound, undamaged condition. Take particular care not to injure linings and coatings and to keep the pipe clean. Load and unload these items using hoists in a manner to avoid shock or damage. Under no circumstances shall they be dropped, skidded, or rolled against other pipe.
 - 2. Repair damaged items to the satisfaction of the Engineer. Set aside damaged items that cannot be repaired and remove from Project site within 24 hours.
 - 3. The Contractor shall employ such devices and equipment as will enable the pipe to be transported, stored, and installed in its final location or configuration, as provided for in the Contract Documents.
 - 4. Pipe to be installed in trenches shall be lowered into the trench using lowering slings and other devices that will prevent an uncontrolled drop into the trench. Compacted bedding material conforming with Section 31 23 00 shall be installed in the bottom of the trench and compacted prior to placing pipe in the trench. Bell holes shall be excavated such that the pipe is fully supported by the pipe barrel. Pipe shall not be permitted to be supported solely by the bells. Where the Contract Documents call for or the Contractor elects to use sand/cement slurry backfill material, the pipe shall be supported on wooden blocks or other supports on each side of every joint. An additional block at mid-span shall be used for PVC pipe. Such blocks shall be of such dimension as to raise the pipe high enough to clear the bells and long enough to span at least 2/3 of the trench width. Wooden blocks shall be redwood or pressure treated timber.
- D. Locator Wire - A wire to be used for future subsurface location shall be installed concurrent with pipe laying operations. The wire shall be a minimum of 12 gauge THW or THWN

solid copper wire and shall be continuous for the entire length of pipe laid. The wire shall be secured to the pipe by either tape, mastic, or looping at a maximum interval of 12 feet. Connections between lengths of wire shall be made either by crimp connectors, or wire nut connectors. Each connection shall be at least double-wrapped with PVC electrical tape with each turn lapping the previous turn by at least 50-percent. The wire shall be brought to the surface in each valve box with at least 2 feet of wire more than that required to reach the surface. The wire shall be protected during backfilling operations to prevent displacement or continuity breaks. Any damage to the locator wire shall be immediately repaired.

E. Installation of Pipe Warning Tape

1. Warning tapes shall be installed a minimum 1-foot above and centered on the pipe. The warning tape shall be installed continuously for the length of the pipe and shall be fastened to valve stem casings or other vertical appurtenances by plastic adhesive tape.
2. Warning tape is not required for pipes installed by trenchless methods.

F. Valves

1. Clean valves of foreign material and inspect in open and closed positions prior to installation
2. Unless otherwise indicated, install valves with operating stem vertical. Mount horizontal valves in such a manner that adequate clearance is provided for operation.
3. Clean flange faces prior to installing flanged valves. After cleaning, insert gasket and nuts, tighten progressively and uniformly. If flanges leak under pressure, loosen nuts, reseal or replace gasket, retighten nuts, and retest joints.
4. Test valves in same manner as specified for piping systems. Protect parts of valves that could be damaged during pipeline test. Joints shall be watertight at specified test pressures. Repair any damage to valves.

G. Bolting Procedures

1. Description - All fittings, joints, assemblies, valves, and miscellaneous special fittings shall be installed in accordance with this Section. The required torque shall be as specified in the Contract Documents, the referenced specifications, and the manufacturer's recommendations.
2. Contractor shall have a calibrated torque wrench on site at all times.
3. Procedure
 - a. The pipe and fitting (or fittings) shall be carefully aligned using slings, blocks, jacks, or other means necessary to establish and maintain the correct alignment. Under no circumstances shall the bolts be used to achieve the correct alignment. As the bolts are inserted through the flange the gasket shall be inserted between the mating faces of the fitting and pipe.
 - b. After taking up the free slack in the nuts, the Contractor shall tighten each bolt in opposing succession taking multiple passes to achieve the proper. Opposing succession is hereby defined as tightening the first nut then the nut diametrically opposed to the first and proceeding either clockwise or counterclockwise in this manner around the circumference of the joint until the required torque is achieved. In no case shall the Contractor tighten the nuts in direct sequence or over-tighten any nut with respect to its opposing mate.
 - c. During the tightening operation and again upon completion of the tightening operation, the space between the mating faces of the fitting and pipe shall be

inspected for evidence of non-parallel assembly. The tolerance for parallel assembly shall be 1/16-inches for mechanical joint faces and 1/32-inches for flanged faces. Other fittings and faces shall be within the tolerance recommended by the manufacturer. If the space is non-parallel in excess of such tolerance, the joint shall be completely disassembled and the installation repeated. The gasket shall be inspected for damage prior to retightening the bolts. If the mating faces of the fitting and pipe cannot be brought into parallel alignment the joint shall be disassembled, the pipe removed, the gasket replaced, and the assembly repeated.

- d. Upon completion of the bolting operation between elements of the fittings and joints, the Contractor shall tighten all thrust restraint gripping surfaces in the same manner of opposing succession. The thrust restraining follower gland shall be tightened to the recommended torque as recommended by the manufacturer. The twist-off nut shall be considered as a safety mechanism to prevent damage from excessive torsional forces. The shear capability shall not be used in lieu of proper tightening, including the use of limiting torque wrenches.
- e. All bolts on the fittings or joint, including those of the thrust restraining devices, shall be subject to a torque test by the Engineer. If any bolts are found to be under- or over-torqued or in any way evidencing damage, the Engineer may direct their readjustment or replacement in accordance with the provisions of this Section.
- f. Upon completion of the bolting operation, all buried fittings shall receive a liberal coating of bitumastic type material (Protecto Wrap 160/160H, Tapecoat Brush-Applied Coating, Christy's HD-50 Coal Tar Coating, or approved substitute). This coating shall be thoroughly worked into the spaces between joint faces, under and around bolts and nuts, and on all surfaces that will be in soil contact. The coating shall be allowed to attain an initial set prior to commencing any backfill operations and in no case shall backfill operations commence less than 1-hour after coating is completed.

3.03 HYDROSTATIC PRESSURE TESTING

- A. Hydrostatic pressure testing is required for pressure pipeline segments only (force main and pump system piping).
- B. Upon completion of pipeline construction, the Contractor shall fill the pipeline with water from an approved source. All work involved in hydrostatic testing of pipelines shall conform to the requirements of AWWA C600, AWWA C605 and the provisions of the Contract Documents.
- C. The Contractor shall provide all pumps, fittings, labor, equipment, and materials and all assistance necessary, including but not limited to, temporary thrust restraint and connection to the supplying water source for the hydrostatic testing of all pipelines. Hydrostatic testing shall be performed in the presence of the Owner's Inspector. Test pressures shall be a minimum of 150 psi or 150-percent of the service pressure for the pipeline, whichever is the greater.
- D. Test pressures shall be held for a minimum of 2 hours or that period of time provided for in the Contract Documents. During the hydrostatic test the pressure shall not be allowed to vary more than 5 psi above or below the required test pressure. Pressure variances outside the allowable range shall be considered a failed test. Tests shall not be held against closed line valves without the prior approval of the Engineer and all hydrant valves shall be open. Where service lines have been installed prior to conducting the hydrostatic test,

the service line to the meter stop shall be included in the test. An additional allowance of 0.0078 gph/inch of service line diameter may be included for each service line included in the hydrostatic test in the calculation of allowable leakage in such cases.

- E. Upon completion of pipeline construction all pressure pipelines shall be hydrostatically tested and observed for leaks. The Contractor shall schedule the hydrostatic test with the Engineer at least two (2) days in advance of the test. The pipelines or pump suction barrels shall be filled and carefully brought to the test pressure. Failure of any portion of the system shall be cause for rejection and the Contractor shall promptly identify and correct the deficiencies causing the failure. The hydrostatic test shall be repeated until a satisfactory test is achieved. All visible leaks shall be promptly repaired regardless of the actual leakage measured.
- F. This procedure shall be followed until an acceptable test is achieved. The Contractor may be charged for the Engineer's time for reinspection for all tests after the first retest in accordance with the General Conditions.
- G. Allowable Leakage - The allowable leakage will be calculated by the following formula:
$$L_a = (LD\sqrt{P})/148,000$$

where: L_a = Allowable leakage
 L = Length of the pipe run
 D = Nominal diameter of the pipe in inches
 P = Test pressure
- H. Flanged above-grade pipe shall have no leakage allowance. Contractor shall correct all visible leakage.
- I. The allowable leakage for differing lengths of pipe runs and higher test pressures will be provided for in the Contract Documents or by direction of the Engineer. The allowable leakage for test sections of differing diameters will be calculated as the sum of the computed leakage for each size.
- J. Equipment - The Contractor shall provide a test pump capable of supplying 250 psi static pressure, a means of adding replacement water during the test, and gauges and meters to monitor the pressure and replacement water used.

END OF SECTION

SECTION 33 11 13.15

DUCTILE IRON PIPE AND FITTINGS

PART 1 - GENERAL

1.01 DESCRIPTION

- A. This section includes materials, installation, and testing of ductile-iron pipe and fittings.
- B. Related sections:
 - 1. Section 01 57 80 – Control of Ground and Surface Water
 - 2. Section 31 23 00 – Trenching, Backfilling and Compaction
 - 3. Section 33 11 00 - General Piping Requirements
 - 4. Section 33 12 16 – Manual Valves

1.02 REFERENCED CODES AND STANDARDS

- A. American Water Works Association (AWWA), latest edition:
 - 1. C104 – Cement Mortar Lining for Ductile-Iron Pipe and Fittings
 - 2. C105 – Polyethylene Encasement for Ductile –Iron Pipe Systems
 - 3. C110 – Ductile-Iron and Gray-Iron Fittings
 - 4. C111 – Rubber-Gasket Joints for Ductile-Iron Pressure Pipe and Fittings
 - 5. C115 – Flanged Ductile-Iron Pipe with Ductile-Iron or Gray-Iron Threaded Flanges
 - 6. C150 – Thickness Design of Ductile Iron Pipe
 - 7. C151 – Ductile-Iron Pipe, Centrifugally Cast
 - 8. C600 – Installation of Ductile-Iron Water Mains and Their Appurtenances
 - 9. C606 – Grooved and Shouldered Joints
- B. NSF International
 - 1. 60 – Drinking Water Treatment Chemicals – Health Effects
 - 2. 61 – Drinking Water System Components – Health Effects

1.03 APPROVED MANUFACTURERS

- A. Fittings
 - 1. US Pipe
 - 2. Tyler
 - 3. Sigma
 - 4. Or equal
- B. Pipe
 - 1. U.S. Pipe
 - 2. Pacific States

3. American Pipe
 4. Or approved equal
- C. Gaskets
1. Tripac 2000
 2. US Pipe
 3. John Crane Co.
 4. Or equal

1.04 USE OF GRAY-IRON FITTINGS

- A. Gray-iron fittings may not be substituted for ductile-iron.

1.05 SUBMITTALS

- A. Contractor shall provide submittals for review and approval by the Engineer in accordance with Section 01 30 00.
- B. Provide shop drawings or catalog cuts for all work and materials included in this Section.

PART 2 - PRODUCTS

2.01 DUCTILE-IRON PIPE

- A. Pressure class or thickness class of DIP shall be determined by the design method detailed in AWWA C150 the "Thickness Design Method."
- B. Ductile-iron pipe shall be manufactured in accordance with AWWA C151.
- C. All ductile-iron pipe shall be pressure class 350 for bell and spigot pipe. Flanged pipe shall be thickness class 53 unless indicated otherwise.
- D. All ductile iron pipe and fittings in sewer applications shall be polyurethane or polyethylene lined and coated.
- E. All buried ductile iron pipe shall have a factory applied bituminous coating of not less than 1 mil. in thickness.
- F. All exposed above-grade ductile iron pipe shall be epoxy-coated per Section 09 90 00.
- G. Unless otherwise called out on the plans, a "push-on" type joint shall be used. The joint dimensions and gasket shall be as specified in AWWA C111.
- H. Where restrained joints are called, push-on joints shall be restrained with locking gasket rated for 250 psi operating pressure for DIP.
- I. Flanges for ductile-iron pipe shall be the "screwed-on" type in accordance with AWWA C115.
- J. Outlets for DIP shall be as follows:

- | | | |
|----|----------------------|------------------------------------|
| 1. | 2" or smaller: | bronze service saddle |
| 2. | 2-1/2": | tapped tee or service saddle |
| 3. | 4" to 8" and larger: | D.I. tee fitting or service saddle |
| 4. | 12" and larger | D.I. tee fitting |

2.02 DUCTILE-IRON FITTINGS FOR PVC AND DUCTILE IRON PIPE

- A. Except as otherwise indicated on the drawings, all fittings on pipelines and piping assemblies shall be manufactured of ductile iron in accordance with the provisions of AWWA C110 and C153. The interior of the fitting shall be lined with polyurethane or polyethylene rated for sanitary sewer service. The exterior shall be coated with 100% solids epoxy.
- B. The body of the fitting shall be free of blows, sand pits, abrasions deeper than 10 percent of the material thickness, cracks, and other defects that adversely affect the performance of the fitting under pressure in-situ or the corrosion potential of that fitting. Likewise the coatings shall be free of chips, holes, abrasions, and scratches that reduce the thickness of the coating below the tolerances specified herein.
- C. Evidence of such defects or damage shall be cause for rejection of the fitting and the Contractor shall replace such defective or damaged fittings at no cost to the Owner.
- D. Push-on to push-on fittings shall not be used unless restraints are provided as described below.
- E. Restrained fittings shall be used where a thrust block is not specified. Where restrained joints are called, pipe-to-pipe push-on joints shall be restrained with locking gasket rated for 250 psi operating pressure for DIP. Push-on joints at fittings shall be restrained with a mechanical type bell restraint for C-900 PVC pipe. Mechanical joint restraints shall be EBAA IRON, INC., MEGALUG, UNIFLANGE Series 1400, or approved equal. Flanged fittings may be used.
- F. Unless otherwise indicated on the drawings, all fittings with flanged ends shall be ductile iron class 150. The gasket surface shall have a serrated finish of approximately 16 serrations per inch, approximately 1/32-inch deep, with serrations in either a concentric or spiral pattern. All flanges shall be flat faced. In addition, all flanges shall meet the following tolerances:

1.	Bolt circle drilling	$\pm 1/16$ inch
2.	Bolt hole spacing	$\pm 1/32$ inch
3.	Eccentricity of bolt circle and	$\pm 1/32$ inch
4.	Maximum facing with respect to bore	$\pm 1/32$ inch

2.03 JOINTS

- A. Joints on fittings used in subsurface installations of transmission and distribution pipelines shall be mechanical joint or flanged type, as provided for in the Contract Documents, conforming to the requirements of AWWA C111. In piping assemblies, both subsurface and above grade, the joints shall be either mechanical joint or flange type conforming with the requirements of AWWA C110, C111, and C153 as provided for in the Contract Documents.

- B. Mechanical Joints - Each mechanical joint shall be supplied with an SBR gasket. The retainer or follower gland shall be replaced with a thrust restraining follower gland in accordance with the provisions of Section 33 11 13.90, Thrust Restraint.

2.04 GASKETS

- A. Gaskets for flanged joints shall be 1/8-inch thick, cloth-inserted rubber. Full face type gaskets with pre-punched holes shall be used where both flanges are flat face. Ring gaskets, 1/8-inch thick vulcanized butadiene rubber (SBR) or neoprene rubber gasket conforming with the provisions of AWWA C110, extending to the inner edge of the bolts may be used where a raised face flange is present.
- B. Rubber gaskets for push-on and mechanical joints shall be vulcanized butadiene rubber (SBR) manufactured in accordance with AWWA C111.

2.05 BOLTS AND NUTS

- A. All bolts and nuts shall be:
 - 1. High-strength, low carbon steel conforming with ASTM A307, galvanized after fabrication, or
 - 2. Type 316 stainless steel conforming to ASTM F593 G or H for bolts, and ASTM F594 with Tripac 2000 Blue Coating for nuts.
- B. Mechanical joint bolts (tee bolts) shall be 3/4-inches in diameter and be furnished for each joint in accordance with AWWA C110, AWWA C111, and AWWA C153.
- C. The length of each bolt or stud shall be such that between 1/4 inch and 3/8 inch will project through the nut when drawn tight.
- D. All bolts and nuts which are not type 316 SS shall be coated with Christy HD-50 Bituminous Coal-Tar Coating after installation.

2.06 PLASTIC FILM WRAP

- A. All ductile-iron pipe and fittings buried underground shall be protected with plastic film wrap in accordance with AWWA C105, unless noted otherwise below. Wrap shall be a loose polyethylene tube, either 8-mil thickness of linear low-density PE or 4-mil thickness of high-density cross-laminated PE. All joints between plastic tubes shall be wrapped with 2-inch-wide polyethylene adhesive tape, Polyken 900, Scotch wrap 50, or approved equal.

2.07 LUBRICANTS

- A. Lubricant for pipe insertion shall be NSF food grade and biodegradable.

2.08 POLYETHYLENE LINING FOR SEWER APPLICATIONS

- A. Lining material for ductile iron pipe and fittings (sewer applications) shall be virgin polyethylene complying with ASTM D1248 and bonded to the interior of the pipe fittings by heat process. The lining material shall be compounded with inert filler and a compound which resists ultraviolet light.

- B. The lining shall cover the interior surface of the pipe/fitting from the laid or beveled end to the rear of the gasket socket. The lining thickness shall be not less than 20 mils. The lining may taper at the ends, starting at 4 inches from the edge of the pipe. The minimum thickness at the end of the taper shall be 10 mils.
- C. Each pipe shall be guaranteed against separation of the lining from the pipe. Random checks for operation will be made during construction and any indication of separation shall be cause for rejection. The test method shall be mutually agreed upon by the contractor and the Owner.

2.09 POLYURETHANE LINING SYSTEM

- A. The lining material shall consist of a liquid-applied polyurethane coating especially formulated for use as a protective lining of pipelines carrying sewage. The material shall be Corropipe II Wasteliner or approved equal. The dry film thickness (DFT) of the lining shall be 40 mils (0.040 inch) nominal.
- B. In order to minimize potential dimensional and assembly problems, the coating thickness on sealing areas in the bell socket interior and on the spigot end of the pipe exterior shall be 8 mils (0.008 inch) nominal with a maximum of 10 mils (0.010 inch). Thicker coatings in these areas are acceptable if it is demonstrated that joint dimensions are within allowable tolerances after coatings.
- C. The lining material shall be applied to the pipe and fittings by an applicator certified or approved by the coating manufacturer. The coating shall be holiday tested with a high voltage tester at 50 volts/mil of material thickness. The material shall be applied and repaired to the pipes and fittings in strict accordance with the manufacturer's requirements with no exceptions. Owner shall be notified five (5) days in advance of the coating installation for factory inspection during the application of the material.
- D. All field cut ends shall be repaired and sealed prior to installation per the manufacturer's recommendations.

2.10 EPOXY COATING SYSTEM

- A. Epoxy lining and coating of valves shall be per AWWA C550 and Section 33 12 16 Manual Valves. All valves shall be lined and coated by manufacturer.
- B. Surfaces to be epoxy coated shall follow the surface preparation requirements as recommended by the manufacturer.
- C. Surfaces shall be coated with organic zinc primer to a dry film thickness of 3 mils.
- D. Apply two coats of epoxy paint (4 mils each) to the primed surface. The manufacturer's recommended drying time between coats shall be followed.
- E. Prepare multiple-component coatings using all of the contents of the container for each component as packaged by the paint manufacturer. Do not use partial batches. Do not use multiple-component coatings that have been mixed beyond their pot life. Provide small quantity kits for touch up painting and for painting other small areas. Mix only the components specified and furnished by the paint manufacturer. Do not intermix additional

components for reasons of color or otherwise, even within the same generic type of coating.

PART 3 - EXECUTION

3.01 GENERAL

- A. Ductile-iron pipe and ductile iron fittings shall be installed in accordance with the applicable Sections of AWWA C600 and as specified herein.

3.02 TRENCHING, BACKFILLING, AND COMPACTING

- A. Trenching, backfilling, and compacting shall be in accordance with Section 31 23 00 and as specified herein.
- B. Backfill within the pipe zone, including the pipe base, shall be imported sand placed and compacted in accordance with Section 31 23 00.
- C. Backfill within the trench zone shall be native earth backfill placed and compacted in accordance with Section 31 23 00.

3.03 PLACEMENT OF PIPE IN TRENCH

- A. Lay pipes uphill if the grade exceeds 10%.
- B. The radius of curvature of the trench shall determine the maximum length of pipe section that can be used without exceeding the allowable deflection at a joint. Combined deflections at rubber gasket, restrained joint, deflection coupling or flexible coupling joints shall not exceed 2 degrees or that recommended by the manufacturer, if smaller.
- C. The manufacturer's printed installation guide outlining the radius of curvature that can be negotiated with pipe sections of various length and the deflection couplings shall be followed if applicable.
- D. The pipe shall be laid true to the line and grade shown on the plans within acceptable tolerances. The tolerance on grade is 1 inch. The tolerance on line is 2 inches.
- E. Pipe shall not be stabbed past the pipe manufacturer's pipe insertion line. Contractor shall mark new insertion lines where original spigot end is cut off.
- F. Wrap ductile-iron pipe and fittings with plastic film wrap in accordance with AWWA C105.
- G. Fittings shall be supported independently of the pipe.
- H. Until thrust blocks and supports are poured, fittings shall be temporarily supported by placing wooden skids under the bells so that the pipe is not subjected to the weight of the fitting.

- I. All exposed flanges and other metal surfaces and all damaged coatings shall be coated after assembly with a mastic, 3M, Minnesota Mining and Manufacturing EC 244, or an approved equal. Stainless steel bolts shall not be coated.
- J. Where locking gaskets are used to restrain push-on joints, the pipe bell shall be stenciled "Locking Gasket."

3.04 MECHANICAL JOINTS

- A. Mechanical joints shall be installed in accordance with the manufacturer's recommendation and Section 33 11 00. The fitting shall be thoroughly cleaned of all dirt, debris, or other deleterious material and inspected prior to incorporation into the work.
- B. The pipe end shall be beveled with a grinding tool or rasp file to facilitate the assembly of the joint. The restraining follower gland shall be slipped over the end of the pipe followed by the gasket. The Contractor shall take care that the restraining follower gland and gasket are installed in the correct alignment and that the gasket is not forced onto the pipe or otherwise damaged.
- C. The pipe end shall then be inserted into the joint to the tolerance required by AWWA C110, C111, and C153. The pipe shall be aligned as straight as field conditions permit but in no case shall the pipe be deflected in excess of 3 degrees (5/8-inch per foot) or that maximum deflection recommended by the manufacturer, whichever is the lesser. The gasket shall then be inserted into the gasket seat taking care not to force or otherwise damage the gasket. Once the gasket is fully and evenly seated in the gasket space, the follower gland shall be aligned with the mating face of the fitting and the bolts inserted and the nuts threaded onto the bolts.
- D. All bolting shall be performed in accordance with the provisions of Section 33 11 00, General Piping Requirements.

3.05 FLANGED JOINTS

- A. Flanged joints shall be installed in accordance with the manufacturer's recommendation and Section 33 11 00. The fitting shall be thoroughly cleaned of all dirt, debris, or other deleterious material and inspected prior to incorporation into the work.
- B. The pipe and fitting shall be carefully aligned using slings, blocks, jacks, or other means necessary to establish and maintain the correct alignment. Under no circumstances shall the bolts be used to achieve the correct alignment. As the bolts are inserted through the flange the gasket shall be inserted between the mating faces of the fitting and pipe.
- C. Bolt holes of flanges shall straddle the horizontal and vertical centerlines of the pipe run.
- D. Clean flanges by wire brushing before installing gasket.
- E. Clean flange bolts and nuts by wire brushing, lubricate threads with anti-seize compound, and tighten nuts uniformly and progressively. Between 1/4 inch and 3/8 inch shall project through the nut when drawn tight.

- F. All bolting shall be performed in accordance with the provisions of Section 33 11 00, General Piping Requirements.
- G. If flanges leak under pressure testing, loosen or remove the nuts and bolts, reseal or replace the gasket, reinstall or retighten the bolts and nuts, and retest the joints. Joints shall be watertight.

3.06 ANCHORS AND THRUST BLOCKS

- A. Concrete anchors and thrust blocks shall be poured against wetted undisturbed soil in accordance with Section 33 11 13.90 and as shown on the Drawings.

3.07 PIPE SUPPORT

- A. All exposed pipe shall be supported as detailed in the plans.

3.08 TESTING

- A. All pressure piping shall be hydrostatically pressure tested in accordance with Section 33 11 00.

3.09 TAPPING

- A. Direct tapping of DIP shall not be allowed. All taps shall include a saddle with two-straps.

END OF SECTION

SECTION 33 12 16

MANUAL VALVES

PART 1 - GENERAL

1.01 DESCRIPTION

- A. This section includes materials, testing, and installation of manually operated valves.
- B. Manual valves to be supplied and installed per AWWA C507 and C509, unless noted otherwise below.

1.02 RELATED WORK SPECIFIED ELSEWHERE

- A. All related work specified elsewhere, or in other codes or standards, will be as last revised, unless a specific date of issuance is called out in opposition to later revision date(s).
- B. Other sections of the technical specifications, not referenced below, shall also apply to the extent required for proper performance of this work.
 - 1. Trenching, Backfilling, and Compacting: 31 23 00
 - 2. Cast-In-Place Concrete: 03 30 00
 - 3. Painting and Coating: 09 90 00
 - 4. Hydrostatic Testing of Pressure Pipelines: 33 05 05.31
 - 5. Ductile-Iron Pipe and Fittings: 33 11 13.15
 - 6. Underground Facilities Identification. 33 05 26

1.03 REFERENCE STANDARDS

- A. Valves shall conform, as applicable, with the latest editions of the following codes and standards.
 - 1. AWWA C504 Rubber-Seated Butterfly Valves
 - 2. AWWA C509 & C515 Resilient Seated Gate Valves
 - 3. AWWA C550 Protective Interior Coatings for Valves and Hydrants
 - 4. ASTM B62 Composition Brass or Ounce Metal Castings
 - a. Ductile Iron Castings for Valves
 - b. Ductile Iron Pipe Flanges
 - 5. ASTM D 429 Tests for Rubber Property – Adhesion to Rigid Substrates

1.04 SUBMITTALS

- A. Submit manufacturer's product data, shop drawings and installation instructions demonstrating compliance with the reference standards and this specification for the intended service.
- B. Certified test reports shall be provided with each delivery showing that the valve(s) delivered complies with this specification.

1.05 APPROVED MANUFACTURERS

- A. Gate Valves - Aboveground Smaller Than 2 Inch
 - 1. Red & White
 - 2. Milwaukee
 - 3. Or approved equal
- B. Ball Valves Smaller than 3-inch
 - 1. Nibco
 - 2. Or approved equal
- C. Resilient - Seated Gate Valves: 2 Inch through 12 Inch
 - 1. Clow
 - 2. Mueller
 - 3. American Flow Control (AFC)
 - 4. Or approved equal
- D. Butterfly Valves
 - 1. Henry Pratt Company
 - 2. Dezurik
 - 3. American Flow Control (AFC)
 - 4. Or approved equal
- E. Valve Boxes
 - 1. Christy G5 with cast iron cover
 - 2. Or approved equal

1.06 FLANGED END

- A. All valves connecting to fittings on a main shall be flanged on at least one side and bolted to the fitting on the main.

1.07 SINGLE TYPE OF VALVE

- A. The Contractor shall choose an approved valve and then use only that valve throughout the Work (i.e., only one manufacturer and model per type of valve).

1.08 BUTTERFLY VALVES

- A. Butterfly valves shall only be used on lines 14 inches and larger or as specifically shown on the plans.

1.09 RESILIENT WEDGE GATE VALVES

- A. Resilient gate wedge valves shall be used on all pressure class 150 lines 2 inch through 12 inch.

1.10 FIELD HYDROSTATIC TEST

- A. All valves 16-inch and larger shall be field hydrostatically tested to the valves working pressure in the presence of the Owner's inspector. Each side of the valve shall be pressurized and tested independently.

PART 2 - MATERIALS

2.01 GENERAL

- A. Valves shall be installed complete with operating handwheels or levers, extension stems, worm gear operators, operating nuts, and wrenches required for operation.
- B. Valves shall have the name of the manufacturer and the size of the valve cast or molded onto the valve body or bonnet or shown on a permanently attached plate.
- C. Valve body and trim casting shall be of domestic origin.
- D. Bolts for all valves shall be 316 stainless steel. Bolts consisting of 304 stainless steel shall not be permitted.
- E. Suitable valves shall be provided to connect to adjoining piping as shown on the plans.

2.02 VALVE OPERATORS

- A. Butterfly Valve Operators
 - 1. Provide lever or wrench operators having adjustable, "position indicator" for exposed butterfly valves smaller than 6 inches.
 - 2. Provide gear operators on butterfly valves 6 inches and larger. Gear operators for valves 8-inches and larger shall be of the traveling nut type. For large valves, worm gears shall be used with the approval of the Engineer.
 - 3. Gear operators shall be enclosed with seals provided on shafts to prevent entry of dirt and water into the operator. Gear operators for valves located above ground or in vaults and structures shall have handwheels. Minimum handwheel diameter shall be 12 inches. The operator shall contain a dial indicating the position of the valve disc or plug.
 - 4. Gear operators for buried or submerged valves shall have 2-inch square AWWA operating nuts.
 - 5. For buried or submerged service, provide watertight shaft seals and watertight valve and actuator cover gaskets. Provide totally enclosed operators designed for buried or submerged service.
 - 6. Traveling nut and worm gear operators shall be of the totally enclosed design so proportioned as to permit operation of the valve under full operating head with a maximum pull of 80 pounds on the hand-wheel. Provide stop limiting devices in the operators in the open and closed positions. Operators shall be of the self-locking type to prevent the disc or plug from creeping. Design operator components between the input and the stop-limiting devices to withstand without damage a pull of 200 pounds for handwheel or chainwheel operators and an input torque of 300 foot-pounds for operating nuts when operating against the stops.
 - 7. Operators on buried valves shall produce the required torque on the operating nut with a maximum input of 150 foot-pounds.

B. Gate Valve Operators

1. Provide hand-wheel operators for above ground gate valves. Minimum handwheel diameter shall be 12 inches.
2. Provide 2-inch AWWA operating nuts for buried and submerged valves.

C. Valve operators, handwheels, or levers shall open by turning counterclockwise.

2.03 PAINTING AND COATING

A. Coat metal valves (except bronze and stainless-steel valves) located above ground or in vaults and structures in accordance with Section 09 90 00. Apply the specified prime coat at the place of manufacture. Apply finish coat in field. Finish coat shall match the color of the adjacent piping. Coat handwheels the same as the valves.

B. Coat buried metal valves at the place of manufacture per Section 09 90 00

C. Valves 4 inches and larger shall be coated on their interior metal surfaces excluding seating areas and bronze and stainless steel pieces in accordance with AWWA C550 and these specifications. Sandblast surfaces in accordance with SSPC SP-1. Remove all protuberances which may produce pinholes in the lining. Round all sharp edges to be coated. Remove any contaminants which may prevent bonding of the lining. Coat the interior ferrous surfaces using one of the following methods:

1. Apply powdered thermosetting epoxy (3M Scotchkote 6251 Fusion Bonded Epoxy or equal) per the manufacturer's application recommendations to a thickness of 7 to 9 mils. All gaskets and seals must be removed prior to applying coating.
2. Apply two coats of catalytically setting epoxy (Tnemec Series N140, or equal) to a dry-film thickness of 7 to 9 mils total. Follow the paint manufacturer's application recommendations including minimum and maximum drying time between the required coats.

D. All valve coatings shall be factory applied or by the manufacturer's qualified distributor. Touch up and repair of valve coatings shall be only done by authorized factory distributors.

2.04 ABOVEGROUND BALL VALVES 2 INCHES AND SMALLER

A. Aboveground threaded end ball valves, 1/4 inch through 3 inches, for water service shall be full bore port ball type having a minimum working pressure of 200 psi. Valves shall have plastic coated lever operators.

B. Materials of construction shall be as described below:

1. Body: Bronze per ASTM B 62
2. Ball: Type 316 Stainless Steel
3. Seat and Seals: Teflon
4. Stem: Bronze or Copper Silicon, per ASTM B 62, B99 (Alloy 651), B 584 or B 371 (Alloy 694)

C. Stem material shall have a minimum tensile strength of 60,000 psi and a minimum yield strength of 30,000 psi.

2.05 RESILIENT-SEATED WEDGE GATE VALVES

- A. Valves shall conform to AWWA C509 and C515 and the requirements listed herein.
- B. All valves shall be bubble tight at 200 psi working pressure.
- C. Valves shall have non-rising low-zinc stems, opening by turning counter-clockwise and provided with 2-inch-square operating nut. Outside stem and yolk valves shall be used on backflow device shutoff valves.
- D. Each valve shall have a smooth unobstructed waterway free from any sediment pockets.
- E. Stuffing boxes shall be O-ring seal type with two rings located in stem.
- F. Low friction torque reduction thrust bearings shall be located both above and below the stem collar.
- G. Materials shall be as described below:
 - 1. Body, Operating Nut Bonnet and Seal Plate: Cast Iron or Ductile Iron per ASTM A 126 Class B
 - 2. Gate: Cast Iron or Ductile Iron per ASTM A 126 Class B
 - 3. Bonnet and Seal Bolts: Type 316 Stainless Steel
 - 4. O-Rings: Synthetic Rubber per ASTM D2000
- H. All internal working parts (excluding gate) shall be all bronze containing not more than 2 percent aluminum or more than 7 percent zinc. Valve stems shall be cast or forged from bronze having a tensile strength of not less than 60,000 psi, a yield point of not less than 30,000 psi, and an elongation of not less than 10 percent in 2 inches.
- I. All gates shall be encapsulated in Buna-N rubber or a nitrile elastomer.

2.06 TAPPING VALVES

- A. Tapping valves shall conform with all requirements for gate valves 2 inches and larger and the additional requirements listed herein.
- B. All valve ends shall be flanged. The flange on one end shall have slotted bolt holes to fit all standard tapping machines.
- C. Seat rings shall be oversized to permit the use of full-size cutters.
- D. Resilient wedge valves may be used as tapping valves, provided that the disk fully retracts to produce a full port opening.

2.07 BUTTERFLY VALVES

- A. Butterfly valves shall conform to AWWA C504, Class 250B. Minimum working differential pressure across the valve disc shall be 250 psi unless specified otherwise on the drawing.

- B. Butterfly valves shall be furnished and installed with the type of ends as shown on the plans and as herein specified. Wafer style valves will not be permitted. Valves connecting to buried fittings shall be flange by mechanical joint, where the valve is directly bolted to flanged fitting. If valve is not available with flange by mechanical joint end configurations, CONTRACTOR shall provide mechanical joint valves and fittings with mechanical restraints at no extra cost to District.
- C. Each valve body shall be tested under a test pressure equal to twice its design water working pressure.
- D. Valves shall be bubble tight at rated pressures and shall be satisfactory for throttling service and frequent operation after long periods of inactivity. Valve discs shall rotate 90 degrees from the full-open position to the tight-shut position.
- E. Valve ends shall be flanged or mechanical joint. Flanged ends shall be compatible with ANSI B16.1 Class 125. Mechanical Joint ends shall be per AWWA C111. Mechanical Joint ends shall be mechanically restrained per Section 33 11 13.15 for specific pipe/valve size.
- F. Valve shafts shall be per AWWA C504, Section 4.2.3.
- G. Materials of construction shall be as described below:
 - 1. Body: Cast Iron or Ductile Iron per ASTM A 126 Class B
 - 2. Exposed Body Cap Screws and Bolts and Nuts: Type 316 Stainless Steel
 - 3. Discs: Cast Iron or Ductile Iron per ASTM A 126 Class B
 - 4. Seat: Buna-N Rubber
- H. The rubber seat shall be an integral part of the valve body. Rubber seats fastened to the disc by any means shall not be permitted.

2.08 BOLTS AND NUTS FOR FLANGED VALVES

- A. Bolts and nuts for flanged valves shall be Type 316 stainless steel in accordance with Section 33 11 13.15.

2.09 GASKETS

- A. Gaskets for flanged end valves shall be as described in Section 33 11 13.15.

2.10 VALVE BOXES FOR BURIED VALVES

- A. Valve extension pipe material shall be 8-inch PVC SDR 35 pipe.
- B. Design cast iron cap to rest within a frame on a cast-in-place concrete ring surrounding the valve extension pipe; size the tapered skirt of the cap for a close fit inside the upper sleeve portion of the valve box. Caps for the domestic water system shall be circular with the word "WATER" cast on the cap. Caps for the recycled water system shall be circular with "RECYCLED" cast on the cap. Coat the cap and frame with asphalt or coat-tar paint.

2.11 EXTENSION STEMS FOR BURIED VALVE OPERATORS

- A. Where the depth of the valve is such that its centerline is more than 4 feet below grade, provide operating extension stems to bring the operating nut to a point 24 to 30-inches below the surface of the ground and/or box cover.
- B. Extension stems shall be steel and shall be complete with 2-inch-square operating nut.
- C. Valve stem extensions shall be of a solid design (no pinned couplings permitted) with guides.
- D. Valve extensions shall conform with SLVWD Standard Detail SD-2.

PART 3 - EXECUTION

3.01 JOINTS

- A. Bolt holes of flanged valves shall straddle the horizontal and vertical centerlines of the pipe run to which the valves are attached. Clean flanges by wire brushing before installing flanged valves. Clean flange bolts and nuts by wire brushing, lubricate threads with oil and graphite, and tighten nuts uniformly and progressively. If flanges leak under pressure testing, loosen or remove the nuts and bolts, reseal or replace the gasket, reinstall or retighten the bolts and nuts, and retest the joints. Joints shall be watertight.
- B. Clean threaded joints by wire brushing or swabbing. Apply Teflon joint compound OR Teflon tape to pipe threads before installing threaded valves. Joints shall be watertight.
- C. Rubber ring grooves of valves shall be inspected before installation by the Contractor for ridges or holes that would interfere with the rubber ring. Interferences with the rubber ring shall be corrected to a satisfactory connection or the valves replaced, as required by the District. (All valves shall have the same rubber-ring groove profile as the groove of the pipe couplings furnished with the pipe.)

3.02 BUTTERFLY VALVE OPERATORS

- A. Butterfly valves shall be installed with the operators on the street centerline side of the pipeline.

3.03 EXTERIOR PROTECTION

- A. All exposed flanges and other metal surfaces and all damaged coatings shall be coated after assembly with bituminous mastic per Section 09 90 00 Coating of stainless-steel flange bolts is not required.
- B. Wrap buried valves with 8-mil polyethylene wrap per AWWA C10

3.04 CONCRETE SUPPORTS

- A. Valves shall be anchored in concrete as shown on plans.
- B. Concrete supports will not be required under valves bolted to flanged fittings.

- C. Until supports are poured, valves shall be temporarily supported by placing wooden skids underneath the valve so that the pipe is not subjected to the weight of the valve.

3.05 VALVE BOXES

- A. Valve boxes shall be firmly supported and shall be kept centered and plumb over the operating nut of the valve.
- B. Beveled sections of pipe will not be allowed at the top of the valve extension pipe. The top cut shall be square, and machine made.
- C. The box cover shall be flush with the surface of the finished pavement unless otherwise indicated on the Drawings.

3.06 BACKFILL

- A. All backfill within 24 inches of a valve shall be clean, washed sand.
- B. Backfill is to be placed and compacted in accordance with Section 31 23 00

3.07 VALVE LEAKAGE TESTING

- A. Test valves for leakage at the same time that the connecting pipelines are tested. See Section 33 11 00 for pressure testing requirements.
- B. Valves shall have a pressure rating higher than or equal to the test pressure.

END OF SECTION

SECTION 33 12 19

FIRE HYDRANTS

PART 1 - GENERAL

1.01 DESCRIPTION

- A. This section includes the materials, installation and testing of fire hydrants.
- B. Hydrants shall be supplied and installed per SLVWD Standard Detail SD-3, AWWA C 503 and as described herein.

1.02 RELATED WORK DESCRIBED ELSEWHERE

- A. All related work specified elsewhere, or in other codes or standards, will be as last revised, unless a specific date of issuance is called out in opposition to later revision date(s).
- B. Other sections of the technical specifications, not referenced below, shall also apply to the extent required for proper performance of this work.
 - 1. Trenching, Backfilling, and Compacting: 31 23 00
 - 2. Concrete: 03 30 00
 - 3. Painting and Coating: 09 90 00
 - 4. General Piping Requirements: 33 11 00
 - 5. Ductile Iron Pipe and Fittings: 33 11 13.15
 - 6. Manual Valves: 33 12 16

1.03 APPROVED WET BARREL HYDRANTS

- A. Clow 960
- B. James Jones 3740 (Hydrant Head and Fluted Spool),

PART 2 - MATERIALS

2.01 WET BARREL HYDRANT

- A. Hydrant Top Section
 - 1. Fire hydrants shall have individual valves for each outlet opening counter clockwise. Fire hydrants shall have one 2-1/2-inch hose nozzle and one 4-1/2-inch pumper nozzle.
 - 2. All outlets shall have National Standard Hose Threads.
 - 3. The hydrant top section shall be manufactured of bronze conforming to ASTM B 62.
 - 4. All interior working parts, including stems, shall be of bronze containing no more than 7% zinc or 2% aluminum.
 - 5. Hydrants are to be provided with:
 - a. 1-1/8-inch sized pentagon-shaped operating nut, and

- b. 1-1/8-inch cap nuts.
- 6. All fire hydrants shall have the name of the manufacturer cast onto the hydrant body or shown on a permanently attached plate.
- 7. Plastic outlet nozzle caps shall be provided for all outlets. Caps shall be securely chained to the barrel with non-kinking metal chain in a manner to permit free rotation of the cap.
- 8. All hydrant flanges shall be eight-hole regular, Class 125, American Standard cast iron flange drilling.

B. Bury Section

- 1. The bury section shall be 6-inch cast iron long radius bury elbow and shall be cement lined in conformance with Section 33 11 13.15. Bury inlet shall be 6-inch rubber-ring hub bell connection for C900 PVC pressure pipe.
- 2. A flanged ductile iron spool shall be installed to position the hydrant flange 4 inches above the concrete pad (finish grade).
- 3. All wet-barrel fire hydrant cast-iron buries are to be cement lined.
- 4. When using a riser spool, bolts shall be stainless steel 316, standard non-break-away.
- 5. Bury section outlet and riser spool flanges shall be eight-hole regular, Class 125, American Standard cast-iron flange drilling.

2.02 BREAK-OFF SPOOL

- A. Break-off spool shall be installed on hydrant riser with break-away bolts on upper flange.

2.03 VALVE

- A. The shut-off valve shall be a resilient-seated gate valve per Section 33 12 16, including the valve box. Butterfly valves will not be permitted on fire hydrant laterals.

2.04 DUCTILE IRON PIPE

- A. Ductile iron pipe shall be per Section 33 11 13.15.

2.05 DUCTILE IRON PIPE AND FITTINGS

- A. Ductile-iron Pipe and fittings shall be in accordance with Section 33 11 13.15.

2.06 CONCRETE

- A. Concrete pads and supports shall be Class B concrete conforming with Section 03 30 00.

2.07 GASKETS

- A. Gaskets shall be of rubber composition per Section 33 11 13.15.

PART 3 - EXECUTION

3.01 GENERAL

- A. Fire hydrant assemblies shall be installed in accordance with the standard drawing and as specified herein, and shall include the connection to the main, the fire hydrant, hydrant bury, shutoff valve, valve well and valve box, connection piping, concrete thrust blocks, and appurtenances.

3.02 LOCATION

- A. Fire hydrant assemblies shall be located as shown on the plans or as approved by the District representative. The center of the fire hydrant shall be, except as otherwise approved by the District representative, located as described below:
 - 1. Where concrete curb or asphalt concrete (A.C.) berm exists or is to be constructed, and the sidewalk is next to the property line; 1 foot 6 inches back of the back edge of the curb.
 - 2. Where 6-foot-wide or narrower sidewalk is to be installed or exists next to the curb; 12 inches back of sidewalk edge. Where there is insufficient public right-of-way behind the sidewalk, an easement will be required. For sidewalks wider than 6 feet; 18 inches back of the curb face.
 - 3. Where there is no curb or berm, the location shall be designated by the District representative.
 - 4. The flange elevation at the base of the hydrant shall be set 4-inches above the curb or sidewalk, or the surrounding graded area, or as approved by the District representative. Spools additional will not be permitted when correcting the flange elevation.

3.03 TRENCHING, BACKFILLING, AND COMPACTING

- A. All trenching, backfilling, compaction and other excavation shall be in accordance with Section 31 23 00.

3.04 VALVE AND VALVE BOX

- A. The valve and valve box shall be installed in accordance with Section 33 12 16.

3.05 DUCTILE IRON PIPE

- A. Ductile iron pipe shall be installed in conformance with Section 33 11 13.15.

3.06 CONCRETE

- A. The concrete pad shall be Class B concrete and thrust blocker shall be Class A concrete and shall be placed per Section 03 30 00.

3.07 PAINTING

- A. All public fire hydrants shall be painted with one prime coat and two finish coats of yellow paint at the place of manufacture. Before the fire hydrant has been installed in accordance with Section 09 90 00. A final touch-up coat shall be applied just prior to the final inspection.

3.08 TESTING

- A. Test hydrants at the same time that the connecting pipeline is pressure tested. See Section 33 11 00 for pressure testing requirements.

END OF SECTION

SECTION 40 91 13

AUTOMATIC VALVES

PART 1 - GENERAL

1.01 DESCRIPTION

- A. This section describes the materials and installation of self-contained automatic control valves.
- B. Items of equipment specified herein shall be the end products of a limited number of manufacturers in order to achieve standardization for operation, maintenance, spare parts, and manufacturer's service.

1.02 RELATED WORK

- A. Painting and Coating: 09 90 00
- B. Ductile-Iron Pipe and Fittings: 33 11 13.15
- C. Copper, Brass and Bronze Pipe, Fittings and Appurtenances: 22 11 13
- D. General Piping Requirements: 33 11 00

1.03 SUBMITTALS

- A. Submit manufacturer's data indicating the type and size of valves to be provided, and compliance with this specification.

PART 2 - MATERIALS

2.01 COMPLETE ASSEMBLIES

- A. All valves shall be complete, with all necessary operating appurtenances included in the work under this section.

2.02 INTERIOR LINING AND EXTERIOR COATING

- A. An epoxy coating shall be applied to internal and external ferrous valve surfaces. Coating shall be per AWWA C550. Unless specified otherwise, herein.

2.03 COMBINATION AIR RELEASE AND VACUUM RELIEF VALVE

- A. Combination Air release and vacuum relief valve for potable water service shall be:
 - 1. DeZurik Apco Series 140C
 - 2. Cla-Val Series 35
 - 3. Or approved equal

- B. Provide vent screen and cover
- C. Size as shown on the Drawings

2.04 PRESSURE REDUCING VALVE

- A. Pressure reducing valve with low flow by-pass shall be Cla-Val Model 90-48, globe-pattern, flanged end, pressure class 300, sized as shown on the Drawings.
- B. Adjustment ranges:
 - 1. Main Valve: 20 to 105 psi
 - 2. Bypass valve: 25 to 100 psi

PART 3 - EXECUTION

3.01 INSTALLATION

- A. Automatic control valves shall be installed above ground or within a vault to provide for adjustment, maintenance and repair. Direct burial of a control valve will not be permitted under any circumstance.
- B. Automatic control valves are to be installed with ductile iron piping per Section 33 11 13.15, unless indicated differently on the Drawings.
- C. Prior to purchase of material, inspect valve to confirm valve size, manufacturer, and part number.

3.02 VALVE ADJUSTMENT AND TESTING

- A. All valves installed, replaced, refurbished, or adjusted shall be tested for normal operation.
- B. Valves shall be readjusted if necessary, to operate at the design pressure.

END OF SECTION