

750 Royal Oaks Drive, Suite 100
Monrovia, California 91016-3629
Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Report

for

San Lorenzo Valley Water District
13060 Highway 9
Boulder Creek, CA 95006-9119
Attention: Nate Gillespie
Fax: 831-338-8002

Date of Issue
09/16/2020



**EUROFINS EATON
ANALYTICAL, LLC**

UMVN: Monica Van Natta
Project Manager

Report: 892530
Project: SPECIAL
Group: Fire Investigation



Utah ELCP CA00006

* Accredited in accordance with TNI 2016 and ISO/IEC 17025:2017.

* Laboratory certifies that the test results meet all **TNI 2016 and ISO/IEC 17025:2017** requirements unless noted under the individual analysis.

* Following the cover page are State Certification List, ISO 17025 Accredited Method List, Acknowledgement of Samples Received, Comments, Hits Report, Data Report, QC Summary, QC Report and Regulatory Forms, as applicable.

* Test results relate only to the sample(s) tested.

* Test results apply to the sample(s) as received, unless otherwise noted in the comments report (ISO/IEC 17025:2017).

* This report shall not be reproduced except in full, without the written approval of the laboratory.

* This report includes ISO/IEC 17025 and non-ISO 17025 accredited methods.

STATE CERTIFICATION LIST

State	Certification Number	State	Certification Number
Alabama	41060	Montana	Cert 0035
Arizona	AZ0778	Nebraska	Certified
Arkansas	Certified	Nevada	CA000062018
California	2813	New Hampshire *	2959
Colorado	Certified	New Jersey *	CA 008
Connecticut	PH-0107	New Mexico	Certified
Delaware	CA 006	New York *	11320
Florida *	E871024	North Carolina	06701
Georgia	947	North Dakota	R-009
Guam	18-005R	Oregon *	CA200003-005
Hawaii	Certified	Pennsylvania *	68-565
Idaho	Certified	Puerto Rico	Certified
Illinois *	200033	Rhode Island	LAO00326
Indiana	C-CA-01	South Carolina	87016
Iowa - Asbestos	413	South Dakota	Certified
Kansas *	E-10268	Tennessee	TN02839
Kentucky	90107	Texas *	T104704230-18-15
Louisiana *	LA180000	Utah (Primary AB) *	CA00006
Maine	CA0006	Vermont	VT0114
Maryland	224	Virginia *	460260
Commonwealth of Northern Marianas Is.	MP0004	Washington	C838
Massachusetts	M-CA006	EPA Region 5	Certified
Michigan	9906	Los Angeles County Sanitation Districts	10264
Mississippi	Certified		

* NELAP/TNI Recognized Accreditation Bodies

ISO/IEC 17025 Accredited Method List

The tests listed below are accredited and meet the requirements of ISO/IEC 17025 as verified by the ANSI-ASQ National Accreditation Board/A2LA.
Refer to Certificate and scope of accreditation (5890) found at: <https://www.eurofinsus.com/Eaton>

SPECIFIC TESTS	METHOD OR TECHNIQUE USED	Environ-mental (Drinking Water)	Environ-mental (Waste Water)	Water as a Component of Food and Bev/Bev/ Bottled Water
1,2,3-TCP (5 PPT & 0.5 PPT)	CA SRL 524M-TCP	x		x
1,4-Dioxane	EPA 522	x		x
2,3,7,8-TCDD	Modified EPA 1613B	x		x
Acrylamide	In House Method (2440)	x		x
Algal Toxins/Microcystin	In House Method (3570)			
Alkalinity	SM 2320B	x	x	x
Ammonia	EPA 350.1		x	x
Ammonia	SM 4500-NH3 H		x	x
Anions and DBPs by IC	EPA 300.0	x	x	x
Anions and DBPs by IC	EPA 300.1	x		x
Asbestos	EPA 100.2	x	x	
BOD / CBOD	SM 5210B		x	x
Bromate	In House Method (2447)	x		x
Carbamates	EPA 531.2	x		x
Carbonate as CO3	SM 2330B	x	x	x
Carbonyls	EPA 556	x		x
COD	EPA 410.4 / SM 5220D		x	
Chloramines	SM 4500-CL G	x	x	x
Chlorinated Acids	EPA 515.4	x		x
Chlorinated Acids	EPA 555	x		x
Chlorine Dioxide	SM 4500-CLO2 D Palin Test	x		x
Chlorine -Total/Free/ Combined Residual	SM 4500-Cl G	x	x	x
Conductivity	EPA 120.1		x	
Conductivity	SM 2510B	x	x	x
Corrosivity (Langelier Index)	SM 2330B	x		x
Cyanide, Amenable	SM 4500-CN G	x	x	
Cyanide, Free	SM 4500CN F	x	x	x
Cyanide, Total	EPA 335.4	x	x	x
Cyanogen Chloride (screen)	In House Method (2470)	x		x
Diquat and Paraquat	EPA 549.2	x		x
DBP/HAA	SM 6251B	x		x
Dissolved Oxygen	SM 4500-O G		x	x
DOC	SM 5310C	x		x
E. Coli	(MTF/EC+MUG)	x		x
E. Coli	CFR 141.21(f)(6)(i)	x		x
E. Coli	SM 9223		x	
E. Coli (Enumeration)	SM 9221B.1/ SM 9221F	x		x
E. Coli (Enumeration)	SM 9223B	x		x
EDB/DCBP	EPA 504.1	x		
EDB/DBCP and DBP	EPA 551.1	x		x
EDTA and NTA	In House Method (2454)	x		x
Endothall	EPA 548.1	x		x
Endothall	In-house Method (2445)	x		x
Enterococci	SM 9230B	x	x	
Fecal Coliform	SM 9221 E (MTF/EC)	x		
Fecal Coliform	SM 9221C, E (MTF/EC)		x	
Fecal Coliform (Enumeration)	SM 9221E (MTF/EC)	x		x
Fecal Coliform with Chlorine Present	SM 9221E		x	
Fecal Streptococci	SM 9230B	x	x	
Fluoride	SM 4500-F C	x	x	x
Glyphosate	EPA 547	x		x
Glyphosate + AMPA	In House Method (3618)	x		x
Gross Alpha/Beta	EPA 900.0	x	x	x
Gross Alpha Coprecipitation	SM 7110 C	x	x	x
Hardness	SM 2340B	x	x	x
Heterotrophic Bacteria	In House Method (2439)	x		x
Heterotrophic Bacteria	SM 9215 B	x		x
Hexavalent Chromium	EPA 218.6	x	x	x

SPECIFIC TESTS	METHOD OR TECHNIQUE USED	Environ-mental (Drinking Water)	Environ-mental (Waste Water)	Water as a Component of Food and Bev/Bev/ Bottled Water
Hexavalent Chromium	EPA 218.7	x		x
Hexavalent Chromium	SM 3500-Cr B		x	
Hormones	EPA 539	x		x
Hydroxide as OH Calc.	SM 2330B	x		x
Kjeldahl Nitrogen	EPA 351.2		x	
Legionella	Legiolert	x		x
Mercury	EPA 200.8	x		x
Metals	EPA 200.7 / 200.8	x	x	x
Microcystin LR	ELISA (2360)	x		x
Microcystin, Total	EPA 546	x		x
NDMA	EEA/Agilent 521.1 In house method (2425)	x		x
Nitrate/Nitrite Nitrogen	EPA 353.2	x	x	x
OCL, Pesticides/PCB	EPA 505	x		x
Ortho Phosphate	EPA 365.1	x	x	x
Ortho Phosphorous	SM 4500P E	x		x
Oxyhalides Disinfection Byproducts	EPA 317.0	x		x
Perchlorate	EPA 331.0	x		x
Perchlorate (low and high)	EPA 314.0	x		x
Perfluorinated Alkyl Acids	EPA 537	x		x
Perfluorinated Pollutant	In house Method (2434)	x		x
pH	EPA 150.1	x		
pH	SM 4500-H+B	x	x	x
Phenylurea Pesticides/ Herbicides	In House Method, based on EPA 532 (2448)	x		x
Pseudomonas	IDEXX Pseudalart (2461)	x		x
Radium-226	GA Institute of Tech	x		x
Radium-228	GA Institute of Tech	x		x
Radon-222	SM 7500RN	x		x
Residue, Filterable	SM 2540C	x	x	x
Residue, Non-filterable	SM 2540D		x	
Residue, Total	SM 2540B		x	x
Residue, Volatile	EPA 160.4		x	
Semi-VOC	EPA 525.2	x		x
Silica	SM 4500-Si D	x	x	
Silica	SM 4500-SiO2 C	x	x	
Sulfide	SM 4500-S ⁻ D		x	
Sulfite	SM 4500-SO ³ B	x	x	x
Surfactants	SM 5540C	x	x	x
Taste and Odor Analytes	SM 6040E	x		x
Total Coliform (P/A)	SM 9221 A, B	x		x
Total Coliform (Enumeration)	SM 9221 A, B, C	x		x
Total Coliform / E. coli	Colisure SM 9223	x		x
Total Coliform	SM 9221B		x	
Total Coliform with Chlorine Present	SM 9221B		x	
Total Coliform / E.coli (P/A and Enumeration)	SM 9223	x		x
TOC	SM 5310C	x	x	x
TOX	SM 5320B		x	
Total Phenols	EPA 420.1		x	
Total Phenols	EPA 420.4	x	x	x
Total Phosphorous	SM 4500 P E		x	
Triazine Pesticides & Degradates	In House (3617)	x		x
Turbidity	EPA 180.1	x	x	x
Turbidity	SM 2130B	x	x	
Uranium by ICP/MS	EPA 200.8	x		x
UV 254	SM 5910B	x		
VOC	EPA 524.2	x		x
VOC	In House Method (2411)	x		x
Yeast and Mold	SM 9610	x		x
Field Sampling	N/A			

Acknowledgement of Samples Received

Addr: **San Lorenzo Valley Water District**
 13060 Highway 9
 Boulder Creek, CA 95006-9119

Client ID: SANLORENZO
 Folder #: 892530
 Project: SPECIAL
 Sample Group: Fire Investigation

Attn: Nate Gillespie
 Phone: 831-216-9019

Project Manager: Monica Van Natta
 Phone: 559-797-1931

The following samples were received from you on **September 15, 2020 at 0953**. They have been scheduled for the tests listed below each sample. If this information is incorrect, please contact your service representative. Thank you for using Eurofins Eaton Analytical, LLC.

Sample #	Sample ID	Sample Date
<u>202009150083</u>	Boulder Creek Fire House	09/12/2020 1115
	@VOASDWA C RUSH	
<u>202009150085</u>	376 Ralston Ridge	09/12/2020 1415
	Water Trax ID: 3BCA8	
	@VOASDWA C RUSH	
<u>202009150086</u>	Teilh and redwood Dr	09/12/2020 1040
	Water Trax ID: 3BCA1	
	@VOASDWA C RUSH	
<u>202009150087</u>	Fern and Reynolds Dr	09/12/2020 1100
	Water Trax ID: 3BCA0	
	@VOASDWA C RUSH	
<u>202009150088</u>	600 Debbie	09/12/2020 0930
	Water Trax ID: 3BCAC	
	@VOASDWA C RUSH	
<u>202009150089</u>	814 Creek Dr	09/12/2020 1020
	Water Trax ID: 3BCA2	
	@VOASDWA C RUSH	
<u>202009150090</u>	12788 Hwy 9	09/12/2020 1030
	Water Trax ID: 3BC98	
	@VOASDWA C RUSH	
<u>202009150091</u>	15177 Bear Creek Rd	09/12/2020 1215
	Water Trax ID: 3BCA7	
	@VOASDWA C RUSH	
<u>202009150092</u>	15030 Hwy 9	09/12/2020 0950
	Water Trax ID: 3BCA5	
	@VOASDWA C RUSH	
<u>202009150093</u>	Hwy 9 and Celia	09/12/2020 1125
	Water Trax ID: 3BC9E	
	@VOASDWA C RUSH	
<u>202009150094</u>	336 Blackstone Terrace	09/12/2020 1145
	Water Trax ID: 3BC9C	

Acknowledgement of Samples Received

Addr: **San Lorenzo Valley Water District**
13060 Highway 9
Boulder Creek, CA 95006-9119

Client ID: SANLORENZO

Folder #: 892530

Project: SPECIAL

Sample Group: Fire Investigation

Attn: Nate Gillespie
Phone: 831-216-9019

Project Manager: Monica Van Natta
Phone: 559-797-1931

The following samples were received from you on **September 15, 2020 at 0953**. They have been scheduled for the tests listed below each sample. If this information is incorrect, please contact your service representative. Thank you for using Eurofins Eaton Analytical, LLC.

Sample #	Sample ID	Sample Date
	@VOASDWA C RUSH	
<u>202009150095</u>	Hwy 9 and Alameda Water Trax ID: 3BCA9	09/12/2020 0910
	@VOASDWA C RUSH	
<u>202009150096</u>	Pinecrest and Middleton Water Trax ID: 3BCA6	09/12/2020 1245
	@VOASDWA C RUSH	
<u>202009150097</u>	Rebecca and Elsie May Water Trax ID: 3BCAD	09/12/2020 1000
	@VOASDWA C RUSH	
<u>202009150098</u>	15715 Forest Hill rd Water Trax ID: 3BC97	09/12/2020 1345
	@VOASDWA C RUSH	

Test Description

@VOASDWA C -- Volatile Organics by GCMS



Eaton Analytical

CHAIN OF CUSTODY RECORD

EUROFINS EATON ANALYTICAL USE ONLY:

750 Royal Oaks Drive, Suite 100
Monrovia, CA 91016-3629
Phone: 626 386 1100
Fax: 626 386 1101
800 566 LABS (800 566 5227)
Website: www.EatonAnalytical.com

LOGIN COMMENTS:

SAMPLES CHECKED AGAINST COC BY: h

SAMPLE TEMP RECEIVED AT:
☐ Colton / No. California / Arizona
☒ Mentrovia

SAMPLES LOGGED IN BY: je

SAMPLES REC'D DAY OF COLLECTION? ☐ (check for yes)

°C (Compliance: 4 ± 2 °C)
4.1 °C (Compliance: 4 ± 2 °C)

CONDITION OF BLUE ICE: Frozen 2 Partially Frozen 2 Thawed 2 Wet Ice 2 No Ice 2
METHOD OF SHIPMENT: Pick-Up / Walk-In / FedEx / UPS / DHL / Area Fast / Top Line / Other: 2

TO BE COMPLETED BY SAMPLER:

COMPANY/AGENCY NAME: San Lorenzo Valley Water District		PROJECT CODE: 4410014 TRAX 8410	COMPLIANCE SAMPLES - Requires state forms Type of samples (circle one): ROUTINE ☒ SPECIAL ☐ CONFIRMATION (eg. SDWA, Phase V, NPDES, FDA, ...)		NON-COMPLIANCE SAMPLES REGULATION INVOLVED:	
EEA CLIENT CODE:	COC ID:	SAMPLE GROUP:	SEE ATTACHED BOTTLE ORDER FOR ANALYSES ☒ (check for yes), <u>OR</u>			
TAT requested: rush by adv notice only			list ANALYSES REQUIRED (enter number of bottles sent for each test for each sample)			

TAT requested: rush by adv notice only				STD_X_ 1 wk ___ 3 day ___ 2 day ___ 1 day 												SAMPLER COMMENTS Trax#'s total CI			
SAMPLE DATE	SAMPLE TIME	SAMPLE ID	CLIENT LAB ID	MATRIX *	Temp C.	free CL2 Residual													
9/12/20	1115	4410014	Boulder Creek Fire House	CFW	20.5	0.57												~	0.68
9/12/20	1415	4410014	376 Ralston Ridge	CFW	21.1	0.66												3BCA8	0.70
9/12/20	1040	4410014	Teilh and redwood Dr	CFW	19.4	0.56												3BCA1	0.62
9/12/20	1100	4410014	Fern and Reynolds Dr	CFW	19.3	0.81												3BCA0	0.86
9/12/20	0930	4410014	600 Debbie	CFW	20.7	0.60												3BCAC	0.71
9/12/20	1020	4410014	814 Creek Dr	CFW	19.0	0.50												3BCA2	0.52
9/12/20	1030	4410014	12788 Hwy 9	CFW	19.6	0.97												3BC98	1.01
9/12/20	1215	4410014	15177 Bear Creek Rd	CFW	20.3	0.71												3BCA7	0.75
9/12/20	0950	4410014	15030 Hwy 9	CFW	18.6	0.78												3BCA5	0.80
9/12/20	1125	4410014	Hwy 9 and Celia	CFW	19.2	0.78												3BC9E	0.84

* MATRIX TYPES: RSW = Raw Surface Water CFW = Chlor(am)inated Finished Water SEAW = Sea Water BW = Bottled Water SO = Soil O = Other - Please Identify
RGW = Raw Ground Water FW = Other Finished Water WW = Waste Water SW = Storm Water SL = Sludge

SAMPLED BY:	SIGNATURE	PRINT NAME	COMPANY/TITLE	DATE	TIME
RELINQUISHED BY:	<u>Sam Sparks</u>	Guiver + Mitchell	SLVWD treatment and systems oper	9/12/20	various
RECEIVED BY:		<u>Hefelick</u>	SLVWD treatment and systems oper	9/14/20	1445
RELINQUISHED BY:					
RECEIVED BY:	<u>cy</u>	<u>WVP</u>		9/15/20	9:53

EUROFINS EATON ANALYTICAL USE ONLY:

750 Royal Oaks Drive, Suite 100
Monrovia, CA 91016-3629

Phone: 626 386 1100
Fax: 626 386 1101

800 566 LABS (800 566 5227)

Website: www.EatonAnalytical.com

LOGIN COMMENTS:

SAMPLES CHECKED AGAINST COC BY:

730 Royal Oaks Drive,
Monrovia, CA 91016-3300

SAMPLES LOGGED IN BY:

SAMPLE TEMP RECEIVED AT:

Colton / No. California / Arizona

Monrovia

°C (Compliance: 4 ± 2 °C)

°C (Compliance: $1 + 2^{\circ}\text{C}$)

o (complication)

Partially Frozen _____ Thawed _____ Wet Ice _____ No Ice _____

in / FedEx / UPS / DHL / Area Fast / Top Line / Other:

TO BE COMPLETED BY SAMPLER:

(check for ves)

(check for ves)

[illegible]

* **MATRIX TYPES:** RSW = Raw Surface Water
RGW = Raw Ground Water
CFW = Chlor(am)inated Finished Water
FW = Other Finished Water
SEAW = Sea Water
WW = Waste Water
BW = Bottled Water
SW = Storm Water
SO = Soil
SL = Sludge
O = Other - Please Identify

SIGNATURE	PRINT NAME	COMPANY/TITLE	DATE	TIME
SAMPLED BY:	Guiver + Mitchell	SLVWD treatment and systems oper	9/12/20	various
RELINQUISHED BY:	<i>for standard</i>	SLVWD treatment and systems oper	9/14/20	1445
RECEIVED BY:				
RELINQUISHED BY:				
RECEIVED BY:	<i>YUN</i>	<i>ESD</i>	9/15/20	9:53



Eaton Analytical

INTERNAL CHAIN OF CUSTODY RECORD

EEA Folder Number

622530

SAMPLE TEMP RECEIVED:

Note: If samples are out of temperature range, let the ASMs know. ASMs will determine whether to proceed with analysis or not.

SAMPLES REC'D DAY OF COLLECTION? Yes / No

IR Gun ID = 6884 (Observation = 4.3 °C) (Corr. Factor P-2 °C) (Final = 4.1 °C)

TYPE OF ICE: Real ☒ Synthetic ☒ No Ice ☐ CONDITION OF ICE: Frozen ☒ Partially Frozen ☐ Thawed ☐ N/A ☐

METHOD OF SHIPMENT: Pick-Up / Walk-In / FedEx / UPS / DHL / Area Fast / Top Line / Other: FedEx

Compliance Acceptance Criteria:

1) Chemistry: $>0, \leq 6^{\circ}\text{C}$, not frozen (NELAP) (if received after 24 hrs of sample collection)

2) Microbiology, Distribution: $< 10^{\circ}\text{C}$, not frozen (can be $\geq 10^{\circ}\text{C}$ if received on ice the same day as sample collection, within 8 hours)

3) Microbiology, Surface Water: $< 10^{\circ}\text{C}$ (if received after 2 hours of sample collection)

If out of temperature range for both Chemistry and Microbiology samples and temperature does not confirm, then measure the temperature of each quadrant and record each temperature of the quadrants

1 = (Observation = <u>4.3</u> °C) (Corr. Factor <u>P-2</u> °C) (Final = <u>4.1</u> °C)	2 = (Observation = <u>4.1</u> °C) (Corr. Factor <u>P-2</u> °C) (Final = <u>4.1</u> °C)
3 = (Observation = <u>4.1</u> °C) (Corr. Factor <u>P-2</u> °C) (Final = <u>4.1</u> °C)	4 = (Observation = <u>4.1</u> °C) (Corr. Factor <u>P-2</u> °C) (Final = <u>4.1</u> °C)

4) Dioxin (1613 or 2,3,7,8 TCDD): must be between $0-4^{\circ}\text{C}$, not frozen (if received after 24 hrs of sample collection)

5) pH Check. Manufacturer: Lot Number: pH strip type: 0 - 14 or Expiration Date: Results:

6) Chlorine check. Manufacturer: Sansafe. Lot No.: Expiration Date: Results:

7) VOA and Radon Headspace: ☐

No Samples with Headspace:

Samples with Headspace (see below): ☐

Headspace Documentation (use additional VOC and Radon Internal COFC for additional bottles)

Exempt from headspace concerns: Methods 515.4, HAA(6251,552), 505, SPME, @CH, 532LCMS, 556, 536, Anatoxin, LCMS methods using 40 ml vials, International clients:

Samp ID	Bottle #	mm	>6mm	Samp ID	Bottle #	mm	>6mm	Samp ID	Bottle #	mm	>6mm

Note Sample IDs which have dissimilar headspace (i.e. potential sampling errors):

RECEIVED BY:	SIGNATURE	PRINT NAME	COMPANY/TITLE	DATE	TIME
		W	Eurofins Eaton Analytical	9/15/20	9:53



Eaton Analytical

Kit Order for San Lorenzo Valley Water District

Monica Van Natta is your Eurofins Eaton Analytical, LLC Service Manager

750 Royal Oaks Drive, Suite 100
Monrovia, California 91016-3629
(626) 386-1100 FAX (866) 988-3757

Kit #: 271007



Created By: Monica Van Natta - [UMVN]

Deliver By: 08/25/2020

STG: Bottle Orders

Ice Type: G

Client ID: SANLORENZO



Project Code: SPECIAL Bottle Orders

Group Name: Fire Investigation

PO#/JOB#:

Description: No Schedule

Created Date & Time: 8/21/2020 2:23:24PM

Note: Sampler Please return this paper with your samples

Ship Sample Kits to Attn: Hugh Dalton 525 Pine Street Aptos, CA 95003 Attn: SLV Water District Phone: 8313385002
--

Send Report to San Lorenzo Valley Water District 13060 Highway 9 Boulder Creek, CA 95006-9119 Attn: Nate Gillespie Phone: 831-216-9019 Fax: 831-338-8002

Billing Address San Lorenzo Valley Water District 13060 Highway 9 Boulder Creek, 95006 Attn: Rachel Munoz Phone: 831.338.2153 Fax: 831.338.7986
--

# of Sample Tests	Bottle Qty - Type [preservative information]	Total	UN DOT #
10 @VOASDWA C	3 - 40ml amber glass vial [25mg Ascorbic+drop 2ml 1:1 HCL]	30	UN1789
1	1 - RETURN AIRBILL [no preservative]	1	

Sum Tests: 11

Sum Bottles: 31

Comments

Client - please use ice cubes in addition to the provided gel ice packs during hot summer months.

SHIPPING: please include return shipping labels and gel ice packs

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Comments

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Analyzed	Analyte	Sample ID	Result	Federal MCL	Units	MRL
202009150083 <u>Boulder Creek Fire House</u>						
09/15/2020 19:09	Bromodichloromethane		1.1		ug/L	0.50
09/15/2020 19:09	Chlorodibromomethane		1.2		ug/L	0.50
09/15/2020 19:09	Chloroform (Trichloromethane)		1.0		ug/L	0.50
09/15/2020 19:09	Total THM		3.3	80	ug/L	0.50
202009150085 <u>376 Ralston Ridge</u>						
09/15/2020 19:32	Bromodichloromethane		2.8		ug/L	0.50
09/15/2020 19:32	Bromoform		0.65		ug/L	0.50
09/15/2020 19:32	Chloroform (Trichloromethane)		3.0		ug/L	0.50
09/15/2020 19:32	Total THM		6.4	80	ug/L	0.50
202009150086 <u>Teilh and redwood Dr</u>						
09/15/2020 19:56	Bromodichloromethane		2.1		ug/L	0.50
09/15/2020 19:56	Bromoform		0.60		ug/L	0.50
09/15/2020 19:56	Chlorodibromomethane		1.7		ug/L	0.50
09/15/2020 19:56	Chloroform (Trichloromethane)		2.7		ug/L	0.50
09/15/2020 19:56	Total THM		7.1	80	ug/L	0.50
202009150087 <u>Fern and Reynolds Dr</u>						
09/15/2020 20:20	Bromodichloromethane		2.4		ug/L	0.50
09/15/2020 20:20	Bromoform		0.58		ug/L	0.50
09/15/2020 20:20	Chlorodibromomethane		1.7		ug/L	0.50
09/15/2020 20:20	Chloroform (Trichloromethane)		3.8		ug/L	0.50
09/15/2020 20:20	Total THM		8.5	80	ug/L	0.50
202009150088 <u>600 Debbie</u>						
09/15/2020 20:43	Bromodichloromethane		1.3		ug/L	0.50
09/15/2020 20:43	Chlorodibromomethane		1.2		ug/L	0.50
09/15/2020 20:43	Chloroform (Trichloromethane)		1.5		ug/L	0.50
09/15/2020 20:43	Total THM		4.0	80	ug/L	0.50
202009150089 <u>814 Creek Dr</u>						
09/15/2020 21:08	Bromodichloromethane		2.8		ug/L	0.50
09/15/2020 21:08	Bromoform		0.65		ug/L	0.50
09/15/2020 21:08	Chlorodibromomethane		2.2		ug/L	0.50
09/15/2020 21:08	Chloroform (Trichloromethane)		3.6		ug/L	0.50
09/15/2020 21:08	Total THM		9.2	80	ug/L	0.50
202009150090 <u>12788 Hwy 9</u>						

SUMMARY OF POSITIVE DATA ONLY

Tel: (626) 386-1100
Fax: (626) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Analyzed	Analyte	Sample ID	Result	Federal MCL	Units	MRL
09/15/2020 21:31	Bromodichloromethane		0.93		ug/L	0.50
09/15/2020 21:31	Chlorodibromomethane		0.94		ug/L	0.50
09/15/2020 21:31	Chloroform (Trichloromethane)		0.85		ug/L	0.50
09/15/2020 21:31	Total THM		2.7	80	ug/L	0.50
202009150091 <u>15177 Bear Creek Rd</u>						
09/15/2020 21:55	Bromodichloromethane		1.3		ug/L	0.50
09/15/2020 21:55	Chlorodibromomethane		1.4		ug/L	0.50
09/15/2020 21:55	Chloroform (Trichloromethane)		1.3		ug/L	0.50
09/15/2020 21:55	Total THM		4.0	80	ug/L	0.50
202009150092 <u>15030 Hwy 9</u>						
09/15/2020 22:18	Bromodichloromethane		1.5		ug/L	0.50
09/15/2020 22:18	Bromoform		0.60		ug/L	0.50
09/15/2020 22:18	Chlorodibromomethane		1.4		ug/L	0.50
09/15/2020 22:18	Chloroform (Trichloromethane)		1.7		ug/L	0.50
09/15/2020 22:18	Total THM		5.2	80	ug/L	0.50
202009150093 <u>Hwy 9 and Celia</u>						
09/15/2020 22:42	Bromodichloromethane		3.2		ug/L	0.50
09/15/2020 22:42	Chlorodibromomethane		1.8		ug/L	0.50
09/15/2020 22:42	Chloroform (Trichloromethane)		7.6		ug/L	0.50
09/15/2020 22:42	Total THM		13	80	ug/L	0.50
202009150094 <u>336 Blackstone Terrace</u>						
09/15/2020 23:06	Bromodichloromethane		1.3		ug/L	0.50
09/15/2020 23:06	Chlorodibromomethane		1.3		ug/L	0.50
09/15/2020 23:06	Chloroform (Trichloromethane)		1.4		ug/L	0.50
09/15/2020 23:06	Total THM		4.0	80	ug/L	0.50
202009150095 <u>Hwy 9 and Alameda</u>						
09/15/2020 23:29	Bromodichloromethane		1.0		ug/L	0.50
09/15/2020 23:29	Chlorodibromomethane		0.94		ug/L	0.50
09/15/2020 23:29	Chloroform (Trichloromethane)		1.1		ug/L	0.50
09/15/2020 23:29	Total THM		3.0	80	ug/L	0.50
202009150096 <u>Pinecrest and Middleton</u>						
09/15/2020 23:52	Bromodichloromethane		4.4		ug/L	0.50
09/15/2020 23:52	Chlorodibromomethane		2.6		ug/L	0.50
09/15/2020 23:52	Chloroform (Trichloromethane)		7.2		ug/L	0.50
09/15/2020 23:52	Ethyl benzene		0.53	700	ug/L	0.50

SUMMARY OF POSITIVE DATA ONLY

Tel: (626) 386-1100
Fax: (626) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Hits

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Analyzed	Analyte	Sample ID	Result	Federal MCL	Units	MRL
09/15/2020 23:52	m,p-Xylenes		1.6	10000	ug/L	0.50
09/15/2020 23:52	Toluene		0.55	1000	ug/L	0.50
09/15/2020 23:52	Total THM		14	80	ug/L	0.50
09/15/2020 23:52	Total xylenes		1.6	10000	ug/L	0.50
202009150097 <u>Rebecca and Elsie May</u>						
09/16/2020 00:16	Bromodichloromethane		1.3		ug/L	0.50
09/16/2020 00:16	Bromoform		0.52		ug/L	0.50
09/16/2020 00:16	Chlorodibromomethane		1.2		ug/L	0.50
09/16/2020 00:16	Chloroform (Trichloromethane)		1.4		ug/L	0.50
09/16/2020 00:16	Total THM		4.4	80	ug/L	0.50
202009150098 <u>15715 Forest Hill rd</u>						
09/16/2020 00:39	Bromodichloromethane		2.0		ug/L	0.50
09/16/2020 00:39	Bromoform		0.50		ug/L	0.50
09/16/2020 00:39	Chlorodibromomethane		1.6		ug/L	0.50
09/16/2020 00:39	Chloroform (Trichloromethane)		2.0		ug/L	0.50
09/16/2020 00:39	Total THM		6.1	80	ug/L	0.50

Tel: (626) 386-1100
Fax: (626) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
Boulder Creek Fire House (202009150083)						Sampled on 09/12/2020 1115			
EPA 524.2 - Volatile Organics by GCMS									
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Bromodichloromethane	1.1	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Bromoform	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Chlorodibromomethane	1.2	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Chloroform (Trichloromethane)	1.0	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Total THM	3.3	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane-d4	102	%		1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	4-Bromofluorobenzene	89	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Toluene-d8	96	%		1
376 Ralston Ridge (202009150085)						Sampled on 09/12/2020 1415			
Water Trax ID: 3BCA8									
EPA 524.2 - Volatile Organics by GCMS									
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Bromodichloromethane	2.8	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Bromoform	0.65	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Chlorodibromomethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Chloroform (Trichloromethane)	3.0	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Total THM	6.4	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane-d4	100	%		1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	4-Bromofluorobenzene	90	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Toluene-d8	97	%		1
Teilh and redwood Dr (202009150086)						Sampled on 09/12/2020 1040			
Water Trax ID: 3BCA1									
EPA 524.2 - Volatile Organics by GCMS									
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Bromodichloromethane	2.1	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Bromoform	0.60	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Chlorodibromomethane	1.7	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Chloroform (Trichloromethane)	2.7	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Total THM	7.1	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane-d4	106	%		1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	4-Bromofluorobenzene	92	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Toluene-d8	97	%		1
Fern and Reynolds Dr (202009150087)						Sampled on 09/12/2020 1100			
Water Trax ID: 3BCA0									
EPA 524.2 - Volatile Organics by GCMS									
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Bromodichloromethane	2.4	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Bromoform	0.58	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Chlorodibromomethane	1.7	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Chloroform (Trichloromethane)	3.8	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Total THM	8.5	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane-d4	104	%		1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	4-Bromofluorobenzene	95	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Toluene-d8	97	%		1
600 Debbie (202009150088)						Sampled on 09/12/2020 0930			
Water Trax ID: 3BCAC									
EPA 524.2 - Volatile Organics by GCMS									
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Bromodichloromethane	1.3	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Bromoform	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Chlorodibromomethane	1.2	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Chloroform (Trichloromethane)	1.5	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Total THM	4.0	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane-d4	101	%		1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	4-Bromofluorobenzene	91	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Toluene-d8	96	%		1
814 Creek Dr (202009150089)						Sampled on 09/12/2020 1020			
Water Trax ID: 3BCA2									
EPA 524.2 - Volatile Organics by GCMS									
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Bromodichloromethane	2.8	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Bromoform	0.65	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Chlorodibromomethane	2.2	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Chloroform (Trichloromethane)	3.6	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Total THM	9.2	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane-d4	106	%		1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	4-Bromofluorobenzene	93	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Toluene-d8	94	%		1
12788 Hwy 9 (202009150090)						Sampled on 09/12/2020 1030			
Water Trax ID: 3BC98									
EPA 524.2 - Volatile Organics by GCMS									
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Bromodichloromethane	0.93	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Bromoform	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Chlorodibromomethane	0.94	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Chloroform (Trichloromethane)	0.85	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Total THM	2.7	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane-d4	101	%		1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	4-Bromofluorobenzene	94	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Toluene-d8	97	%		1
15177 Bear Creek Rd (202009150091)						Sampled on 09/12/2020 1215			
Water Trax ID: 3BCA7									
EPA 524.2 - Volatile Organics by GCMS									
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Bromodichloromethane	1.3	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Bromoform	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Chlorodibromomethane	1.4	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Chloroform (Trichloromethane)	1.3	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Total THM	4.0	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane-d4	102	%		1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	4-Bromofluorobenzene	97	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Toluene-d8	99	%		1
15030 Hwy 9 (202009150092)						Sampled on 09/12/2020 0950			
Water Trax ID: 3BCA5									
EPA 524.2 - Volatile Organics by GCMS									
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Bromodichloromethane	1.5	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Bromoform	0.60	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Chlorodibromomethane	1.4	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Chloroform (Trichloromethane)	1.7	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Total THM	5.2	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane-d4	101	%		1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	4-Bromofluorobenzene	94	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Toluene-d8	96	%		1
Hwy 9 and Celia (202009150093)						Sampled on 09/12/2020 1125			
Water Trax ID: 3BC9E									
EPA 524.2 - Volatile Organics by GCMS									
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Bromodichloromethane	3.2	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Bromoform	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Chlorodibromomethane	1.8	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Chloroform (Trichloromethane)	7.6	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Total THM	13	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane-d4	106	%		1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	4-Bromofluorobenzene	92	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Toluene-d8	96	%		1
336 Blackstone Terrace (202009150094)						Sampled on 09/12/2020 1145			
Water Trax ID: 3BC9C									
EPA 524.2 - Volatile Organics by GCMS									
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Bromodichloromethane	1.3	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Bromoform	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Chlorodibromomethane	1.3	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Chloroform (Trichloromethane)	1.4	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Total THM	4.0	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane-d4	108	%		1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	4-Bromofluorobenzene	88	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Toluene-d8	97	%		1
Hwy 9 and Alameda (202009150095)						Sampled on 09/12/2020 0910			
Water Trax ID: 3BCA9									
EPA 524.2 - Volatile Organics by GCMS									
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Bromodichloromethane	1.0	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Bromoform	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Chlorodibromomethane	0.94	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Chloroform (Trichloromethane)	1.1	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Total THM	3.0	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane-d4	105	%		1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	4-Bromofluorobenzene	95	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Toluene-d8	97	%		1
Pinecrest and Middleton (202009150096)						Sampled on 09/12/2020 1245			
Water Trax ID: 3BCA6									
EPA 524.2 - Volatile Organics by GCMS									
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Bromodichloromethane	4.4	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Bromoform	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Chlorodibromomethane	2.6	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Chloroform (Trichloromethane)	7.2	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Ethyl benzene	0.53	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	m,p-Xylenes	1.6	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Toluene	0.55	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Total THM	14	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Total xylenes	1.6	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane-d4	103	%		1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	4-Bromofluorobenzene	96	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Toluene-d8	93	%		1
Rebecca and Elsie May (202009150097)						Sampled on 09/12/2020 1000			
Water Trax ID: 3BCAD									
EPA 524.2 - Volatile Organics by GCMS									
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Bromodichloromethane	1.3	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Bromoform	0.52	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Chlorodibromomethane	1.2	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Chloroform (Trichloromethane)	1.4	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Total THM	4.4	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane-d4	105	%		1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	4-Bromofluorobenzene	90	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Toluene-d8	97	%		1
15715 Forest Hill rd (202009150098)						Sampled on 09/12/2020 1345			
Water Trax ID: 3BC97									
EPA 524.2 - Volatile Organics by GCMS									
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Bromodichloromethane	2.0	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Bromoform	0.50	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Chlorodibromomethane	1.6	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Chloroform (Trichloromethane)	2.0	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Total THM	6.1	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane-d4	103	%		1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	4-Bromofluorobenzene	97	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Toluene-d8	98	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
----------	----------	------------	----------------	--------	---------	--------	-------	-----	----------

Boulder Creek Fire House (202009150083)

Sampled on 09/12/2020 1115

EPA 524.2 - Volatile Organics by GCMS

09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Bromodichloromethane	1.1	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Bromoform	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Chlorodibromomethane	1.2	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Chloroform (Trichloromethane)	1.0	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Total THM	3.3	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane-d4	102	%		1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	4-Bromofluorobenzene	89	%		1
09/15/20	09/15/20 19:09	1274800	1274801	(EPA 524.2)	Toluene-d8	96	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
376 Ralston Ridge (202009150085)						Sampled on 09/12/2020 1415			
Water Trax ID: 3BCA8									
EPA 524.2 - Volatile Organics by GCMS									
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Bromodichloromethane	2.8	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Bromoform	0.65	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Chlorodibromomethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Chloroform (Trichloromethane)	3.0	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Total THM	6.4	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane-d4	100	%		1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	4-Bromofluorobenzene	90	%		1
09/15/20	09/15/20 19:32	1274800	1274801	(EPA 524.2)	Toluene-d8	97	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
Teilh and redwood Dr (202009150086)						Sampled on 09/12/2020 1040			
Water Trax ID: 3BCA1									
EPA 524.2 - Volatile Organics by GCMS									
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Bromodichloromethane	2.1	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Bromoform	0.60	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Chlorodibromomethane	1.7	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Chloroform (Trichloromethane)	2.7	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Total THM	7.1	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (626) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane-d4	106	%		1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	4-Bromofluorobenzene	92	%		1
09/15/20	09/15/20 19:56	1274800	1274801	(EPA 524.2)	Toluene-d8	97	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
----------	----------	------------	----------------	--------	---------	--------	-------	-----	----------

Fern and Reynolds Dr (202009150087)

Sampled on 09/12/2020 1100

Water Trax ID: 3BCA0

EPA 524.2 - Volatile Organics by GCMS

09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Bromodichloromethane	2.4	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Bromoform	0.58	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Chlorodibromomethane	1.7	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Chloroform (Trichloromethane)	3.8	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Total THM	8.5	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane-d4	104	%		1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	4-Bromofluorobenzene	95	%		1
09/15/20	09/15/20 20:20	1274800	1274801	(EPA 524.2)	Toluene-d8	97	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
600 Debbie (202009150088)						Sampled on 09/12/2020 0930			
Water Trax ID: 3BCAC									
EPA 524.2 - Volatile Organics by GCMS									
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Bromodichloromethane	1.3	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Bromoform	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Chlorodibromomethane	1.2	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Chloroform (Trichloromethane)	1.5	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Total THM	4.0	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane-d4	101	%		1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	4-Bromofluorobenzene	91	%		1
09/15/20	09/15/20 20:43	1274800	1274801	(EPA 524.2)	Toluene-d8	96	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
814 Creek Dr (202009150089)						Sampled on 09/12/2020 1020			
Water Trax ID: 3BCA2									
EPA 524.2 - Volatile Organics by GCMS									
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Bromodichloromethane	2.8	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Bromoform	0.65	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Chlorodibromomethane	2.2	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Chloroform (Trichloromethane)	3.6	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Total THM	9.2	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane-d4	106	%		1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	4-Bromofluorobenzene	93	%		1
09/15/20	09/15/20 21:08	1274800	1274801	(EPA 524.2)	Toluene-d8	94	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
12788 Hwy 9 (202009150090)						Sampled on 09/12/2020 1030			
Water Trax ID: 3BC98									
EPA 524.2 - Volatile Organics by GCMS									
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Bromodichloromethane	0.93	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Bromoform	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Chlorodibromomethane	0.94	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Chloroform (Trichloromethane)	0.85	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Total THM	2.7	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane-d4	101	%		1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	4-Bromofluorobenzene	94	%		1
09/15/20	09/15/20 21:31	1274800	1274801	(EPA 524.2)	Toluene-d8	97	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
15177 Bear Creek Rd (202009150091)						Sampled on 09/12/2020 1215			
Water Trax ID: 3BCA7									
EPA 524.2 - Volatile Organics by GCMS									
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Bromodichloromethane	1.3	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Bromoform	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Chlorodibromomethane	1.4	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Chloroform (Trichloromethane)	1.3	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Total THM	4.0	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (626) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane-d4	102	%		1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	4-Bromofluorobenzene	97	%		1
09/15/20	09/15/20 21:55	1274800	1274801	(EPA 524.2)	Toluene-d8	99	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
15030 Hwy 9 (202009150092)						Sampled on 09/12/2020 0950			
Water Trax ID: 3BCA5									
EPA 524.2 - Volatile Organics by GCMS									
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Bromodichloromethane	1.5	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Bromoform	0.60	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Chlorodibromomethane	1.4	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Chloroform (Trichloromethane)	1.7	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Total THM	5.2	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (626) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane-d4	101	%		1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	4-Bromofluorobenzene	94	%		1
09/15/20	09/15/20 22:18	1274800	1274801	(EPA 524.2)	Toluene-d8	96	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
<u>Hwy 9 and Celia (202009150093)</u>						Sampled on 09/12/2020 1125			
Water Trax ID: 3BC9E									
EPA 524.2 - Volatile Organics by GCMS									
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Bromodichloromethane	3.2	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Bromoform	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Chlorodibromomethane	1.8	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Chloroform (Trichloromethane)	7.6	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Total THM	13	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane-d4	106	%		1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	4-Bromofluorobenzene	92	%		1
09/15/20	09/15/20 22:42	1274800	1274801	(EPA 524.2)	Toluene-d8	96	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
336 Blackstone Terrace (202009150094)						Sampled on 09/12/2020 1145			
Water Trax ID: 3BC9C									
EPA 524.2 - Volatile Organics by GCMS									
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Bromodichloromethane	1.3	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Bromoform	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Chlorodibromomethane	1.3	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Chloroform (Trichloromethane)	1.4	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Total THM	4.0	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane-d4	108	%		1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	4-Bromofluorobenzene	88	%		1
09/15/20	09/15/20 23:06	1274800	1274801	(EPA 524.2)	Toluene-d8	97	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
Hwy 9 and Alameda (202009150095)						Sampled on 09/12/2020 0910			
Water Trax ID: 3BCA9									
EPA 524.2 - Volatile Organics by GCMS									
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Bromodichloromethane	1.0	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Bromoform	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Chlorodibromomethane	0.94	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Chloroform (Trichloromethane)	1.1	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Total THM	3.0	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (626) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane-d4	105	%		1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	4-Bromofluorobenzene	95	%		1
09/15/20	09/15/20 23:29	1274800	1274801	(EPA 524.2)	Toluene-d8	97	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
Pinecrest and Middleton (202009150096)						Sampled on 09/12/2020 1245			
Water Trax ID: 3BCA6									
EPA 524.2 - Volatile Organics by GCMS									
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Bromodichloromethane	4.4	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Bromoform	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Chlorodibromomethane	2.6	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Chloroform (Trichloromethane)	7.2	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Ethyl benzene	0.53	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	m,p-Xylenes	1.6	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Toluene	0.55	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Total THM	14	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Total xylenes	1.6	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (626) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane-d4	103	%		1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	4-Bromofluorobenzene	96	%		1
09/15/20	09/15/20 23:52	1274800	1274801	(EPA 524.2)	Toluene-d8	93	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
<u>Rebecca and Elsie May (202009150097)</u>						Sampled on 09/12/2020 1000			
Water Trax ID: 3BCAD									
EPA 524.2 - Volatile Organics by GCMS									
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Bromodichloromethane	1.3	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Bromoform	0.52	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Chlorodibromomethane	1.2	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Chloroform (Trichloromethane)	1.4	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Total THM	4.4	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane-d4	105	%		1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	4-Bromofluorobenzene	90	%		1
09/15/20	09/16/20 00:16	1274800	1274801	(EPA 524.2)	Toluene-d8	97	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
15715 Forest Hill rd (202009150098)						Sampled on 09/12/2020 1345			
Water Trax ID: 3BC97									
EPA 524.2 - Volatile Organics by GCMS									
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Bromodichloromethane	2.0	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Bromoform	0.50	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Chlorodibromomethane	1.6	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Chloroform (Trichloromethane)	2.0	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Total THM	6.1	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
09/15/2020 0953

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	1,2-Dichloroethane-d4	103	%		1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	4-Bromofluorobenzene	97	%		1
09/15/20	09/16/20 00:39	1274800	1274801	(EPA 524.2)	Toluene-d8	98	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Volatile Organics by GCMS

Prep Batch: 1274800 Analytical Batch: 1274801

202009150083	Boulder Creek Fire House
202009150085	376 Ralston Ridge
202009150086	Teilh and redwood Dr
202009150087	Fern and Reynolds Dr
202009150088	600 Debbie
202009150089	814 Creek Dr
202009150090	12788 Hwy 9
202009150091	15177 Bear Creek Rd
202009150092	15030 Hwy 9
202009150093	Hwy 9 and Celia
202009150094	336 Blackstone Terrace
202009150095	Hwy 9 and Alameda
202009150096	Pinecrest and Middleton
202009150097	Rebecca and Elsie May
202009150098	15715 Forest Hill rd

Analysis Date: 09/15/2020

Analyzed by: TG9W
Analyzed by: TG9W
Analyzed by: TG9W
Analyzed by: TG9W
Analyzed by: TG9W
Analyzed by: TG9W
Analyzed by: TG9W
Analyzed by: TG9W
Analyzed by: TG9W
Analyzed by: TG9W
Analyzed by: TG9W
Analyzed by: TG9W
Analyzed by: TG9W
Analyzed by: TG9W
Analyzed by: TG9W

Tel: (626) 386-1100
Fax: (626) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

QC Type	Analyte	Native	Spiked	Recovered	Units	Yield(%)	Limits (%)	RPD Limit(%)	RPD%
Volatile Organics by GCMS by EPA 524.2									
Analytical Batch: 1274801					Analysis Date: 09/15/2020				
LCS1	1,1,1,2-Tetrachloroethane		5	5.36	ug/L	107	(70-130)		
LCS2	1,1,1,2-Tetrachloroethane		5	5.16	ug/L	103	(70-130)	20	3.8
MBLK	1,1,1,2-Tetrachloroethane			<0.5	ug/L				
MRL_CHK	1,1,1,2-Tetrachloroethane		0.5	0.680	ug/L	136	(50-150)		
LCS1	1,1,1-Trichloroethane		5	5.30	ug/L	106	(70-130)		
LCS2	1,1,1-Trichloroethane		5	5.36	ug/L	107	(70-130)	20	1.1
MBLK	1,1,1-Trichloroethane			<0.5	ug/L				
MRL_CHK	1,1,1-Trichloroethane		0.5	0.470	ug/L	94	(50-150)		
LCS1	1,1,2,2-Tetrachloroethane		5	5.12	ug/L	102	(70-130)		
LCS2	1,1,2,2-Tetrachloroethane		5	5.18	ug/L	104	(70-130)	20	1.2
MBLK	1,1,2,2-Tetrachloroethane			<0.5	ug/L				
MRL_CHK	1,1,2,2-Tetrachloroethane		0.5	0.540	ug/L	108	(50-150)		
LCS1	1,1,2-Trichloroethane		5	5.27	ug/L	105	(70-130)		
LCS2	1,1,2-Trichloroethane		5	5.09	ug/L	102	(70-130)	20	3.5
MBLK	1,1,2-Trichloroethane			<0.5	ug/L				
MRL_CHK	1,1,2-Trichloroethane		0.5	0.550	ug/L	110	(50-150)		
LCS1	1,1-Dichloroethane		5	5.04	ug/L	101	(70-130)		
LCS2	1,1-Dichloroethane		5	5.07	ug/L	101	(70-130)	20	0.59
MBLK	1,1-Dichloroethane			<0.5	ug/L				
MRL_CHK	1,1-Dichloroethane		0.5	0.520	ug/L	104	(50-150)		
LCS1	1,1-Dichloroethylene		5	5.30	ug/L	106	(70-130)		
LCS2	1,1-Dichloroethylene		5	5.04	ug/L	101	(70-130)	20	5.0
MBLK	1,1-Dichloroethylene			<0.5	ug/L				
MRL_CHK	1,1-Dichloroethylene		0.5	0.520	ug/L	104	(50-150)		
LCS1	1,1-Dichloropropene		5	4.89	ug/L	98	(70-130)		
LCS2	1,1-Dichloropropene		5	4.94	ug/L	99	(70-130)	20	1.0
MBLK	1,1-Dichloropropene			<0.5	ug/L				
MRL_CHK	1,1-Dichloropropene		0.5	0.450	ug/L	90	(50-150)		
LCS1	1,2,3-Trichlorobenzene		5	4.83	ug/L	97	(70-130)		
LCS2	1,2,3-Trichlorobenzene		5	4.90	ug/L	98	(70-130)	20	1.4
MBLK	1,2,3-Trichlorobenzene			<0.5	ug/L				
MRL_CHK	1,2,3-Trichlorobenzene		0.5	0.650	ug/L	130	(50-150)		
LCS1	1,2,3-Trichloropropane		5	4.70	ug/L	94	(70-130)		
LCS2	1,2,3-Trichloropropane		5	4.95	ug/L	99	(70-130)	20	5.2
MBLK	1,2,3-Trichloropropane			<0.5	ug/L				

Spike recovery is already corrected for native results.

Spikes which exceed Limits and Method Blanks with positive results are highlighted by Underlining.

Criteria for MS and Dup are advisory only, batch control is based on LCS. Criteria for duplicates are advisory only, unless otherwise specified in the method.

RPD not calculated for LCS2 when different a concentration than LCS1 is used.

RPD not calculated for Duplicates when the result is not five times the MRL (Minimum Reporting Level).

(S) - Indicates surrogate compound.

(I) - Indicates internal standard compound.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

QC Type	Analyte	Native	Spiked	Recovered	Units	Yield(%)	Limits (%)	RPD Limit(%)	RPD%
MRL_CHK	1,2,3-Trichloropropane		0.5	0.530	ug/L	106	(50-150)		
LCS1	1,2,4-Trichlorobenzene		5	4.70	ug/L	94	(70-130)		
LCS2	1,2,4-Trichlorobenzene		5	4.82	ug/L	96	(70-130)	20	2.5
MBLK	1,2,4-Trichlorobenzene			<0.5	ug/L				
MRL_CHK	1,2,4-Trichlorobenzene		0.5	0.580	ug/L	116	(50-150)		
LCS1	1,2,4-Trimethylbenzene		5	4.90	ug/L	98	(70-130)		
LCS2	1,2,4-Trimethylbenzene		5	4.90	ug/L	98	(70-130)	20	0.0
MBLK	1,2,4-Trimethylbenzene			<0.5	ug/L				
MRL_CHK	1,2,4-Trimethylbenzene		0.5	0.440	ug/L	88	(50-150)		
LCS1	1,2-Dichloroethane		5	5.22	ug/L	104	(70-130)		
LCS2	1,2-Dichloroethane		5	5.30	ug/L	106	(70-130)	20	1.5
MBLK	1,2-Dichloroethane			<0.5	ug/L				
MRL_CHK	1,2-Dichloroethane		0.5	0.540	ug/L	108	(50-150)		
LCS1	1,2-Dichloroethane-d4 (S)		5	102	%	102	(70-130)		
LCS2	1,2-Dichloroethane-d4 (S)		5	106	%	106	(70-130)		
MBLK	1,2-Dichloroethane-d4 (S)			99.4	%	99	(70-130)		
MRL_CHK	1,2-Dichloroethane-d4 (S)		5	104	%	104	(70-130)		
MRLW	1,2-Dichloroethane-d4 (S)		5	107	%	107	(70-130)		
LCS1	1,2-Dichloropropane		5	5.39	ug/L	108	(70-130)		
LCS2	1,2-Dichloropropane		5	5.08	ug/L	102	(70-130)	20	5.9
MBLK	1,2-Dichloropropane			<0.5	ug/L				
MRL_CHK	1,2-Dichloropropane		0.5	0.510	ug/L	102	(50-150)		
LCS1	1,3,5-Trimethylbenzene		5	4.83	ug/L	97	(70-130)		
LCS2	1,3,5-Trimethylbenzene		5	4.87	ug/L	97	(70-130)	20	0.83
MBLK	1,3,5-Trimethylbenzene			<0.5	ug/L				
MRL_CHK	1,3,5-Trimethylbenzene		0.5	0.420	ug/L	84	(50-150)		
LCS1	1,3-Dichloropropane		5	5.03	ug/L	101	(70-130)		
LCS2	1,3-Dichloropropane		5	5.40	ug/L	108	(70-130)	20	7.1
MBLK	1,3-Dichloropropane			<0.5	ug/L				
MRL_CHK	1,3-Dichloropropane		0.5	0.510	ug/L	102	(50-150)		
LCS1	2,2-Dichloropropane		5	5.58	ug/L	112	(70-130)		
LCS2	2,2-Dichloropropane		5	5.45	ug/L	109	(70-130)	20	2.4
MBLK	2,2-Dichloropropane			<0.5	ug/L				
MRL_CHK	2,2-Dichloropropane		0.5	0.540	ug/L	108	(50-150)		
LCS1	2-Butanone (MEK)		50	46.5	ug/L	93	(70-130)		
LCS2	2-Butanone (MEK)		50	48.6	ug/L	97	(70-130)	20	4.4
MBLK	2-Butanone (MEK)			<5.0	ug/L				
MRL_CHK	2-Butanone (MEK)		5	5.49	ug/L	110	(50-150)		

Spike recovery is already corrected for native results.

Spikes which exceed Limits and Method Blanks with positive results are highlighted by Underlining.

Criteria for MS and Dup are advisory only, batch control is based on LCS. Criteria for duplicates are advisory only, unless otherwise specified in the method.

RPD not calculated for LCS2 when different a concentration than LCS1 is used.

RPD not calculated for Duplicates when the result is not five times the MRL (Minimum Reporting Level).

(S) - Indicates surrogate compound.

(I) - Indicates internal standard compound.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

QC Type	Analyte	Native	Spiked	Recovered	Units	Yield(%)	Limits (%)	RPD Limit(%)	RPD%
LCS1	4-Bromofluorobenzene (S)		5	99.2	%	99	(70-130)		
LCS2	4-Bromofluorobenzene (S)		5	103	%	103	(70-130)		
MBLK	4-Bromofluorobenzene (S)			93.0	%	93	(70-130)		
MRL_CHK	4-Bromofluorobenzene (S)		5	95.4	%	95	(70-130)		
MRLLW	4-Bromofluorobenzene (S)		5	97.4	%	97	(70-130)		
LCS1	4-Methyl-2-Pentanone (MIBK)		50	49.0	ug/L	98	(70-130)		
LCS2	4-Methyl-2-Pentanone (MIBK)		50	51.6	ug/L	103	(70-130)	20	5.0
MBLK	4-Methyl-2-Pentanone (MIBK)			<5.0	ug/L				
MRL_CHK	4-Methyl-2-Pentanone (MIBK)		5	5.00	ug/L	100	(50-150)		
LCS1	Benzene		5	5.23	ug/L	105	(70-130)		
LCS2	Benzene		5	5.24	ug/L	105	(70-130)	20	0.19
MBLK	Benzene			<0.5	ug/L				
MRL_CHK	Benzene		0.5	0.500	ug/L	100	(50-150)		
LCS1	Bromobenzene		5	4.63	ug/L	93	(70-130)		
LCS2	Bromobenzene		5	4.78	ug/L	96	(70-130)	20	3.2
MBLK	Bromobenzene			<0.5	ug/L				
MRL_CHK	Bromobenzene		0.5	0.450	ug/L	90	(50-150)		
LCS1	Bromochloromethane		5	4.61	ug/L	92	(70-130)		
LCS2	Bromochloromethane		5	4.70	ug/L	94	(70-130)	20	1.9
MBLK	Bromochloromethane			<0.5	ug/L				
MRL_CHK	Bromochloromethane		0.5	0.530	ug/L	106	(50-150)		
LCS1	Bromodichloromethane		5	4.82	ug/L	96	(70-130)		
LCS2	Bromodichloromethane		5	4.83	ug/L	97	(70-130)	20	0.21
MBLK	Bromodichloromethane			<0.5	ug/L				
MRL_CHK	Bromodichloromethane		0.5	0.480	ug/L	96	(50-150)		
LCS1	Bromoethane		5	5.41	ug/L	108	(70-130)		
LCS2	Bromoethane		5	5.64	ug/L	113	(70-130)	20	4.2
MBLK	Bromoethane			<0.5	ug/L				
MRL_CHK	Bromoethane		0.5	0.550	ug/L	110	(50-150)		
LCS1	Bromoform		5	5.11	ug/L	102	(70-130)		
LCS2	Bromoform		5	5.28	ug/L	106	(70-130)	20	3.3
MBLK	Bromoform			<0.5	ug/L				
MRL_CHK	Bromoform		0.5	0.660	ug/L	132	(50-150)		
LCS1	Bromomethane (Methyl Bromide)		5	4.89	ug/L	98	(70-130)		
LCS2	Bromomethane (Methyl Bromide)		5	4.80	ug/L	96	(70-130)	20	1.9
MBLK	Bromomethane (Methyl Bromide)			<0.5	ug/L				
MRL_CHK	Bromomethane (Methyl Bromide)		0.5	0.620	ug/L	124	(50-150)		
LCS1	Carbon disulfide		5	5.79	ug/L	116	(70-130)		

Spike recovery is already corrected for native results.

Spikes which exceed Limits and Method Blanks with positive results are highlighted by Underlining.

Criteria for MS and Dup are advisory only, batch control is based on LCS. Criteria for duplicates are advisory only, unless otherwise specified in the method.

RPD not calculated for LCS2 when different a concentration than LCS1 is used.

RPD not calculated for Duplicates when the result is not five times the MRL (Minimum Reporting Level).

(S) - Indicates surrogate compound.

(I) - Indicates internal standard compound.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

QC Type	Analyte	Native	Spiked	Recovered	Units	Yield(%)	Limits (%)	RPD Limit(%)	RPD%
LCS2	Carbon disulfide		5	5.62	ug/L	112	(70-130)	20	3.0
MBLK	Carbon disulfide			<0.5	ug/L				
MRL_CHK	Carbon disulfide		0.5	0.410	ug/L	82	(50-150)		
LCS1	Carbon Tetrachloride		5	5.69	ug/L	114	(70-130)		
LCS2	Carbon Tetrachloride		5	5.33	ug/L	107	(70-130)	20	6.5
MBLK	Carbon Tetrachloride			<0.5	ug/L				
MRL_CHK	Carbon Tetrachloride		0.5	0.450	ug/L	90	(50-150)		
LCS1	Chlorobenzene		5	5.14	ug/L	103	(70-130)		
LCS2	Chlorobenzene		5	5.13	ug/L	103	(70-130)	20	0.20
MBLK	Chlorobenzene			<0.5	ug/L				
MRL_CHK	Chlorobenzene		0.5	0.460	ug/L	92	(50-150)		
LCS1	Chlorodibromomethane		5	5.37	ug/L	107	(70-130)		
LCS2	Chlorodibromomethane		5	5.38	ug/L	108	(70-130)	20	0.19
MBLK	Chlorodibromomethane			<0.5	ug/L				
MRL_CHK	Chlorodibromomethane		0.5	0.630	ug/L	126	(50-150)		
LCS1	Chloroethane		5	4.91	ug/L	98	(70-130)		
LCS2	Chloroethane		5	5.36	ug/L	107	(70-130)	20	8.8
MBLK	Chloroethane			<0.5	ug/L				
MRL_CHK	Chloroethane		0.5	0.500	ug/L	100	(50-150)		
LCS1	Chloroform (Trichloromethane)		5	4.79	ug/L	96	(70-130)		
LCS2	Chloroform (Trichloromethane)		5	4.84	ug/L	97	(70-130)	20	1.0
MBLK	Chloroform (Trichloromethane)			<0.5	ug/L				
MRL_CHK	Chloroform (Trichloromethane)		0.5	0.530	ug/L	106	(50-150)		
LCS1	Chloromethane(Methyl Chloride)		5	4.45	ug/L	89	(70-130)		
LCS2	Chloromethane(Methyl Chloride)		5	4.58	ug/L	92	(70-130)	20	2.9
MBLK	Chloromethane(Methyl Chloride)			<0.5	ug/L				
MRL_CHK	Chloromethane(Methyl Chloride)		0.5	0.560	ug/L	112	(50-150)		
LCS1	cis-1,2-Dichloroethylene		5	4.46	ug/L	89	(70-130)		
LCS2	cis-1,2-Dichloroethylene		5	4.82	ug/L	96	(70-130)	20	7.8
MBLK	cis-1,2-Dichloroethylene			<0.5	ug/L				
MRL_CHK	cis-1,2-Dichloroethylene		0.5	0.530	ug/L	106	(50-150)		
LCS1	cis-1,3-Dichloropropene		5	5.46	ug/L	109	(70-130)		
LCS2	cis-1,3-Dichloropropene		5	5.49	ug/L	110	(70-130)	20	0.55
MBLK	cis-1,3-Dichloropropene			<0.5	ug/L				
MRL_CHK	cis-1,3-Dichloropropene		0.5	0.650	ug/L	130	(50-150)		
LCS1	Dibromomethane		5	4.50	ug/L	90	(70-130)		
LCS2	Dibromomethane		5	4.92	ug/L	98	(70-130)	20	8.9
MBLK	Dibromomethane			<0.5	ug/L				

Spike recovery is already corrected for native results.

Spikes which exceed Limits and Method Blanks with positive results are highlighted by Underlining.

Criteria for MS and Dup are advisory only, batch control is based on LCS. Criteria for duplicates are advisory only, unless otherwise specified in the method.

RPD not calculated for LCS2 when different a concentration than LCS1 is used.

RPD not calculated for Duplicates when the result is not five times the MRL (Minimum Reporting Level).

(S) - Indicates surrogate compound.

(I) - Indicates internal standard compound.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

QC Type	Analyte	Native	Spiked	Recovered	Units	Yield(%)	Limits (%)	RPD Limit(%)	RPD%
MRL_CHK	Dibromomethane		0.5	0.470	ug/L	94	(50-150)		
LCS1	Dichlorodifluoromethane		5	5.08	ug/L	102	(70-130)		
LCS2	Dichlorodifluoromethane		5	5.18	ug/L	104	(70-130)	20	2.0
MBLK	Dichlorodifluoromethane			<0.5	ug/L				
MRL_CHK	Dichlorodifluoromethane		0.5	0.390	ug/L	78	(50-150)		
LCS1	Dichloromethane		5	4.80	ug/L	96	(70-130)		
LCS2	Dichloromethane		5	4.90	ug/L	98	(70-130)	20	2.1
MBLK	Dichloromethane			<0.5	ug/L				
MRL_CHK	Dichloromethane		0.5	0.640	ug/L	128	(50-150)		
LCS1	Di-isopropyl ether		5	5.25	ug/L	105	(70-130)		
LCS2	Di-isopropyl ether		5	5.24	ug/L	105	(70-130)	20	0.19
MBLK	Di-isopropyl ether			<3.0	ug/L				
MRL_CHK	Di-isopropyl ether		0.5	0.480	ug/L	96	(50-150)		
LCS1	Ethyl benzene		5	5.16	ug/L	103	(70-130)		
LCS2	Ethyl benzene		5	4.94	ug/L	99	(70-130)	20	4.4
MBLK	Ethyl benzene			<0.5	ug/L				
MRL_CHK	Ethyl benzene		0.5	0.410	ug/L	82	(50-150)		
LCS1	Hexachlorobutadiene		5	4.91	ug/L	98	(70-130)		
LCS2	Hexachlorobutadiene		5	4.85	ug/L	97	(70-130)	20	1.2
MBLK	Hexachlorobutadiene			<0.5	ug/L				
MRL_CHK	Hexachlorobutadiene		0.5	0.580	ug/L	116	(50-150)		
LCS1	Isopropylbenzene		5	4.84	ug/L	97	(70-130)		
LCS2	Isopropylbenzene		5	4.82	ug/L	96	(70-130)	20	0.41
MBLK	Isopropylbenzene			<0.5	ug/L				
MRL_CHK	Isopropylbenzene		0.5	0.400	ug/L	80	(50-150)		
LCS1	m,p-Xylenes		10	10.1	ug/L	101	(70-130)		
LCS2	m,p-Xylenes		10	10.0	ug/L	100	(70-130)	20	1
MBLK	m,p-Xylenes			<0.5	ug/L				
MRL_CHK	m,p-Xylenes		1	0.820	ug/L	82	(50-150)		
MRLLW	m,p-Xylenes		0.5	0.400	ug/L	80	(50-150)		
LCS1	m-Dichlorobenzene (1,3-DCB)		5	4.86	ug/L	97	(70-130)		
LCS2	m-Dichlorobenzene (1,3-DCB)		5	4.89	ug/L	98	(70-130)	20	0.62
MBLK	m-Dichlorobenzene (1,3-DCB)			<0.5	ug/L				
MRL_CHK	m-Dichlorobenzene (1,3-DCB)		0.5	0.420	ug/L	84	(50-150)		
LCS1	Methyl Tert-butyl ether (MTBE)		5	5.41	ug/L	108	(70-130)		
LCS2	Methyl Tert-butyl ether (MTBE)		5	5.54	ug/L	111	(70-130)	20	2.4
MBLK	Methyl Tert-butyl ether (MTBE)			<0.5	ug/L				
MRL_CHK	Methyl Tert-butyl ether (MTBE)		0.5	0.520	ug/L	104	(50-150)		

Spike recovery is already corrected for native results.

Spikes which exceed Limits and Method Blanks with positive results are highlighted by Underlining.

Criteria for MS and Dup are advisory only, batch control is based on LCS. Criteria for duplicates are advisory only, unless otherwise specified in the method.

RPD not calculated for LCS2 when different a concentration than LCS1 is used.

RPD not calculated for Duplicates when the result is not five times the MRL (Minimum Reporting Level).

(S) - Indicates surrogate compound.

(I) - Indicates internal standard compound.

Tel: (626) 386-1100
Fax: (626) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

QC Type	Analyte	Native	Spiked	Recovered	Units	Yield(%)	Limits (%)	RPD Limit(%)	RPD%
LCS1	Naphthalene		5	4.86	ug/L	97	(70-130)		
LCS2	Naphthalene		5	5.04	ug/L	101	(70-130)	20	3.6
MBLK	Naphthalene			<0.5	ug/L				
MRL_CHK	Naphthalene		0.5	0.740	ug/L	148	(50-150)		
LCS1	n-Butylbenzene		5	4.86	ug/L	97	(70-130)		
LCS2	n-Butylbenzene		5	4.88	ug/L	98	(70-130)	20	0.41
MBLK	n-Butylbenzene			<0.5	ug/L				
MRL_CHK	n-Butylbenzene		0.5	0.450	ug/L	90	(50-150)		
LCS1	n-Propylbenzene		5	4.95	ug/L	99	(70-130)		
LCS2	n-Propylbenzene		5	5.01	ug/L	100	(70-130)	20	1.2
MBLK	n-Propylbenzene			<0.5	ug/L				
MRL_CHK	n-Propylbenzene		0.5	0.450	ug/L	90	(50-150)		
LCS1	o-Chlorotoluene		5	4.94	ug/L	99	(70-130)		
LCS2	o-Chlorotoluene		5	5.06	ug/L	101	(70-130)	20	2.4
MBLK	o-Chlorotoluene			<0.5	ug/L				
MRL_CHK	o-Chlorotoluene		0.5	0.410	ug/L	82	(50-150)		
LCS1	o-Dichlorobenzene (1,2-DCB)		5	4.93	ug/L	99	(70-130)		
LCS2	o-Dichlorobenzene (1,2-DCB)		5	5.13	ug/L	103	(70-130)	20	4.0
MBLK	o-Dichlorobenzene (1,2-DCB)			<0.5	ug/L				
MRL_CHK	o-Dichlorobenzene (1,2-DCB)		0.5	0.520	ug/L	104	(50-150)		
LCS1	o-Xylene		5	5.02	ug/L	100	(70-130)		
LCS2	o-Xylene		5	5.17	ug/L	103	(70-130)	20	2.9
MBLK	o-Xylene			<0.5	ug/L				
MRL_CHK	o-Xylene		0.5	0.410	ug/L	82	(50-150)		
LCS1	p-Chlorotoluene		5	4.92	ug/L	98	(70-130)		
LCS2	p-Chlorotoluene		5	5.16	ug/L	103	(70-130)	20	4.8
MBLK	p-Chlorotoluene			<0.5	ug/L				
MRL_CHK	p-Chlorotoluene		0.5	0.400	ug/L	80	(50-150)		
LCS1	p-Dichlorobenzene (1,4-DCB)		5	4.87	ug/L	97	(70-130)		
LCS2	p-Dichlorobenzene (1,4-DCB)		5	4.97	ug/L	99	(70-130)	20	2.0
MBLK	p-Dichlorobenzene (1,4-DCB)			<0.5	ug/L				
MRL_CHK	p-Dichlorobenzene (1,4-DCB)		0.5	0.470	ug/L	94	(50-150)		
LCS1	p-Isopropyltoluene		5	4.82	ug/L	96	(70-130)		
LCS2	p-Isopropyltoluene		5	4.91	ug/L	98	(70-130)	20	1.9
MBLK	p-Isopropyltoluene			<0.5	ug/L				
MRL_CHK	p-Isopropyltoluene		0.5	0.390	ug/L	78	(50-150)		
LCS1	sec-Butylbenzene		5	5.22	ug/L	104	(70-130)		
LCS2	sec-Butylbenzene		5	5.38	ug/L	108	(70-130)	20	3.0

Spike recovery is already corrected for native results.

Spikes which exceed Limits and Method Blanks with positive results are highlighted by Underlining.

Criteria for MS and Dup are advisory only, batch control is based on LCS. Criteria for duplicates are advisory only, unless otherwise specified in the method.

RPD not calculated for LCS2 when different a concentration than LCS1 is used.

RPD not calculated for Duplicates when the result is not five times the MRL (Minimum Reporting Level).

(S) - Indicates surrogate compound.

(I) - Indicates internal standard compound.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

QC Type	Analyte	Native	Spiked	Recovered	Units	Yield(%)	Limits (%)	RPD Limit(%)	RPD%
MBLK	sec-Butylbenzene			<0.5	ug/L				
MRL_CHK	sec-Butylbenzene		0.5	0.400	ug/L	80	(50-150)		
LCS1	Styrene		5	4.96	ug/L	99	(70-130)		
LCS2	Styrene		5	4.84	ug/L	97	(70-130)	20	2.5
MBLK	Styrene			<0.5	ug/L				
MRL_CHK	Styrene		0.5	0.370	ug/L	74	(50-150)		
LCS1	tert-amyl Methyl Ether		5	5.77	ug/L	115	(70-130)		
LCS2	tert-amyl Methyl Ether		5	5.79	ug/L	116	(70-130)	20	0.35
MBLK	tert-amyl Methyl Ether			<3.0	ug/L				
MRL_CHK	tert-amyl Methyl Ether		0.5	0.500	ug/L	100	(50-150)		
LCS1	tert-Butyl Ethyl Ether		5	5.98	ug/L	120	(70-130)		
LCS2	tert-Butyl Ethyl Ether		5	6.00	ug/L	120	(70-130)	20	0.33
MBLK	tert-Butyl Ethyl Ether			<3.0	ug/L				
MRL_CHK	tert-Butyl Ethyl Ether		0.5	0.550	ug/L	110	(50-150)		
LCS1	tert-Butylbenzene		5	4.85	ug/L	97	(70-130)		
LCS2	tert-Butylbenzene		5	4.90	ug/L	98	(70-130)	20	1.0
MBLK	tert-Butylbenzene			<0.5	ug/L				
MRL_CHK	tert-Butylbenzene		0.5	0.380	ug/L	76	(50-150)		
LCS1	Tetrachloroethylene (PCE)		5	4.80	ug/L	96	(70-130)		
LCS2	Tetrachloroethylene (PCE)		5	4.87	ug/L	97	(70-130)	20	1.5
MBLK	Tetrachloroethylene (PCE)			<0.5	ug/L				
MRL_CHK	Tetrachloroethylene (PCE)		0.5	0.400	ug/L	80	(50-150)		
LCS1	Toluene		5	5.05	ug/L	101	(70-130)		
LCS2	Toluene		5	5.12	ug/L	102	(70-130)	20	1.4
MBLK	Toluene			<0.5	ug/L				
MRL_CHK	Toluene		0.5	0.480	ug/L	96	(50-150)		
LCS1	Toluene-d8 (S)		5	102	%	102	(70-130)		
LCS2	Toluene-d8 (S)		5	101	%	101	(70-130)		
MBLK	Toluene-d8 (S)			97.4	%	97	(70-130)		
MRL_CHK	Toluene-d8 (S)		5	100	%	100	(70-130)		
MRLLW	Toluene-d8 (S)		5	97.4	%	97	(70-130)		
LCS1	trans-1,2-Dichloroethylene		5	5.28	ug/L	106	(70-130)		
LCS2	trans-1,2-Dichloroethylene		5	5.33	ug/L	107	(70-130)	20	0.94
MBLK	trans-1,2-Dichloroethylene			<0.5	ug/L				
MRL_CHK	trans-1,2-Dichloroethylene		0.5	0.560	ug/L	112	(50-150)		
LCS1	trans-1,3-Dichloropropene		5	5.51	ug/L	110	(70-130)		
LCS2	trans-1,3-Dichloropropene		5	5.64	ug/L	113	(70-130)	20	2.3
MBLK	trans-1,3-Dichloropropene			<0.5	ug/L				

Spike recovery is already corrected for native results.

Spikes which exceed Limits and Method Blanks with positive results are highlighted by Underlining.

Criteria for MS and Dup are advisory only, batch control is based on LCS. Criteria for duplicates are advisory only, unless otherwise specified in the method.

RPD not calculated for LCS2 when different a concentration than LCS1 is used.

RPD not calculated for Duplicates when the result is not five times the MRL (Minimum Reporting Level).

(S) - Indicates surrogate compound.

(I) - Indicates internal standard compound.

Tel: (626) 386-1100
Fax: (626) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 892530
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

QC Type	Analyte	Native	Spiked	Recovered	Units	Yield(%)	Limits (%)	RPD Limit(%)	RPD%
MRL_CHK	trans-1,3-Dichloropropene		0.5	0.660	ug/L	132	(50-150)		
LCS1	Trichloroethylene (TCE)		5	5.27	ug/L	105	(70-130)		
LCS2	Trichloroethylene (TCE)		5	5.25	ug/L	105	(70-130)	20	0.38
MBLK	Trichloroethylene (TCE)			<0.5	ug/L				
MRL_CHK	Trichloroethylene (TCE)		0.5	0.450	ug/L	90	(50-150)		
LCS1	Trichlorofluoromethane		5	4.85	ug/L	97	(70-130)		
LCS2	Trichlorofluoromethane		5	4.78	ug/L	96	(70-130)	20	1.5
MBLK	Trichlorofluoromethane			<0.5	ug/L				
MRL_CHK	Trichlorofluoromethane		0.5	0.440	ug/L	88	(50-150)		
LCS1	Trichlorotrifluoroethane(Freon		5	4.23	ug/L	85	(70-130)		
LCS2	Trichlorotrifluoroethane(Freon		5	4.09	ug/L	82	(70-130)	20	3.4
MBLK	Trichlorotrifluoroethane(Freon			<0.5	ug/L				
MRL_CHK	Trichlorotrifluoroethane(Freon		0.5	0.530	ug/L	106	(50-150)		
LCS1	Vinyl chloride (VC)		5	5.26	ug/L	105	(70-130)		
LCS2	Vinyl chloride (VC)		5	5.42	ug/L	108	(70-130)	20	3.0
MBLK	Vinyl chloride (VC)			<0.3	ug/L				
MRL_CHK	Vinyl chloride (VC)		0.5	0.260	ug/L	52	(50-150)		
MRLW	Vinyl chloride (VC)		0.25	0.250	ug/L	100	(50-150)		

Spike recovery is already corrected for native results.

Spikes which exceed Limits and Method Blanks with positive results are highlighted by Underlining.

Criteria for MS and Dup are advisory only, batch control is based on LCS. Criteria for duplicates are advisory only, unless otherwise specified in the method.

RPD not calculated for LCS2 when different a concentration than LCS1 is used.

RPD not calculated for Duplicates when the result is not five times the MRL (Minimum Reporting Level).

(S) - Indicates surrogate compound.

(I) - Indicates internal standard compound.