

750 Royal Oaks Drive, Suite 100
Monrovia, California 91016-3629
Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Report

for

San Lorenzo Valley Water District
13060 Highway 9
Boulder Creek, CA 95006-9119
Attention: Nate Gillespie
Fax: 831-338-8002

Date of Issue
05/29/2021



**EUROFINS EATON
ANALYTICAL, LLC**

UMVN: Monica Van Natta
Project Manager

Report: 935099
Project: SPECIAL
Group: Fire Investigation



Utah ELCP CA00006

* Accredited in accordance with TNI 2016 and ISO/IEC 17025:2017.

* Laboratory certifies that the test results meet all **TNI 2016 and ISO/IEC 17025:2017** requirements unless noted under the individual analysis.

* Following the cover page are State Certification List, ISO 17025 Accredited Method List, Acknowledgement of Samples Received, Comments, Hits Report, Data Report, QC Summary, QC Report and Regulatory Forms, as applicable.

* Test results relate only to the sample(s) tested.

* Test results apply to the sample(s) as received, unless otherwise noted in the comments report (ISO/IEC 17025:2017).

* This report shall not be reproduced except in full, without the written approval of the laboratory.

* This report includes ISO/IEC 17025 and non-ISO 17025 accredited methods.

STATE CERTIFICATION LIST

State	Certification Number	State	Certification Number
Alabama	41060	Montana	Cert 0035
Arizona	AZ0778	Nebraska	Certified
Arkansas	Certified	Nevada	CA000062018
California	2813	New Hampshire *	2959
Colorado	Certified	New Jersey *	CA 008
Connecticut	PH-0107	New Mexico	Certified
Delaware	CA 006	New York *	11320
Florida *	E871024	North Carolina	06701
Georgia	947	North Dakota	R-009
Guam	18-005R	Oregon *	CA200003-005
Hawaii	Certified	Pennsylvania *	68-565
Idaho	Certified	Puerto Rico	Certified
Illinois *	200033	Rhode Island	LAO00326
Indiana	C-CA-01	South Carolina	87016
Iowa - Asbestos	413	South Dakota	Certified
Kansas *	E-10268	Tennessee	TN02839
Kentucky	90107	Texas *	T104704230-18-15
Louisiana *	LA180000	Utah (Primary AB) *	CA00006
Maine	CA0006	Vermont	VT0114
Maryland	224	Virginia *	460260
Commonwealth of Northern Marianas Is.	MP0004	Washington	C838
Massachusetts	M-CA006	EPA Region 5	Certified
Michigan	9906	Los Angeles County Sanitation Districts	10264
Mississippi	Certified		

* NELAP/TNI Recognized Accreditation Bodies

ISO/IEC 17025 Accredited Method List

The tests listed below are accredited and meet the requirements of ISO/IEC 17025 as verified by the ANSI-ASQ National Accreditation Board/A2LA.
Refer to Certificate and scope of accreditation (5890) found at: <https://www.eurofinsus.com/Eaton>

SPECIFIC TESTS	METHOD OR TECHNIQUE USED	Environ-mental (Drinking Water)	Environ-mental (Waste Water)	Water as a Component of Food and Bev/Bev/ Bottled Water
1,2,3-TCP (5 PPT & 0.5 PPT)	CA SRL 524M-TCP	x		x
1,4-Dioxane	EPA 522	x		x
2,3,7,8-TCDD	Modified EPA 1613B	x		x
Acrylamide	In House Method (2440)	x		x
Algal Toxins/Microcystin	In House Method (3570)			
Alkalinity	SM 2320B	x	x	x
Ammonia	EPA 350.1		x	x
Ammonia	SM 4500-NH3 H		x	x
Anions and DBPs by IC	EPA 300.0	x	x	x
Anions and DBPs by IC	EPA 300.1	x		x
Asbestos	EPA 100.2	x	x	
BOD / CBOD	SM 5210B		x	x
Bromate	In House Method (2447)	x		x
Carbamates	EPA 531.2	x		x
Carbonate as CO3	SM 2330B	x	x	x
Carbonyls	EPA 556	x		x
COD	EPA 410.4 / SM 5220D		x	
Chloramines	SM 4500-CL G	x	x	x
Chlorinated Acids	EPA 515.4	x		x
Chlorinated Acids	EPA 555	x		x
Chlorine Dioxide	SM 4500-CLO2 D Palin Test	x		x
Chlorine -Total/Free/ Combined Residual	SM 4500-Cl G	x	x	x
Conductivity	EPA 120.1		x	
Conductivity	SM 2510B	x	x	x
Corrosivity (Langelier Index)	SM 2330B	x		x
Cyanide, Amenable	SM 4500-CN G	x	x	
Cyanide, Free	SM 4500CN F	x	x	x
Cyanide, Total	EPA 335.4	x	x	x
Cyanogen Chloride (screen)	In House Method (2470)	x		x
Diquat and Paraquat	EPA 549.2	x		x
DBP/HAA	SM 6251B	x		x
Dissolved Oxygen	SM 4500-O G		x	x
DOC	SM 5310C	x		x
E. Coli	(MTF/EC+MUG)	x		x
E. Coli	CFR 141.21(f)(6)(i)	x		x
E. Coli	SM 9223		x	
E. Coli (Enumeration)	SM 9221B.1/ SM 9221F	x		x
E. Coli (Enumeration)	SM 9223B	x		x
EDB/DCBP	EPA 504.1	x		
EDB/DBCP and DBP	EPA 551.1	x		x
EDTA and NTA	In House Method (2454)	x		x
Endothall	EPA 548.1	x		x
Endothall	In-house Method (2445)	x		x
Enterococci	SM 9230B	x	x	
Fecal Coliform	SM 9221 E (MTF/EC)	x		
Fecal Coliform	SM 9221C, E (MTF/EC)		x	
Fecal Coliform (Enumeration)	SM 9221E (MTF/EC)	x		x
Fecal Coliform with Chlorine Present	SM 9221E		x	
Fecal Streptococci	SM 9230B	x	x	
Fluoride	SM 4500-F C	x	x	x
Glyphosate	EPA 547	x		x
Glyphosate + AMPA	In House Method (3618)	x		x
Gross Alpha/Beta	EPA 900.0	x	x	x
Gross Alpha Coprecipitation	SM 7110 C	x	x	x
Hardness	SM 2340B	x	x	x
Heterotrophic Bacteria	In House Method (2439)	x		x
Heterotrophic Bacteria	SM 9215 B	x		x
Hexavalent Chromium	EPA 218.6	x	x	x

SPECIFIC TESTS	METHOD OR TECHNIQUE USED	Environ-mental (Drinking Water)	Environ-mental (Waste Water)	Water as a Component of Food and Bev/Bev/ Bottled Water
Hexavalent Chromium	EPA 218.7	x		x
Hexavalent Chromium	SM 3500-Cr B		x	
Hormones	EPA 539	x		x
Hydroxide as OH Calc.	SM 2330B	x		x
Kjeldahl Nitrogen	EPA 351.2		x	
Legionella	Legiolert	x		x
Mercury	EPA 200.8	x		x
Metals	EPA 200.7 / 200.8	x	x	x
Microcystin LR	ELISA (2360)	x		x
Microcystin, Total	EPA 546	x		x
NDMA	EEA/Agilent 521.1 In house method (2425)	x		x
Nitrate/Nitrite Nitrogen	EPA 353.2	x	x	x
OCL, Pesticides/PCB	EPA 505	x		x
Ortho Phosphate	EPA 365.1	x	x	x
Ortho Phosphorous	SM 4500P E	x		x
Oxyhalides Disinfection Byproducts	EPA 317.0	x		x
Perchlorate	EPA 331.0	x		x
Perchlorate (low and high)	EPA 314.0	x		x
Perfluorinated Alkyl Acids	EPA 537	x		x
Perfluorinated Pollutant	In house Method (2434)	x		x
pH	EPA 150.1	x		
pH	SM 4500-H+B	x	x	x
Phenylurea Pesticides/ Herbicides	In House Method, based on EPA 532 (2448)	x		x
Pseudomonas	IDEXX Pseudalart (2461)	x		x
Radium-226	GA Institute of Tech	x		x
Radium-228	GA Institute of Tech	x		x
Radon-222	SM 7500RN	x		x
Residue, Filterable	SM 2540C	x	x	x
Residue, Non-filterable	SM 2540D		x	
Residue, Total	SM 2540B		x	x
Residue, Volatile	EPA 160.4		x	
Semi-VOC	EPA 525.2	x		x
Silica	SM 4500-Si D	x	x	
Silica	SM 4500-SiO2 C	x	x	
Sulfide	SM 4500-S ⁻ D		x	
Sulfite	SM 4500-SO ³ B	x	x	x
Surfactants	SM 5540C	x	x	x
Taste and Odor Analytes	SM 6040E	x		x
Total Coliform (P/A)	SM 9221 A, B	x		x
Total Coliform (Enumeration)	SM 9221 A, B, C	x		x
Total Coliform / E. coli	Colisure SM 9223	x		x
Total Coliform	SM 9221B		x	
Total Coliform with Chlorine Present	SM 9221B		x	
Total Coliform / E.coli (P/A and Enumeration)	SM 9223	x		x
TOC	SM 5310C	x	x	x
TOX	SM 5320B		x	
Total Phenols	EPA 420.1		x	
Total Phenols	EPA 420.4	x	x	x
Total Phosphorous	SM 4500 P E		x	
Triazine Pesticides & Degradates	In House (3617)	x		x
Turbidity	EPA 180.1	x	x	x
Turbidity	SM 2130B	x	x	
Uranium by ICP/MS	EPA 200.8	x		x
UV 254	SM 5910B	x		
VOC	EPA 524.2	x		x
VOC	In House Method (2411)	x		x
Yeast and Mold	SM 9610	x		x
Field Sampling	N/A			

Acknowledgement of Samples Received

Addr: **San Lorenzo Valley Water District**
 13060 Highway 9
 Boulder Creek, CA 95006-9119

Client ID: SANLORENZO

Folder #: 935099

Project: SPECIAL

Sample Group: Fire Investigation

Attn: Nate Gillespie
 Phone: 831-216-9019

Project Manager: Monica Van Natta
 Phone: 559-797-1931

The following samples were received from you on **May 13, 2021** at **1017**. They have been scheduled for the tests listed below each sample. If this information is incorrect, please contact your service representative. Thank you for using Eurofins Eaton Analytical, LLC.

Sample #	Sample ID	Sample Date
<u>202105130949</u>	815 Forest	05/12/2021 0825
	Water Trax ID: 3BCAE	
	@VOASDWA C	
<u>202105130950</u>	12788 HWY 9	05/12/2021 0855
	Water Trax ID: 3BC98	
	@VOASDWA C	
<u>202105130951</u>	Clear Creek and Alameda	05/12/2021 0840
	Water Trax ID: 3BC9B	
	@VOASDWA C	
<u>202105130952</u>	275 Brook Ln	05/12/2021 0910
	Water Trax ID: 3BCAB	
	@VOASDWA C	
<u>202105130953</u>	15030 HWY 9	05/12/2021 0925
	Water Trax ID: 3BCA5	
	@VOASDWA C	
<u>202105130954</u>	Crescent Dr and River Rd	05/12/2021 0940
	Water Trax ID: 3BCA3	
	@VOASDWA C	
<u>202105130955</u>	814 Creek Dr	05/12/2021 1000
	Water Trax ID: 3BCA2	
	@VOASDWA C	
<u>202105130956</u>	801 Dry Well Rd (Hydrant)	05/12/2021 1120
	@VOASDWA C	
<u>202105130957</u>	1000 Stewart Dr	05/12/2021 1030
	@VOASDWA C	
<u>202105130958</u>	Sylvan and Redwood	05/12/2021 1145
	Water Trax ID: 3BC9F	
	@VOASDWA C	
<u>202105130959</u>	Riverside and Middle	05/12/2021 0810
	Water Trax ID: 3BCB1	
	@VOASDWA C	

Acknowledgement of Samples Received

Addr: **San Lorenzo Valley Water District**
13060 Highway 9
Boulder Creek, CA 95006-9119

Client ID: SANLORENZO
Folder #: 935099
Project: SPECIAL
Sample Group: Fire Investigation

Attn: Nate Gillespie
Phone: 831-216-9019

Project Manager: Monica Van Natta
Phone: 559-797-1931

The following samples were received from you on **May 13, 2021** at **1017**. They have been scheduled for the tests listed below each sample. If this information is incorrect, please contact your service representative. Thank you for using Eurofins Eaton Analytical, LLC.

Sample #	Sample ID	Sample Date
Test Description		
@VOASDWA C -- Volatile Organics by GCMS		



Eaton Analytical

INTERNAL CHAIN OF CUSTODY RECORD

EEA Folder Number:

625044

SAMPLE TEMP RECEIVED:

Note: If samples are out of temperature range, let the ASMs know. ASMs will determine whether to proceed with analysis or not.

SAMPLES REC'D DAY OF COLLECTION? Yes / No

IR Gun ID = 031A (Observation = 5.5 °C) (Corr.Factor = 0.1 °C) (Final = 5.4 °C)

TYPE OF ICE: Real ☒ Synthetic ☒ No Ice ☐ CONDITION OF ICE: Frozen ☒ Partially Frozen ☐ Thawed ☐ N/A ☐

METHOD OF SHIPMENT: Pick-Up / Walk-In / FedEx / UPS / DHL / Area Fast / Top Line / Other: ☐

Compliance Acceptance Criteria:

- 1) Chemistry: >0, ≤6°C, not frozen (NELAP) (if received after 24 hrs of sample collection)
- 2) Microbiology, Distribution: < 10°C, not frozen (can be ≥10°C if received on ice the same day as sample collection, within 8 hours)
- 3) Microbiology, Surface Water: < 10°C (if received after 2 hours of sample collection)

If out of temperature range for both Chemistry and Microbiology samples and temperature does not confirm, then measure the temperature of each quadrant and record each temperature of the quadrants

1 = (Observation = °C) (Corr.Factor = °C) (Final = °C)	2 = (Observation = °C) (Corr.Factor = °C) (Final = °C)
3 = (Observation = °C) (Corr.Factor = °C) (Final = °C)	4 = (Observation = °C) (Corr.Factor = °C) (Final = °C)

4) Dioxin (1613 or 2,3,7,8 TCDD): must be between 0-4 °C, not frozen (if received after 24 hrs of sample collection)

5) pH Check. Manufacturer: Lot Number: pH strip type: 0 - 14 or Expiration Date: Results:

6) Chlorine check. Manufacturer: Sansafe. Lot No.: Expiration Date: Results:

7) VOA and Radon

No Samples with Headspace:

Samples with Headspace (see below):


Headspace Documentation (use additional VOC and Radon Internal COFC for additional bottles)

Exempt from headspace concerns: Methods 515.4, HAA(6251.652), 505, SPME, @CH, 532LCMS, 556, 536, Anatoxin, LCMS methods using 40 ml vials, International clients:

Samp ID	Bottle #	None/<6 mm	Samp ID	Bottle #	None/<6 mm	Samp ID	Bottle #	None/<6 mm

Note Sample IDs which have dissimilar headspace (i.e. potential sampling errors):

RECEIVED BY	SIGNATURE	PRINT NAME	COMPANY/TITLE	DATE	TIME
		Chae Baek	Eurofins Eaton Analytical	5-13-21	1017



Eaton Analytical

750 Royal Oaks Drive, Suite 100
Monrovia, California 91016-3629
(626) 386-1100 FAX (866) 988-3757

Kit #: 271007



Created By: Monica Van Natta - [UMVN]

Deliver By: 08/25/2020

STG: Bottle Orders

Ice Type: G

Kit Order for San Lorenzo Valley Water District

Monica Van Natta is your Eurofins Eaton Analytical, LLC Service Manager

Created Date & Time: 8/21/2020 2:23:24PM

Note: Sampler Please return this paper with your samples

Client ID: SANLORENZO



Project Code: SPECIAL Bottle Orders

Group Name: Fire Investigation

PO#/JOB#:

Description: No Schedule

Ship Sample Kits to
Attr: Hugh Dalton
525 Pine Street
Aptos, CA 95003

Attr: SLV Water District
Phone: 8313385002

Send Report to
San Lorenzo Valley Water District
13060 Highway 9
Boulder Creek, CA 95006-9119

Attr: Nate Gillespie
Phone: 831-216-9019
Fax: 831-338-8002

Billing Address
San Lorenzo Valley Water District
13060 Highway 9
Boulder Creek, 95006

Attr: Rachel Munoz
Phone: 831.338.2153
Fax: 831.338.7986

of

Sample Tests

10 @VOASDWA C

Bottle Qty - Type [preservative information]

3 - 40ml amber glass vial [25mg Ascorbic+drop 2ml 1:1 HCL]

1 - RETURN AIRBILL [no preservative]

Total

30

UN DOT #

UN1789

Sum Tests: 11

Sum Bottles: 31

Comments

Client - please use ice cubes in addition to the provided gel ice packs during hot summer months.

SHIPPING: please include return shipping labels and gel ice packs

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Comments

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Flags Legend:

VC - CCV is high biased, ND data are reportable as per TNI V1M4 1.7.2.e).i.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Analyzed	Analyte	Sample ID	Result	Federal MCL	Units	MRL
202105130949 <u>815 Forest</u>						
05/22/2021 22:35	Bromodichloromethane		1.3		ug/L	0.50
05/22/2021 22:35	Chlorodibromomethane		1.1		ug/L	0.50
05/22/2021 22:35	Chloroform (Trichloromethane)		2.4		ug/L	0.50
05/22/2021 22:35	Total THM		4.8	80	ug/L	0.50
202105130950 <u>12788 HWY 9</u>						
05/22/2021 22:57	Bromodichloromethane		1.3		ug/L	0.50
05/22/2021 22:57	Chlorodibromomethane		1.1		ug/L	0.50
05/22/2021 22:57	Chloroform (Trichloromethane)		1.6		ug/L	0.50
05/22/2021 22:57	Total THM		4.0	80	ug/L	0.50
202105130951 <u>Clear Creek and Alameda</u>						
05/22/2021 23:18	Bromodichloromethane		8.3		ug/L	0.50
05/22/2021 23:18	Chlorodibromomethane		2.5		ug/L	0.50
05/22/2021 23:18	Chloroform (Trichloromethane)		28		ug/L	0.50
05/22/2021 23:18	Total THM		39	80	ug/L	0.50
202105130952 <u>275 Brook Ln</u>						
05/22/2021 23:39	Bromodichloromethane		11		ug/L	0.50
05/22/2021 23:39	Chlorodibromomethane		2.7		ug/L	0.50
05/22/2021 23:39	Chloroform (Trichloromethane)		44		ug/L	0.50
05/22/2021 23:39	Total THM		58	80	ug/L	0.50
202105130953 <u>15030 HWY 9</u>						
05/23/2021 0:00	Bromodichloromethane		1.4		ug/L	0.50
05/23/2021 0:00	Chlorodibromomethane		1.1		ug/L	0.50
05/23/2021 0:00	Chloroform (Trichloromethane)		2.1		ug/L	0.50
05/23/2021 0:00	Total THM		4.6	80	ug/L	0.50
202105130954 <u>Crescent Dr and River Rd</u>						
05/23/2021 0:21	Bromodichloromethane		5.7		ug/L	0.50
05/23/2021 0:21	Chlorodibromomethane		2.2		ug/L	0.50
05/23/2021 0:21	Chloroform (Trichloromethane)		18		ug/L	0.50
05/23/2021 0:21	Total THM		26	80	ug/L	0.50
202105130955 <u>814 Creek Dr</u>						
05/23/2021 0:42	Bromodichloromethane		6.9		ug/L	0.50
05/23/2021 0:42	Chlorodibromomethane		2.7		ug/L	0.50
05/23/2021 0:42	Chloroform (Trichloromethane)		19		ug/L	0.50

SUMMARY OF POSITIVE DATA ONLY

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Analyzed	Analyte	Sample ID	Result	Federal MCL	Units	MRL
05/23/2021 0:42	Total THM		29	80	ug/L	0.50
	202105130956	<u>801 Dry Well Rd (Hydrant)</u>				
05/23/2021 1:03	Bromodichloromethane		9.2		ug/L	0.50
05/23/2021 1:03	Chlorodibromomethane		3.5		ug/L	0.50
05/23/2021 1:03	Chloroform (Trichloromethane)		26		ug/L	0.50
05/23/2021 1:03	Total THM		39	80	ug/L	0.50
	202105130957	<u>1000 Stewart Dr</u>				
05/23/2021 1:25	Bromodichloromethane		8.0		ug/L	0.50
05/23/2021 1:25	Chlorodibromomethane		3.1		ug/L	0.50
05/23/2021 1:25	Chloroform (Trichloromethane)		21		ug/L	0.50
05/23/2021 1:25	Total THM		32	80	ug/L	0.50
	202105130958	<u>Sylvan and Redwood</u>				
05/23/2021 18:58	Bromodichloromethane		5.3		ug/L	0.50
05/23/2021 18:58	Chlorodibromomethane		2.1		ug/L	0.50
05/23/2021 18:58	Chloroform (Trichloromethane)		15		ug/L	0.50
05/23/2021 18:58	Total THM		22	80	ug/L	0.50
	202105130959	<u>Riverside and Middle</u>				
05/23/2021 15:06	Chloroform (Trichloromethane)		0.72		ug/L	0.50
05/23/2021 15:06	Total THM		0.72	80	ug/L	0.50

SUMMARY OF POSITIVE DATA ONLY

Tel: (626) 386-1100
Fax: (626) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
815 Forest (202105130949)						Sampled on 05/12/2021 0825			
Water Trax ID: 3BCAE									
EPA 524.2 - Volatile Organics by GCMS									
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Bromodichloromethane	1.3	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Bromoform	ND (VC)	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Chlorodibromomethane	1.1	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Chloroform (Trichloromethane)	2.4	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Total THM	4.8	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	trans-1,3-Dichloropropene	ND (VC)	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane-d4	113	%		1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	4-Bromofluorobenzene	98	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Toluene-d8	89	%		1
12788 HWY 9 (202105130950)						Sampled on 05/12/2021 0855			
Water Trax ID: 3BC98									
EPA 524.2 - Volatile Organics by GCMS									
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Bromodichloromethane	1.3	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Bromoform	ND (VC)	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Chlorodibromomethane	1.1	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Chloroform (Trichloromethane)	1.6	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Total THM	4.0	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	trans-1,3-Dichloropropene	ND (VC)	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane-d4	117	%		1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	4-Bromofluorobenzene	97	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Toluene-d8	88	%		1
Clear Creek and Alameda (202105130951)						Sampled on 05/12/2021 0840			
Water Trax ID: 3BC9B									
EPA 524.2 - Volatile Organics by GCMS									
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Bromodichloromethane	8.3	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Bromoform	ND (VC)	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Chlorodibromomethane	2.5	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Chloroform (Trichloromethane)	28	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Total THM	39	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	trans-1,3-Dichloropropene	ND (VC)	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane-d4	115	%		1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	4-Bromofluorobenzene	96	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Toluene-d8	93	%		1
275 Brook Ln (202105130952)						Sampled on 05/12/2021 0910			
Water Trax ID: 3BCAB									
EPA 524.2 - Volatile Organics by GCMS									
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Bromodichloromethane	11	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Bromoform	ND (VC)	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Chlorodibromomethane	2.7	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Chloroform (Trichloromethane)	44	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Total THM	58	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	trans-1,3-Dichloropropene	ND (VC)	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane-d4	116	%		1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	4-Bromofluorobenzene	96	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Toluene-d8	91	%		1
15030 HWY 9 (202105130953)						Sampled on 05/12/2021 0925			
Water Trax ID: 3BCA5									
EPA 524.2 - Volatile Organics by GCMS									
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Bromodichloromethane	1.4	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Bromoform	ND (VC)	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Chlorodibromomethane	1.1	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Chloroform (Trichloromethane)	2.1	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Total THM	4.6	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	trans-1,3-Dichloropropene	ND (VC)	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane-d4	114	%		1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	4-Bromofluorobenzene	98	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Toluene-d8	93	%		1
Crescent Dr and River Rd (202105130954)						Sampled on 05/12/2021 0940			
Water Trax ID: 3BCA3									
EPA 524.2 - Volatile Organics by GCMS									
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Bromodichloromethane	5.7	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Bromoform	ND (VC)	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Chlorodibromomethane	2.2	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Chloroform (Trichloromethane)	18	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Total THM	26	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	trans-1,3-Dichloropropene	ND (VC)	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane-d4	116	%		1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	4-Bromofluorobenzene	99	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Toluene-d8	91	%		1
814 Creek Dr (202105130955)						Sampled on 05/12/2021 1000			
Water Trax ID: 3BCA2									
EPA 524.2 - Volatile Organics by GCMS									
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Bromodichloromethane	6.9	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Bromoform	ND (VC)	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Chlorodibromomethane	2.7	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Chloroform (Trichloromethane)	19	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Total THM	29	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	trans-1,3-Dichloropropene	ND (VC)	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane-d4	118	%		1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	4-Bromofluorobenzene	98	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Toluene-d8	94	%		1
801 Dry Well Rd (Hydrant) (202105130956)						Sampled on 05/12/2021 1120			
EPA 524.2 - Volatile Organics by GCMS									
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Bromodichloromethane	9.2	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Bromoform	ND (VC)	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Chlorodibromomethane	3.5	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Chloroform (Trichloromethane)	26	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Total THM	39	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	trans-1,3-Dichloropropene	ND (VC)	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane-d4	115	%		1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	4-Bromofluorobenzene	101	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (626) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Toluene-d8	94	%		1
1000 Stewart Dr (202105130957)						Sampled on 05/12/2021 1030			
EPA 524.2 - Volatile Organics by GCMS									
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Bromodichloromethane	8.0	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Bromoform	ND (VC)	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Chlorodibromomethane	3.1	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Chloroform (Trichloromethane)	21	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution	
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Total THM	32	ug/L	0.50	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	trans-1,3-Dichloropropene	ND (VC)	ug/L	0.50	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane-d4	114	%		1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	4-Bromofluorobenzene	93	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Toluene-d8	87	%		1
Sylvan and Redwood (202105130958)						Sampled on 05/12/2021 1145			
Water Trax ID: 3BC9F									
EPA 524.2 - Volatile Organics by GCMS									
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Bromodichloromethane	5.3	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Bromoform	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Chlorodibromomethane	2.1	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Chloroform (Trichloromethane)	15	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Total THM	22	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,2-Dichloroethane-d4	115	%		1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	4-Bromofluorobenzene	97	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Toluene-d8	91	%		1
Riverside and Middle (202105130959)						Sampled on 05/12/2021 0810			
Water Trax ID: 3BCB1									
EPA 524.2 - Volatile Organics by GCMS									
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Bromodichloromethane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Bromoform	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Chlorodibromomethane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Chloroform (Trichloromethane)	0.72	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Total THM	0.72	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,2-Dichloroethane-d4	116	%		1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	4-Bromofluorobenzene	96	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepped	Analyzed	Prep Batch	Analytical Batch	Method	Analyte	Result	Units	MRL	Dilution
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Toluene-d8	90	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (626) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
----------	----------	------------	----------------	--------	---------	--------	-------	-----	----------

815 Forest (202105130949)

Sampled on 05/12/2021 0825

Water Trax ID: 3BCAE

EPA 524.2 - Volatile Organics by GCMS

05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Bromodichloromethane	1.3	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Bromoform	ND (VC)	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Chlorodibromomethane	1.1	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Chloroform (Trichloromethane)	2.4	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Total THM	4.8	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (626) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	trans-1,3-Dichloropropene	ND (VC)	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane-d4	113	%		1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	4-Bromofluorobenzene	98	%		1
05/22/21	05/22/21 22:35	1329838	1329843	(EPA 524.2)	Toluene-d8	89	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
12788 HWY 9 (202105130950)						Sampled on 05/12/2021 0855			
Water Trax ID: 3BC98									
EPA 524.2 - Volatile Organics by GCMS									
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Bromodichloromethane	1.3	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Bromoform	ND (VC)	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Chlorodibromomethane	1.1	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Chloroform (Trichloromethane)	1.6	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Total THM	4.0	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	trans-1,3-Dichloropropene	ND (VC)	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (626) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane-d4	117	%		1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	4-Bromofluorobenzene	97	%		1
05/22/21	05/22/21 22:57	1329838	1329843	(EPA 524.2)	Toluene-d8	88	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
Clear Creek and Alameda (202105130951)						Sampled on 05/12/2021 0840			
Water Trax ID: 3BC9B									
EPA 524.2 - Volatile Organics by GCMS									
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Bromodichloromethane	8.3	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Bromoform	ND (VC)	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Chlorodibromomethane	2.5	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Chloroform (Trichloromethane)	28	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Total THM	39	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	trans-1,3-Dichloropropene	ND (VC)	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (626) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane-d4	115	%		1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	4-Bromofluorobenzene	96	%		1
05/22/21	05/22/21 23:18	1329838	1329843	(EPA 524.2)	Toluene-d8	93	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
275 Brook Ln (202105130952)						Sampled on 05/12/2021 0910			
Water Trax ID: 3BCAB									
EPA 524.2 - Volatile Organics by GCMS									
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Bromodichloromethane	11	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Bromoform	ND (VC)	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Chlorodibromomethane	2.7	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Chloroform (Trichloromethane)	44	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Total THM	58	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	trans-1,3-Dichloropropene	ND (VC)	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (626) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane-d4	116	%		1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	4-Bromofluorobenzene	96	%		1
05/22/21	05/22/21 23:39	1329838	1329843	(EPA 524.2)	Toluene-d8	91	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
15030 HWY 9 (202105130953)						Sampled on 05/12/2021 0925			
Water Trax ID: 3BCA5									
EPA 524.2 - Volatile Organics by GCMS									
05/22/21	05/23/21	0:00	1329838	1329843	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:00	1329838	1329843	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:00	1329838	1329843	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:00	1329838	1329843	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:00	1329838	1329843	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:00	1329838	1329843	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50 1
05/22/21	05/23/21	0:00	1329838	1329843	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50 1
05/22/21	05/23/21	0:00	1329838	1329843	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50 1
05/22/21	05/23/21	0:00	1329838	1329843	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:00	1329838	1329843	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50 1
05/22/21	05/23/21	0:00	1329838	1329843	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50 1
05/22/21	05/23/21	0:00	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:00	1329838	1329843	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:00	1329838	1329843	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50 1
05/22/21	05/23/21	0:00	1329838	1329843	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:00	1329838	1329843	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:00	1329838	1329843	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0 1
05/22/21	05/23/21	0:00	1329838	1329843	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0 1
05/22/21	05/23/21	0:00	1329838	1329843	(EPA 524.2)	Benzene	ND	ug/L	0.50 1
05/22/21	05/23/21	0:00	1329838	1329843	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50 1
05/22/21	05/23/21	0:00	1329838	1329843	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:00	1329838	1329843	(EPA 524.2)	Bromodichloromethane	1.4	ug/L	0.50 1
05/22/21	05/23/21	0:00	1329838	1329843	(EPA 524.2)	Bromoethane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:00	1329838	1329843	(EPA 524.2)	Bromoform	ND (VC)	ug/L	0.50 1
05/22/21	05/23/21	0:00	1329838	1329843	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50 1
05/22/21	05/23/21	0:00	1329838	1329843	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50 1
05/22/21	05/23/21	0:00	1329838	1329843	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50 1
05/22/21	05/23/21	0:00	1329838	1329843	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50 1
05/22/21	05/23/21	0:00	1329838	1329843	(EPA 524.2)	Chlorodibromomethane	1.1	ug/L	0.50 1
05/22/21	05/23/21	0:00	1329838	1329843	(EPA 524.2)	Chloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:00	1329838	1329843	(EPA 524.2)	Chloroform (Trichloromethane)	2.1	ug/L	0.50 1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Total THM	4.6	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	trans-1,3-Dichloropropene	ND (VC)	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane-d4	114	%		1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	4-Bromofluorobenzene	98	%		1
05/22/21	05/23/21 0:00	1329838	1329843	(EPA 524.2)	Toluene-d8	93	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
Crescent Dr and River Rd (202105130954)						Sampled on 05/12/2021 0940			
Water Trax ID: 3BCA3									
EPA 524.2 - Volatile Organics by GCMS									
05/22/21	05/23/21	0:21	1329838	1329843	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:21	1329838	1329843	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:21	1329838	1329843	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:21	1329838	1329843	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:21	1329838	1329843	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:21	1329838	1329843	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50 1
05/22/21	05/23/21	0:21	1329838	1329843	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50 1
05/22/21	05/23/21	0:21	1329838	1329843	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50 1
05/22/21	05/23/21	0:21	1329838	1329843	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:21	1329838	1329843	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50 1
05/22/21	05/23/21	0:21	1329838	1329843	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50 1
05/22/21	05/23/21	0:21	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:21	1329838	1329843	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:21	1329838	1329843	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50 1
05/22/21	05/23/21	0:21	1329838	1329843	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:21	1329838	1329843	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:21	1329838	1329843	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0 1
05/22/21	05/23/21	0:21	1329838	1329843	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0 1
05/22/21	05/23/21	0:21	1329838	1329843	(EPA 524.2)	Benzene	ND	ug/L	0.50 1
05/22/21	05/23/21	0:21	1329838	1329843	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50 1
05/22/21	05/23/21	0:21	1329838	1329843	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:21	1329838	1329843	(EPA 524.2)	Bromodichloromethane	5.7	ug/L	0.50 1
05/22/21	05/23/21	0:21	1329838	1329843	(EPA 524.2)	Bromoethane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:21	1329838	1329843	(EPA 524.2)	Bromoform	ND (VC)	ug/L	0.50 1
05/22/21	05/23/21	0:21	1329838	1329843	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50 1
05/22/21	05/23/21	0:21	1329838	1329843	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50 1
05/22/21	05/23/21	0:21	1329838	1329843	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50 1
05/22/21	05/23/21	0:21	1329838	1329843	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50 1
05/22/21	05/23/21	0:21	1329838	1329843	(EPA 524.2)	Chlorodibromomethane	2.2	ug/L	0.50 1
05/22/21	05/23/21	0:21	1329838	1329843	(EPA 524.2)	Chloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:21	1329838	1329843	(EPA 524.2)	Chloroform (Trichloromethane)	18	ug/L	0.50 1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Total THM	26	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	trans-1,3-Dichloropropene	ND (VC)	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (626) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane-d4	116	%		1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	4-Bromofluorobenzene	99	%		1
05/22/21	05/23/21 0:21	1329838	1329843	(EPA 524.2)	Toluene-d8	91	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
814 Creek Dr (202105130955)						Sampled on 05/12/2021 1000			
Water Trax ID: 3BCA2									
EPA 524.2 - Volatile Organics by GCMS									
05/22/21	05/23/21	0:42	1329838	1329843	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:42	1329838	1329843	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:42	1329838	1329843	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:42	1329838	1329843	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:42	1329838	1329843	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:42	1329838	1329843	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50 1
05/22/21	05/23/21	0:42	1329838	1329843	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50 1
05/22/21	05/23/21	0:42	1329838	1329843	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50 1
05/22/21	05/23/21	0:42	1329838	1329843	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:42	1329838	1329843	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50 1
05/22/21	05/23/21	0:42	1329838	1329843	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50 1
05/22/21	05/23/21	0:42	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:42	1329838	1329843	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:42	1329838	1329843	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50 1
05/22/21	05/23/21	0:42	1329838	1329843	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:42	1329838	1329843	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:42	1329838	1329843	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0 1
05/22/21	05/23/21	0:42	1329838	1329843	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0 1
05/22/21	05/23/21	0:42	1329838	1329843	(EPA 524.2)	Benzene	ND	ug/L	0.50 1
05/22/21	05/23/21	0:42	1329838	1329843	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50 1
05/22/21	05/23/21	0:42	1329838	1329843	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:42	1329838	1329843	(EPA 524.2)	Bromodichloromethane	6.9	ug/L	0.50 1
05/22/21	05/23/21	0:42	1329838	1329843	(EPA 524.2)	Bromoethane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:42	1329838	1329843	(EPA 524.2)	Bromoform	ND (VC)	ug/L	0.50 1
05/22/21	05/23/21	0:42	1329838	1329843	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50 1
05/22/21	05/23/21	0:42	1329838	1329843	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50 1
05/22/21	05/23/21	0:42	1329838	1329843	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50 1
05/22/21	05/23/21	0:42	1329838	1329843	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50 1
05/22/21	05/23/21	0:42	1329838	1329843	(EPA 524.2)	Chlorodibromomethane	2.7	ug/L	0.50 1
05/22/21	05/23/21	0:42	1329838	1329843	(EPA 524.2)	Chloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	0:42	1329838	1329843	(EPA 524.2)	Chloroform (Trichloromethane)	19	ug/L	0.50 1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Total THM	29	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	trans-1,3-Dichloropropene	ND (VC)	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (626) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane-d4	118	%		1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	4-Bromofluorobenzene	98	%		1
05/22/21	05/23/21 0:42	1329838	1329843	(EPA 524.2)	Toluene-d8	94	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
801 Dry Well Rd (Hydrant) (202105130956)						Sampled on 05/12/2021 1120			
EPA 524.2 - Volatile Organics by GCMS									
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50 1
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50 1
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50 1
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50 1
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50 1
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50 1
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50 1
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50 1
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50 1
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50 1
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0 1
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0 1
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	Benzene	ND	ug/L	0.50 1
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50 1
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50 1
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	Bromodichloromethane	9.2	ug/L	0.50 1
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	Bromoethane	ND	ug/L	0.50 1
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	Bromoform	ND (VC)	ug/L	0.50 1
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50 1
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50 1
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50 1
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50 1
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	Chlorodibromomethane	3.5	ug/L	0.50 1
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	Chloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	Chloroform (Trichloromethane)	26	ug/L	0.50 1
05/22/21	05/23/21	1:03	1329838	1329843	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50 1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Total THM	39	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	trans-1,3-Dichloropropene	ND (VC)	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane-d4	115	%		1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	4-Bromofluorobenzene	101	%		1
05/22/21	05/23/21 1:03	1329838	1329843	(EPA 524.2)	Toluene-d8	94	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
1000 Stewart Dr (202105130957)						Sampled on 05/12/2021 1030			
EPA 524.2 - Volatile Organics by GCMS									
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50 1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50 1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50 1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50 1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50 1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50 1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50 1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50 1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50 1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50 1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0 1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0 1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Benzene	ND	ug/L	0.50 1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50 1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50 1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Bromodichloromethane	8.0	ug/L	0.50 1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Bromoethane	ND	ug/L	0.50 1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Bromoform	ND (VC)	ug/L	0.50 1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50 1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50 1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50 1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50 1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Chlorodibromomethane	3.1	ug/L	0.50 1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Chloroethane	ND	ug/L	0.50 1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Chloroform (Trichloromethane)	21	ug/L	0.50 1
05/22/21	05/23/21	1:25	1329838	1329843	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50 1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Total THM	32	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	trans-1,3-Dichloropropene	ND (VC)	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (626) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	1,2-Dichloroethane-d4	114	%		1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	4-Bromofluorobenzene	93	%		1
05/22/21	05/23/21 1:25	1329838	1329843	(EPA 524.2)	Toluene-d8	87	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
Sylvan and Redwood (202105130958)						Sampled on 05/12/2021 1145			
Water Trax ID: 3BC9F									
EPA 524.2 - Volatile Organics by GCMS									
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Bromodichloromethane	5.3	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Bromoform	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Chlorodibromomethane	2.1	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Chloroform (Trichloromethane)	15	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Total THM	22	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (626) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	1,2-Dichloroethane-d4	115	%		1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	4-Bromofluorobenzene	97	%		1
05/23/21	05/23/21 18:58	1329875	1329877	(EPA 524.2)	Toluene-d8	91	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
Riverside and Middle (202105130959)						Sampled on 05/12/2021 0810			
Water Trax ID: 3BCB1									
EPA 524.2 - Volatile Organics by GCMS									
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,1,1,2-Tetrachloroethane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,1,1-Trichloroethane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,1,2,2-Tetrachloroethane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,1,2-Trichloroethane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,1-Dichloroethane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,1-Dichloroethylene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,1-Dichloropropene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,2,3-Trichlorobenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,2,3-Trichloropropane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,2,4-Trichlorobenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,2,4-Trimethylbenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,2-Dichloroethane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,2-Dichloropropane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,3,5-Trimethylbenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,3-Dichloropropane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	2,2-Dichloropropane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	2-Butanone (MEK)	ND	ug/L	5.0	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	4-Methyl-2-Pentanone (MIBK)	ND	ug/L	5.0	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Benzene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Bromobenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Bromochloromethane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Bromodichloromethane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Bromoethane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Bromoform	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Bromomethane (Methyl Bromide)	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Carbon disulfide	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Carbon Tetrachloride	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Chlorobenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Chlorodibromomethane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Chloroethane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Chloroform (Trichloromethane)	0.72	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Chloromethane(Methyl Chloride)	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	cis-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	cis-1,3-Dichloropropene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Dibromomethane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Dichlorodifluoromethane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Dichloromethane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Di-isopropyl ether	ND	ug/L	3.0	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Ethyl benzene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Hexachlorobutadiene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Isopropylbenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	m,p-Xylenes	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	m-Dichlorobenzene (1,3-DCB)	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Methyl Tert-butyl ether (MTBE)	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Naphthalene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	n-Butylbenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	n-Propylbenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	o-Chlorotoluene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	o-Dichlorobenzene (1,2-DCB)	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	o-Xylene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	p-Chlorotoluene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	p-Dichlorobenzene (1,4-DCB)	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	p-Isopropyltoluene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	sec-Butylbenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Styrene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	tert-amyl Methyl Ether	ND	ug/L	3.0	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	tert-Butyl Ethyl Ether	ND	ug/L	3.0	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	tert-Butylbenzene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Tetrachloroethylene (PCE)	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Toluene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Total 1,3-Dichloropropene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Total THM	0.72	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Total xylenes	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	trans-1,2-Dichloroethylene	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	trans-1,3-Dichloropropene	ND	ug/L	0.50	1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory Data

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District
Nate Gillespie
13060 Highway 9
Boulder Creek, CA 95006-9119

Samples Received on:
05/13/2021 1017

Prepared	Analyzed	Prep Batch	Analyzed Batch	Method	Analyte	Result	Units	MRL	Dilution
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Trichloroethylene (TCE)	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Trichlorofluoromethane	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Trichlorotrifluoroethane(Freon 113)	ND	ug/L	0.50	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Vinyl chloride (VC)	ND	ug/L	0.30	1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	1,2-Dichloroethane-d4	116	%		1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	4-Bromofluorobenzene	96	%		1
05/23/21	05/23/21 15:06	1329875	1329877	(EPA 524.2)	Toluene-d8	90	%		1

Rounding on totals after summation.

(c) - indicates calculated results. Analysis is a calculated result. Reported results are not rounded until the final step before reporting. Therefore methods that use a test result with further calculation may have slight differences in final result than the component analyses.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Laboratory QC Summary

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

Volatile Organics by GCMS

Prep Batch: 1329838 Analytical Batch: 1329843

202105130949	815 Forest
202105130950	12788 HWY 9
202105130951	Clear Creek and Alameda
202105130952	275 Brook Ln
202105130953	15030 HWY 9
202105130954	Crescent Dr and River Rd
202105130955	814 Creek Dr
202105130956	801 Dry Well Rd (Hydrant)
202105130957	1000 Stewart Dr

Analysis Date: 05/22/2021

Analyzed by: TG9W
Analyzed by: TG9W
Analyzed by: TG9W
Analyzed by: TG9W
Analyzed by: TG9W
Analyzed by: TG9W
Analyzed by: TG9W
Analyzed by: TG9W
Analyzed by: TG9W

Volatile Organics by GCMS

Prep Batch: 1329875 Analytical Batch: 1329877

202105130958	Sylvan and Redwood
202105130959	Riverside and Middle

Analysis Date: 05/23/2021

Analyzed by: TR7W
Analyzed by: TR7W

Tel: (626) 386-1100
Fax: (626) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

QC Type	Analyte	Native	Spiked	Recovered	Units	Yield(%)	Limits (%)	RPD Limit(%)	RPD%
Volatile Organics by GCMS by EPA 524.2									
Analytical Batch: 1329843					Analysis Date: 05/22/2021				
LCS1	1,1,1,2-Tetrachloroethane		5	5.07	ug/L	101	(70-130)		
LCS2	1,1,1,2-Tetrachloroethane		5	5.23	ug/L	105	(70-130)	20	3.1
MBLK	1,1,1,2-Tetrachloroethane			<0.5	ug/L				
MRL_CHK	1,1,1,2-Tetrachloroethane		0.5	0.460	ug/L	92	(50-150)		
LCS1	1,1,1-Trichloroethane		5	4.65	ug/L	93	(70-130)		
LCS2	1,1,1-Trichloroethane		5	4.88	ug/L	98	(70-130)	20	4.8
MBLK	1,1,1-Trichloroethane			<0.5	ug/L				
MRL_CHK	1,1,1-Trichloroethane		0.5	0.460	ug/L	92	(50-150)		
LCS1	1,1,2,2-Tetrachloroethane		5	5.11	ug/L	102	(70-130)		
LCS2	1,1,2,2-Tetrachloroethane		5	5.02	ug/L	100	(70-130)	20	1.8
MBLK	1,1,2,2-Tetrachloroethane			<0.5	ug/L				
MRL_CHK	1,1,2,2-Tetrachloroethane		0.5	0.560	ug/L	112	(50-150)		
LCS1	1,1,2-Trichloroethane		5	5.16	ug/L	103	(70-130)		
LCS2	1,1,2-Trichloroethane		5	5.35	ug/L	107	(70-130)	20	3.6
MBLK	1,1,2-Trichloroethane			<0.5	ug/L				
MRL_CHK	1,1,2-Trichloroethane		0.5	0.520	ug/L	104	(50-150)		
LCS1	1,1-Dichloroethane		5	4.40	ug/L	88	(70-130)		
LCS2	1,1-Dichloroethane		5	4.56	ug/L	91	(70-130)	20	3.6
MBLK	1,1-Dichloroethane			<0.5	ug/L				
MRL_CHK	1,1-Dichloroethane		0.5	0.490	ug/L	98	(50-150)		
LCS1	1,1-Dichloroethylene		5	4.46	ug/L	89	(70-130)		
LCS2	1,1-Dichloroethylene		5	4.45	ug/L	89	(70-130)	20	0.22
MBLK	1,1-Dichloroethylene			<0.5	ug/L				
MRL_CHK	1,1-Dichloroethylene		0.5	0.540	ug/L	108	(50-150)		
LCS1	1,1-Dichloropropene		5	4.45	ug/L	89	(70-130)		
LCS2	1,1-Dichloropropene		5	4.63	ug/L	93	(70-130)	20	4.0
MBLK	1,1-Dichloropropene			<0.5	ug/L				
MRL_CHK	1,1-Dichloropropene		0.5	0.480	ug/L	96	(50-150)		
LCS1	1,2,3-Trichlorobenzene		5	5.11	ug/L	102	(70-130)		
LCS2	1,2,3-Trichlorobenzene		5	5.16	ug/L	103	(70-130)	20	0.97
MBLK	1,2,3-Trichlorobenzene			<0.5	ug/L				
MRL_CHK	1,2,3-Trichlorobenzene		0.5	0.550	ug/L	110	(50-150)		
LCS1	1,2,3-Trichloropropane		5	4.68	ug/L	94	(70-130)		
LCS2	1,2,3-Trichloropropane		5	4.78	ug/L	96	(70-130)	20	2.1
MBLK	1,2,3-Trichloropropane			<0.5	ug/L				

Spike recovery is already corrected for native results.

Spikes which exceed Limits and Method Blanks with positive results are highlighted by Underlining.

Criteria for MS and Dup are advisory only, batch control is based on LCS. Criteria for duplicates are advisory only, unless otherwise specified in the method.

RPD not calculated for LCS2 when different a concentration than LCS1 is used.

RPD not calculated for Duplicates when the result is not five times the MRL (Minimum Reporting Level).

(S) - Indicates surrogate compound.

(I) - Indicates internal standard compound.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

QC Type	Analyte	Native	Spiked	Recovered	Units	Yield(%)	Limits (%)	RPD Limit(%)	RPD%
MRL_CHK	1,2,3-Trichloropropane		0.5	0.560	ug/L	112	(50-150)		
LCS1	1,2,4-Trichlorobenzene		5	4.75	ug/L	95	(70-130)		
LCS2	1,2,4-Trichlorobenzene		5	4.86	ug/L	97	(70-130)	20	2.3
MBLK	1,2,4-Trichlorobenzene			<0.5	ug/L				
MRL_CHK	1,2,4-Trichlorobenzene		0.5	0.500	ug/L	100	(50-150)		
LCS1	1,2,4-Trimethylbenzene		5	4.81	ug/L	96	(70-130)		
LCS2	1,2,4-Trimethylbenzene		5	4.84	ug/L	97	(70-130)	20	0.62
MBLK	1,2,4-Trimethylbenzene			<0.5	ug/L				
MRL_CHK	1,2,4-Trimethylbenzene		0.5	0.410	ug/L	82	(50-150)		
LCS1	1,2-Dichloroethane		5	4.98	ug/L	100	(70-130)		
LCS2	1,2-Dichloroethane		5	5.00	ug/L	100	(70-130)	20	0.40
MBLK	1,2-Dichloroethane			<0.5	ug/L				
MRL_CHK	1,2-Dichloroethane		0.5	0.560	ug/L	112	(50-150)		
LCS1	1,2-Dichloroethane-d4 (S)		5	102	%	102	(70-130)		
LCS2	1,2-Dichloroethane-d4 (S)		5	102	%	102	(70-130)		
MBLK	1,2-Dichloroethane-d4 (S)			112	%	112	(70-130)		
MRL_CHK	1,2-Dichloroethane-d4 (S)		5	106	%	106	(70-130)		
MRLW	1,2-Dichloroethane-d4 (S)		5	107	%	107	(70-130)		
LCS1	1,2-Dichloropropane		5	4.84	ug/L	97	(70-130)		
LCS2	1,2-Dichloropropane		5	5.00	ug/L	100	(70-130)	20	3.3
MBLK	1,2-Dichloropropane			<0.5	ug/L				
MRL_CHK	1,2-Dichloropropane		0.5	0.500	ug/L	100	(50-150)		
LCS1	1,3,5-Trimethylbenzene		5	4.73	ug/L	95	(70-130)		
LCS2	1,3,5-Trimethylbenzene		5	4.77	ug/L	95	(70-130)	20	0.84
MBLK	1,3,5-Trimethylbenzene			<0.5	ug/L				
MRL_CHK	1,3,5-Trimethylbenzene		0.5	0.420	ug/L	84	(50-150)		
LCS1	1,3-Dichloropropane		5	4.98	ug/L	100	(70-130)		
LCS2	1,3-Dichloropropane		5	5.16	ug/L	103	(70-130)	20	3.5
MBLK	1,3-Dichloropropane			<0.5	ug/L				
MRL_CHK	1,3-Dichloropropane		0.5	0.510	ug/L	102	(50-150)		
LCS1	2,2-Dichloropropane		5	4.76	ug/L	95	(70-130)		
LCS2	2,2-Dichloropropane		5	4.55	ug/L	91	(70-130)	20	4.5
MBLK	2,2-Dichloropropane			<0.5	ug/L				
MRL_CHK	2,2-Dichloropropane		0.5	0.510	ug/L	102	(50-150)		
LCS1	2-Butanone (MEK)		50	47.9	ug/L	96	(70-130)		
LCS2	2-Butanone (MEK)		50	49.5	ug/L	99	(70-130)	20	3.3
MBLK	2-Butanone (MEK)			<5.0	ug/L				
MRL_CHK	2-Butanone (MEK)		5	5.18	ug/L	104	(50-150)		

Spike recovery is already corrected for native results.

Spikes which exceed Limits and Method Blanks with positive results are highlighted by Underlining.

Criteria for MS and Dup are advisory only, batch control is based on LCS. Criteria for duplicates are advisory only, unless otherwise specified in the method.

RPD not calculated for LCS2 when different a concentration than LCS1 is used.

RPD not calculated for Duplicates when the result is not five times the MRL (Minimum Reporting Level).

(S) - Indicates surrogate compound.

(I) - Indicates internal standard compound.

Tel: (626) 386-1100
Fax: (626) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

QC Type	Analyte	Native	Spiked	Recovered	Units	Yield(%)	Limits (%)	RPD Limit(%)	RPD%
LCS1	4-Bromofluorobenzene (S)		5	95.6	%	96	(70-130)		
LCS2	4-Bromofluorobenzene (S)		5	95.0	%	95	(70-130)		
MBLK	4-Bromofluorobenzene (S)			94.4	%	94	(70-130)		
MRL_CHK	4-Bromofluorobenzene (S)		5	97.8	%	98	(70-130)		
MRLLW	4-Bromofluorobenzene (S)		5	96.2	%	96	(70-130)		
LCS1	4-Methyl-2-Pentanone (MIBK)		50	53.3	ug/L	107	(70-130)		
LCS2	4-Methyl-2-Pentanone (MIBK)		50	55.6	ug/L	111	(70-130)	20	4.2
MBLK	4-Methyl-2-Pentanone (MIBK)			<5.0	ug/L				
MRL_CHK	4-Methyl-2-Pentanone (MIBK)		5	4.62	ug/L	92	(50-150)		
LCS1	Benzene		5	4.93	ug/L	99	(70-130)		
LCS2	Benzene		5	5.11	ug/L	102	(70-130)	20	3.6
MBLK	Benzene			<0.5	ug/L				
MRL_CHK	Benzene		0.5	0.520	ug/L	104	(50-150)		
LCS1	Bromobenzene		5	4.57	ug/L	91	(70-130)		
LCS2	Bromobenzene		5	4.65	ug/L	93	(70-130)	20	1.7
MBLK	Bromobenzene			<0.5	ug/L				
MRL_CHK	Bromobenzene		0.5	0.490	ug/L	98	(50-150)		
LCS1	Bromochloromethane		5	4.96	ug/L	99	(70-130)		
LCS2	Bromochloromethane		5	5.11	ug/L	102	(70-130)	20	3.0
MBLK	Bromochloromethane			<0.5	ug/L				
MRL_CHK	Bromochloromethane		0.5	0.580	ug/L	116	(50-150)		
LCS1	Bromodichloromethane		5	4.83	ug/L	97	(70-130)		
LCS2	Bromodichloromethane		5	4.88	ug/L	98	(70-130)	20	1.0
MBLK	Bromodichloromethane			<0.5	ug/L				
MRL_CHK	Bromodichloromethane		0.5	0.470	ug/L	94	(50-150)		
LCS1	Bromoethane		5	4.70	ug/L	94	(70-130)		
LCS2	Bromoethane		5	4.75	ug/L	95	(70-130)	20	1.1
MBLK	Bromoethane			<0.5	ug/L				
MRL_CHK	Bromoethane		0.5	0.510	ug/L	102	(50-150)		
LCS1	Bromoform		5	5.72	ug/L	114	(70-130)		
LCS2	Bromoform		5	5.51	ug/L	110	(70-130)	20	3.7
MBLK	Bromoform			<0.5	ug/L				
MRL_CHK	Bromoform		0.5	0.560	ug/L	112	(50-150)		
LCS1	Bromomethane (Methyl Bromide)		5	4.83	ug/L	97	(70-130)		
LCS2	Bromomethane (Methyl Bromide)		5	4.87	ug/L	97	(70-130)	20	0.83
MBLK	Bromomethane (Methyl Bromide)			<0.5	ug/L				
MRL_CHK	Bromomethane (Methyl Bromide)		0.5	0.490	ug/L	98	(50-150)		
LCS1	Carbon disulfide		5	4.66	ug/L	93	(70-130)		

Spike recovery is already corrected for native results.

Spikes which exceed Limits and Method Blanks with positive results are highlighted by Underlining.

Criteria for MS and Dup are advisory only, batch control is based on LCS. Criteria for duplicates are advisory only, unless otherwise specified in the method.

RPD not calculated for LCS2 when different a concentration than LCS1 is used.

RPD not calculated for Duplicates when the result is not five times the MRL (Minimum Reporting Level).

(S) - Indicates surrogate compound.

(I) - Indicates internal standard compound.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

QC Type	Analyte	Native	Spiked	Recovered	Units	Yield(%)	Limits (%)	RPD Limit(%)	RPD%
LCS2	Carbon disulfide		5	4.77	ug/L	95	(70-130)	20	2.3
MBLK	Carbon disulfide			<0.5	ug/L				
MRL_CHK	Carbon disulfide		0.5	0.500	ug/L	100	(50-150)		
LCS1	Carbon Tetrachloride		5	4.64	ug/L	93	(70-130)		
LCS2	Carbon Tetrachloride		5	4.73	ug/L	95	(70-130)	20	1.9
MBLK	Carbon Tetrachloride			<0.5	ug/L				
MRL_CHK	Carbon Tetrachloride		0.5	0.460	ug/L	92	(50-150)		
LCS1	Chlorobenzene		5	4.97	ug/L	99	(70-130)		
LCS2	Chlorobenzene		5	5.12	ug/L	102	(70-130)	20	3.0
MBLK	Chlorobenzene			<0.5	ug/L				
MRL_CHK	Chlorobenzene		0.5	0.490	ug/L	98	(50-150)		
LCS1	Chlorodibromomethane		5	5.58	ug/L	112	(70-130)		
LCS2	Chlorodibromomethane		5	5.67	ug/L	113	(70-130)	20	1.6
MBLK	Chlorodibromomethane			<0.5	ug/L				
MRL_CHK	Chlorodibromomethane		0.5	0.560	ug/L	112	(50-150)		
LCS1	Chloroethane		5	4.23	ug/L	85	(70-130)		
LCS2	Chloroethane		5	4.22	ug/L	84	(70-130)	20	0.24
MBLK	Chloroethane			<0.5	ug/L				
MRL_CHK	Chloroethane		0.5	0.490	ug/L	98	(50-150)		
LCS1	Chloroform (Trichloromethane)		5	4.94	ug/L	99	(70-130)		
LCS2	Chloroform (Trichloromethane)		5	4.98	ug/L	100	(70-130)	20	0.81
MBLK	Chloroform (Trichloromethane)			<0.5	ug/L				
MRL_CHK	Chloroform (Trichloromethane)		0.5	0.540	ug/L	108	(50-150)		
LCS1	Chloromethane(Methyl Chloride)		5	4.48	ug/L	90	(70-130)		
LCS2	Chloromethane(Methyl Chloride)		5	4.66	ug/L	93	(70-130)	20	3.9
MBLK	Chloromethane(Methyl Chloride)			<0.5	ug/L				
MRL_CHK	Chloromethane(Methyl Chloride)		0.5	0.290	ug/L	58	(50-150)		
LCS1	cis-1,2-Dichloroethylene		5	4.82	ug/L	96	(70-130)		
LCS2	cis-1,2-Dichloroethylene		5	4.92	ug/L	98	(70-130)	20	2.0
MBLK	cis-1,2-Dichloroethylene			<0.5	ug/L				
MRL_CHK	cis-1,2-Dichloroethylene		0.5	0.540	ug/L	108	(50-150)		
LCS1	cis-1,3-Dichloropropene		5	5.04	ug/L	101	(70-130)		
LCS2	cis-1,3-Dichloropropene		5	5.25	ug/L	105	(70-130)	20	4.1
MBLK	cis-1,3-Dichloropropene			<0.5	ug/L				
MRL_CHK	cis-1,3-Dichloropropene		0.5	0.450	ug/L	90	(50-150)		
LCS1	Dibromomethane		5	5.01	ug/L	100	(70-130)		
LCS2	Dibromomethane		5	5.05	ug/L	101	(70-130)	20	0.80
MBLK	Dibromomethane			<0.5	ug/L				

Spike recovery is already corrected for native results.

Spikes which exceed Limits and Method Blanks with positive results are highlighted by Underlining.

Criteria for MS and Dup are advisory only, batch control is based on LCS. Criteria for duplicates are advisory only, unless otherwise specified in the method.

RPD not calculated for LCS2 when different a concentration than LCS1 is used.

RPD not calculated for Duplicates when the result is not five times the MRL (Minimum Reporting Level).

(S) - Indicates surrogate compound.

(I) - Indicates internal standard compound.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

QC Type	Analyte	Native	Spiked	Recovered	Units	Yield(%)	Limits (%)	RPD Limit(%)	RPD%
MRL_CHK	Dibromomethane		0.5	0.550	ug/L	110	(50-150)		
LCS1	Dichlorodifluoromethane		5	4.83	ug/L	97	(70-130)		
LCS2	Dichlorodifluoromethane		5	4.87	ug/L	97	(70-130)	20	0.83
MBLK	Dichlorodifluoromethane			<0.5	ug/L				
MRL_CHK	Dichlorodifluoromethane		0.5	0.490	ug/L	98	(50-150)		
LCS1	Dichloromethane		5	4.62	ug/L	92	(70-130)		
LCS2	Dichloromethane		5	4.54	ug/L	91	(70-130)	20	1.8
MBLK	Dichloromethane			<0.5	ug/L				
MRL_CHK	Dichloromethane		0.5	0.590	ug/L	118	(50-150)		
LCS1	Di-isopropyl ether		5	4.19	ug/L	84	(70-130)		
LCS2	Di-isopropyl ether		5	4.29	ug/L	86	(70-130)	20	2.4
MBLK	Di-isopropyl ether			<3.0	ug/L				
MRL_CHK	Di-isopropyl ether		0.5	0.480	ug/L	96	(50-150)		
LCS1	Ethyl benzene		5	4.77	ug/L	95	(70-130)		
LCS2	Ethyl benzene		5	4.99	ug/L	100	(70-130)	20	4.5
MBLK	Ethyl benzene			<0.5	ug/L				
MRL_CHK	Ethyl benzene		0.5	0.410	ug/L	82	(50-150)		
LCS1	Hexachlorobutadiene		5	4.97	ug/L	99	(70-130)		
LCS2	Hexachlorobutadiene		5	5.13	ug/L	103	(70-130)	20	3.2
MBLK	Hexachlorobutadiene			<0.5	ug/L				
MRL_CHK	Hexachlorobutadiene		0.5	0.530	ug/L	106	(50-150)		
LCS1	Isopropylbenzene		5	4.61	ug/L	92	(70-130)		
LCS2	Isopropylbenzene		5	4.72	ug/L	94	(70-130)	20	2.4
MBLK	Isopropylbenzene			<0.5	ug/L				
MRL_CHK	Isopropylbenzene		0.5	0.420	ug/L	84	(50-150)		
LCS1	m,p-Xylenes		10	10.2	ug/L	102	(70-130)		
LCS2	m,p-Xylenes		10	10.6	ug/L	106	(70-130)	20	3.9
MBLK	m,p-Xylenes			<0.5	ug/L				
MRL_CHK	m,p-Xylenes		1	0.840	ug/L	84	(50-150)		
MRLLW	m,p-Xylenes		0.5	0.390	ug/L	78	(50-150)		
LCS1	m-Dichlorobenzene (1,3-DCB)		5	4.78	ug/L	96	(70-130)		
LCS2	m-Dichlorobenzene (1,3-DCB)		5	4.83	ug/L	97	(70-130)	20	1.0
MBLK	m-Dichlorobenzene (1,3-DCB)			<0.5	ug/L				
MRL_CHK	m-Dichlorobenzene (1,3-DCB)		0.5	0.520	ug/L	104	(50-150)		
LCS1	Methyl Tert-butyl ether (MTBE)		5	4.75	ug/L	95	(70-130)		
LCS2	Methyl Tert-butyl ether (MTBE)		5	4.68	ug/L	94	(70-130)	20	1.5
MBLK	Methyl Tert-butyl ether (MTBE)			<0.5	ug/L				
MRL_CHK	Methyl Tert-butyl ether (MTBE)		0.5	0.510	ug/L	102	(50-150)		

Spike recovery is already corrected for native results.

Spikes which exceed Limits and Method Blanks with positive results are highlighted by Underlining.

Criteria for MS and Dup are advisory only, batch control is based on LCS. Criteria for duplicates are advisory only, unless otherwise specified in the method.

RPD not calculated for LCS2 when different a concentration than LCS1 is used.

RPD not calculated for Duplicates when the result is not five times the MRL (Minimum Reporting Level).

(S) - Indicates surrogate compound.

(I) - Indicates internal standard compound.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

QC Type	Analyte	Native	Spiked	Recovered	Units	Yield(%)	Limits (%)	RPD Limit(%)	RPD%
LCS1	Naphthalene		5	4.82	ug/L	96	(70-130)		
LCS2	Naphthalene		5	4.94	ug/L	99	(70-130)	20	2.5
MBLK	Naphthalene			<0.5	ug/L				
MRL_CHK	Naphthalene		0.5	0.470	ug/L	94	(50-150)		
LCS1	n-Butylbenzene		5	4.66	ug/L	93	(70-130)		
LCS2	n-Butylbenzene		5	4.85	ug/L	97	(70-130)	20	4.0
MBLK	n-Butylbenzene			<0.5	ug/L				
MRL_CHK	n-Butylbenzene		0.5	0.460	ug/L	92	(50-150)		
LCS1	n-Propylbenzene		5	4.52	ug/L	90	(70-130)		
LCS2	n-Propylbenzene		5	4.62	ug/L	92	(70-130)	20	2.2
MBLK	n-Propylbenzene			<0.5	ug/L				
MRL_CHK	n-Propylbenzene		0.5	0.410	ug/L	82	(50-150)		
LCS1	o-Chlorotoluene		5	4.67	ug/L	93	(70-130)		
LCS2	o-Chlorotoluene		5	4.73	ug/L	95	(70-130)	20	1.3
MBLK	o-Chlorotoluene			<0.5	ug/L				
MRL_CHK	o-Chlorotoluene		0.5	0.460	ug/L	92	(50-150)		
LCS1	o-Dichlorobenzene (1,2-DCB)		5	4.89	ug/L	98	(70-130)		
LCS2	o-Dichlorobenzene (1,2-DCB)		5	5.00	ug/L	100	(70-130)	20	2.2
MBLK	o-Dichlorobenzene (1,2-DCB)			<0.5	ug/L				
MRL_CHK	o-Dichlorobenzene (1,2-DCB)		0.5	0.540	ug/L	108	(50-150)		
LCS1	o-Xylene		5	4.74	ug/L	95	(70-130)		
LCS2	o-Xylene		5	5.01	ug/L	100	(70-130)	20	5.5
MBLK	o-Xylene			<0.5	ug/L				
MRL_CHK	o-Xylene		0.5	0.390	ug/L	78	(50-150)		
LCS1	p-Chlorotoluene		5	4.76	ug/L	95	(70-130)		
LCS2	p-Chlorotoluene		5	4.88	ug/L	98	(70-130)	20	2.5
MBLK	p-Chlorotoluene			<0.5	ug/L				
MRL_CHK	p-Chlorotoluene		0.5	0.470	ug/L	94	(50-150)		
LCS1	p-Dichlorobenzene (1,4-DCB)		5	4.84	ug/L	97	(70-130)		
LCS2	p-Dichlorobenzene (1,4-DCB)		5	4.78	ug/L	96	(70-130)	20	1.3
MBLK	p-Dichlorobenzene (1,4-DCB)			<0.5	ug/L				
MRL_CHK	p-Dichlorobenzene (1,4-DCB)		0.5	0.510	ug/L	102	(50-150)		
LCS1	p-Isopropyltoluene		5	4.78	ug/L	96	(70-130)		
LCS2	p-Isopropyltoluene		5	4.86	ug/L	97	(70-130)	20	1.7
MBLK	p-Isopropyltoluene			<0.5	ug/L				
MRL_CHK	p-Isopropyltoluene		0.5	0.400	ug/L	80	(50-150)		
LCS1	sec-Butylbenzene		5	5.22	ug/L	104	(70-130)		
LCS2	sec-Butylbenzene		5	5.29	ug/L	106	(70-130)	20	1.3

Spike recovery is already corrected for native results.

Spikes which exceed Limits and Method Blanks with positive results are highlighted by Underlining.

Criteria for MS and Dup are advisory only, batch control is based on LCS. Criteria for duplicates are advisory only, unless otherwise specified in the method.

RPD not calculated for LCS2 when different a concentration than LCS1 is used.

RPD not calculated for Duplicates when the result is not five times the MRL (Minimum Reporting Level).

(S) - Indicates surrogate compound.

(I) - Indicates internal standard compound.

Tel: (626) 386-1100
Fax: (626) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

QC Type	Analyte	Native	Spiked	Recovered	Units	Yield(%)	Limits (%)	RPD Limit(%)	RPD%
MBLK	sec-Butylbenzene			<0.5	ug/L				
MRL_CHK	sec-Butylbenzene		0.5	0.420	ug/L	84	(50-150)		
LCS1	Styrene		5	5.24	ug/L	105	(70-130)		
LCS2	Styrene		5	5.49	ug/L	110	(70-130)	20	4.7
MBLK	Styrene			<0.5	ug/L				
MRL_CHK	Styrene		0.5	0.390	ug/L	78	(50-150)		
LCS1	tert-amyl Methyl Ether		5	4.75	ug/L	95	(70-130)		
LCS2	tert-amyl Methyl Ether		5	4.76	ug/L	95	(70-130)	20	0.21
MBLK	tert-amyl Methyl Ether			<3.0	ug/L				
MRL_CHK	tert-amyl Methyl Ether		0.5	0.480	ug/L	96	(50-150)		
LCS1	tert-Butyl Ethyl Ether		5	4.61	ug/L	92	(70-130)		
LCS2	tert-Butyl Ethyl Ether		5	5.00	ug/L	100	(70-130)	20	8.1
MBLK	tert-Butyl Ethyl Ether			<3.0	ug/L				
MRL_CHK	tert-Butyl Ethyl Ether		0.5	0.510	ug/L	102	(50-150)		
LCS1	tert-Butylbenzene		5	4.43	ug/L	89	(70-130)		
LCS2	tert-Butylbenzene		5	4.53	ug/L	91	(70-130)	20	2.2
MBLK	tert-Butylbenzene			<0.5	ug/L				
MRL_CHK	tert-Butylbenzene		0.5	0.400	ug/L	80	(50-150)		
LCS1	Tetrachloroethylene (PCE)		5	4.98	ug/L	100	(70-130)		
LCS2	Tetrachloroethylene (PCE)		5	5.16	ug/L	103	(70-130)	20	3.5
MBLK	Tetrachloroethylene (PCE)			<0.5	ug/L				
MRL_CHK	Tetrachloroethylene (PCE)		0.5	0.530	ug/L	106	(50-150)		
LCS1	Toluene		5	5.04	ug/L	101	(70-130)		
LCS2	Toluene		5	5.37	ug/L	107	(70-130)	20	6.3
MBLK	Toluene			<0.5	ug/L				
MRL_CHK	Toluene		0.5	0.510	ug/L	102	(50-150)		
LCS1	Toluene-d8 (S)		5	106	%	106	(70-130)		
LCS2	Toluene-d8 (S)		5	105	%	105	(70-130)		
MBLK	Toluene-d8 (S)			89.8	%	90	(70-130)		
MRL_CHK	Toluene-d8 (S)		5	94.4	%	94	(70-130)		
MRLLW	Toluene-d8 (S)		5	94.4	%	94	(70-130)		
LCS1	trans-1,2-Dichloroethylene		5	4.68	ug/L	94	(70-130)		
LCS2	trans-1,2-Dichloroethylene		5	4.73	ug/L	95	(70-130)	20	1.1
MBLK	trans-1,2-Dichloroethylene			<0.5	ug/L				
MRL_CHK	trans-1,2-Dichloroethylene		0.5	0.470	ug/L	94	(50-150)		
LCS1	trans-1,3-Dichloropropene		5	5.14	ug/L	103	(70-130)		
LCS2	trans-1,3-Dichloropropene		5	5.14	ug/L	103	(70-130)	20	0.0
MBLK	trans-1,3-Dichloropropene			<0.5	ug/L				

Spike recovery is already corrected for native results.

Spikes which exceed Limits and Method Blanks with positive results are highlighted by Underlining.

Criteria for MS and Dup are advisory only, batch control is based on LCS. Criteria for duplicates are advisory only, unless otherwise specified in the method.

RPD not calculated for LCS2 when different a concentration than LCS1 is used.

RPD not calculated for Duplicates when the result is not five times the MRL (Minimum Reporting Level).

(S) - Indicates surrogate compound.

(I) - Indicates internal standard compound.

Tel: (626) 386-1100
Fax: (626) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

QC Type	Analyte	Native	Spiked	Recovered	Units	Yield(%)	Limits (%)	RPD Limit(%)	RPD%
MRL_CHK	trans-1,3-Dichloropropene		0.5	0.420	ug/L	84	(50-150)		
LCS1	Trichloroethylene (TCE)		5	4.82	ug/L	96	(70-130)		
LCS2	Trichloroethylene (TCE)		5	4.92	ug/L	98	(70-130)	20	2.0
MBLK	Trichloroethylene (TCE)			<0.5	ug/L				
MRL_CHK	Trichloroethylene (TCE)		0.5	0.500	ug/L	100	(50-150)		
LCS1	Trichlorofluoromethane		5	4.45	ug/L	89	(70-130)		
LCS2	Trichlorofluoromethane		5	4.61	ug/L	92	(70-130)	20	3.5
MBLK	Trichlorofluoromethane			<0.5	ug/L				
MRL_CHK	Trichlorofluoromethane		0.5	0.510	ug/L	102	(50-150)		
LCS1	Trichlorotrifluoroethane(Freon		5	4.78	ug/L	96	(70-130)		
LCS2	Trichlorotrifluoroethane(Freon		5	4.73	ug/L	95	(70-130)	20	1.1
MBLK	Trichlorotrifluoroethane(Freon			<0.5	ug/L				
MRL_CHK	Trichlorotrifluoroethane(Freon		0.5	0.510	ug/L	102	(50-150)		
LCS1	Vinyl chloride (VC)		5	4.38	ug/L	88	(70-130)		
LCS2	Vinyl chloride (VC)		5	4.48	ug/L	90	(70-130)	20	2.3
MBLK	Vinyl chloride (VC)			<0.3	ug/L				
MRL_CHK	Vinyl chloride (VC)		0.5	0.500	ug/L	100	(50-150)		
MRLW	Vinyl chloride (VC)		0.25	0.170	ug/L	68	(50-150)		

Volatile Organics by GCMS by EPA 524.2

Analytical Batch: 1329877

Analysis Date: 05/23/2021

LCS1	1,1,1,2-Tetrachloroethane		5	4.88	ug/L	98	(70-130)		
LCS2	1,1,1,2-Tetrachloroethane		5	4.94	ug/L	99	(70-130)	20	1.2
MBLK	1,1,1,2-Tetrachloroethane			<0.5	ug/L				
MRL_CHK	1,1,1,2-Tetrachloroethane		0.5	0.440	ug/L	88	(50-150)		
LCS1	1,1,1-Trichloroethane		5	4.83	ug/L	97	(70-130)		
LCS2	1,1,1-Trichloroethane		5	4.69	ug/L	94	(70-130)	20	2.9
MBLK	1,1,1-Trichloroethane			<0.5	ug/L				
MRL_CHK	1,1,1-Trichloroethane		0.5	0.480	ug/L	96	(50-150)		
LCS1	1,1,2,2-Tetrachloroethane		5	4.79	ug/L	96	(70-130)		
LCS2	1,1,2,2-Tetrachloroethane		5	4.61	ug/L	92	(70-130)	20	3.8
MBLK	1,1,2,2-Tetrachloroethane			<0.5	ug/L				
MRL_CHK	1,1,2,2-Tetrachloroethane		0.5	0.540	ug/L	108	(50-150)		
LCS1	1,1,2-Trichloroethane		5	5.07	ug/L	101	(70-130)		
LCS2	1,1,2-Trichloroethane		5	5.07	ug/L	101	(70-130)	20	0.0
MBLK	1,1,2-Trichloroethane			<0.5	ug/L				
MRL_CHK	1,1,2-Trichloroethane		0.5	0.580	ug/L	116	(50-150)		
LCS1	1,1-Dichloroethane		5	4.43	ug/L	89	(70-130)		

Spike recovery is already corrected for native results.

Spikes which exceed Limits and Method Blanks with positive results are highlighted by Underlining.

Criteria for MS and Dup are advisory only, batch control is based on LCS. Criteria for duplicates are advisory only, unless otherwise specified in the method.

RPD not calculated for LCS2 when different a concentration than LCS1 is used.

RPD not calculated for Duplicates when the result is not five times the MRL (Minimum Reporting Level).

(S) - Indicates surrogate compound.

(I) - Indicates internal standard compound.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

QC Type	Analyte	Native	Spiked	Recovered	Units	Yield(%)	Limits (%)	RPD Limit(%)	RPD%
LCS2	1,1-Dichloroethane		5	4.37	ug/L	87	(70-130)	20	1.4
MBLK	1,1-Dichloroethane			<0.5	ug/L				
MRL_CHK	1,1-Dichloroethane		0.5	0.510	ug/L	102	(50-150)		
LCS1	1,1-Dichloroethylene		5	4.55	ug/L	91	(70-130)		
LCS2	1,1-Dichloroethylene		5	4.59	ug/L	92	(70-130)	20	0.88
MBLK	1,1-Dichloroethylene			<0.5	ug/L				
MRL_CHK	1,1-Dichloroethylene		0.5	0.530	ug/L	106	(50-150)		
LCS1	1,1-Dichloropropene		5	4.58	ug/L	92	(70-130)		
LCS2	1,1-Dichloropropene		5	4.65	ug/L	93	(70-130)	20	1.5
MBLK	1,1-Dichloropropene			<0.5	ug/L				
MRL_CHK	1,1-Dichloropropene		0.5	0.470	ug/L	94	(50-150)		
LCS1	1,2,3-Trichlorobenzene		5	4.95	ug/L	99	(70-130)		
LCS2	1,2,3-Trichlorobenzene		5	4.82	ug/L	96	(70-130)	20	2.7
MBLK	1,2,3-Trichlorobenzene			<0.5	ug/L				
MRL_CHK	1,2,3-Trichlorobenzene		0.5	0.500	ug/L	100	(50-150)		
LCS1	1,2,3-Trichloropropane		5	4.60	ug/L	92	(70-130)		
LCS2	1,2,3-Trichloropropane		5	4.52	ug/L	90	(70-130)	20	1.8
MBLK	1,2,3-Trichloropropane			<0.5	ug/L				
MRL_CHK	1,2,3-Trichloropropane		0.5	0.520	ug/L	104	(50-150)		
LCS1	1,2,4-Trichlorobenzene		5	4.55	ug/L	91	(70-130)		
LCS2	1,2,4-Trichlorobenzene		5	4.47	ug/L	89	(70-130)	20	1.8
MBLK	1,2,4-Trichlorobenzene			<0.5	ug/L				
MRL_CHK	1,2,4-Trichlorobenzene		0.5	0.480	ug/L	96	(50-150)		
LCS1	1,2,4-Trimethylbenzene		5	4.89	ug/L	98	(70-130)		
LCS2	1,2,4-Trimethylbenzene		5	4.68	ug/L	94	(70-130)	20	4.4
MBLK	1,2,4-Trimethylbenzene			<0.5	ug/L				
MRL_CHK	1,2,4-Trimethylbenzene		0.5	0.380	ug/L	76	(50-150)		
LCS1	1,2-Dichloroethane		5	4.82	ug/L	96	(70-130)		
LCS2	1,2-Dichloroethane		5	4.95	ug/L	99	(70-130)	20	2.7
MBLK	1,2-Dichloroethane			<0.5	ug/L				
MRL_CHK	1,2-Dichloroethane		0.5	0.520	ug/L	104	(50-150)		
LCS1	1,2-Dichloroethane-d4 (S)		5	106	%	106	(70-130)		
LCS2	1,2-Dichloroethane-d4 (S)		5	104	%	104	(70-130)		
MBLK	1,2-Dichloroethane-d4 (S)			112	%	112	(70-130)		
MRL_CHK	1,2-Dichloroethane-d4 (S)		5	109	%	109	(70-130)		
MRLLW	1,2-Dichloroethane-d4 (S)		5	112	%	112	(70-130)		
LCS1	1,2-Dichloropropane		5	4.69	ug/L	94	(70-130)		
LCS2	1,2-Dichloropropane		5	4.75	ug/L	95	(70-130)	20	1.3

Spike recovery is already corrected for native results.

Spikes which exceed Limits and Method Blanks with positive results are highlighted by Underlining.

Criteria for MS and Dup are advisory only, batch control is based on LCS. Criteria for duplicates are advisory only, unless otherwise specified in the method.

RPD not calculated for LCS2 when different a concentration than LCS1 is used.

RPD not calculated for Duplicates when the result is not five times the MRL (Minimum Reporting Level).

(S) - Indicates surrogate compound.

(I) - Indicates internal standard compound.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

QC Type	Analyte	Native	Spiked	Recovered	Units	Yield(%)	Limits (%)	RPD Limit(%)	RPD%
MBLK	1,2-Dichloropropane			<0.5	ug/L				
MRL_CHK	1,2-Dichloropropane		0.5	0.520	ug/L	104	(50-150)		
LCS1	1,3,5-Trimethylbenzene		5	4.83	ug/L	97	(70-130)		
LCS2	1,3,5-Trimethylbenzene		5	4.66	ug/L	93	(70-130)	20	3.6
MBLK	1,3,5-Trimethylbenzene			<0.5	ug/L				
MRL_CHK	1,3,5-Trimethylbenzene		0.5	0.400	ug/L	80	(50-150)		
LCS1	1,3-Dichloropropane		5	4.80	ug/L	96	(70-130)		
LCS2	1,3-Dichloropropane		5	4.81	ug/L	96	(70-130)	20	0.21
MBLK	1,3-Dichloropropane			<0.5	ug/L				
MRL_CHK	1,3-Dichloropropane		0.5	0.490	ug/L	98	(50-150)		
LCS1	2,2-Dichloropropane		5	4.71	ug/L	94	(70-130)		
LCS2	2,2-Dichloropropane		5	4.37	ug/L	87	(70-130)	20	7.5
MBLK	2,2-Dichloropropane			<0.5	ug/L				
MRL_CHK	2,2-Dichloropropane		0.5	0.480	ug/L	96	(50-150)		
LCS1	2-Butanone (MEK)		50	46.1	ug/L	92	(70-130)		
LCS2	2-Butanone (MEK)		50	46.5	ug/L	93	(70-130)	20	0.86
MBLK	2-Butanone (MEK)			<5.0	ug/L				
MRL_CHK	2-Butanone (MEK)		5	5.29	ug/L	106	(50-150)		
LCS1	4-Bromofluorobenzene (S)		5	97.4	%	97	(70-130)		
LCS2	4-Bromofluorobenzene (S)		5	94.2	%	94	(70-130)		
MBLK	4-Bromofluorobenzene (S)			101	%	101	(70-130)		
MRL_CHK	4-Bromofluorobenzene (S)		5	98.6	%	99	(70-130)		
MRLLW	4-Bromofluorobenzene (S)		5	101	%	101	(70-130)		
LCS1	4-Methyl-2-Pentanone (MIBK)		50	50.4	ug/L	101	(70-130)		
LCS2	4-Methyl-2-Pentanone (MIBK)		50	51.4	ug/L	103	(70-130)	20	2.0
MBLK	4-Methyl-2-Pentanone (MIBK)			<5.0	ug/L				
MRL_CHK	4-Methyl-2-Pentanone (MIBK)		5	4.48	ug/L	90	(50-150)		
LCS1	Benzene		5	4.85	ug/L	97	(70-130)		
LCS2	Benzene		5	4.86	ug/L	97	(70-130)	20	0.21
MBLK	Benzene			<0.5	ug/L				
MRL_CHK	Benzene		0.5	0.490	ug/L	98	(50-150)		
LCS1	Bromobenzene		5	4.44	ug/L	89	(70-130)		
LCS2	Bromobenzene		5	4.37	ug/L	87	(70-130)	20	1.6
MBLK	Bromobenzene			<0.5	ug/L				
MRL_CHK	Bromobenzene		0.5	0.480	ug/L	96	(50-150)		
LCS1	Bromochloromethane		5	4.99	ug/L	100	(70-130)		
LCS2	Bromochloromethane		5	4.98	ug/L	100	(70-130)	20	0.20
MBLK	Bromochloromethane			<0.5	ug/L				

Spike recovery is already corrected for native results.

Spikes which exceed Limits and Method Blanks with positive results are highlighted by Underlining.

Criteria for MS and Dup are advisory only, batch control is based on LCS. Criteria for duplicates are advisory only, unless otherwise specified in the method.

RPD not calculated for LCS2 when different a concentration than LCS1 is used.

RPD not calculated for Duplicates when the result is not five times the MRL (Minimum Reporting Level).

(S) - Indicates surrogate compound.

(I) - Indicates internal standard compound.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

QC Type	Analyte	Native	Spiked	Recovered	Units	Yield(%)	Limits (%)	RPD Limit(%)	RPD%
MRL_CHK	Bromochloromethane		0.5	0.520	ug/L	104	(50-150)		
LCS1	Bromodichloromethane		5	4.72	ug/L	94	(70-130)		
LCS2	Bromodichloromethane		5	4.80	ug/L	96	(70-130)	20	1.7
MBLK	Bromodichloromethane			<0.5	ug/L				
MRL_CHK	Bromodichloromethane		0.5	0.440	ug/L	88	(50-150)		
LCS1	Bromoethane		5	4.55	ug/L	91	(70-130)		
LCS2	Bromoethane		5	4.39	ug/L	88	(70-130)	20	3.6
MBLK	Bromoethane			<0.5	ug/L				
MRL_CHK	Bromoethane		0.5	0.490	ug/L	98	(50-150)		
LCS1	Bromoform		5	5.18	ug/L	104	(70-130)		
LCS2	Bromoform		5	5.11	ug/L	102	(70-130)	20	1.4
MBLK	Bromoform			<0.5	ug/L				
MRL_CHK	Bromoform		0.5	0.500	ug/L	100	(50-150)		
LCS1	Bromomethane (Methyl Bromide)		5	4.51	ug/L	90	(70-130)		
LCS2	Bromomethane (Methyl Bromide)		5	4.53	ug/L	91	(70-130)	20	0.44
MBLK	Bromomethane (Methyl Bromide)			<0.5	ug/L				
MRL_CHK	Bromomethane (Methyl Bromide)		0.5	0.500	ug/L	100	(50-150)		
LCS1	Carbon disulfide		5	3.97	ug/L	79	(70-130)		
LCS2	Carbon disulfide		5	4.00	ug/L	80	(70-130)	20	0.75
MBLK	Carbon disulfide			<0.5	ug/L				
MRL_CHK	Carbon disulfide		0.5	0.410	ug/L	82	(50-150)		
LCS1	Carbon Tetrachloride		5	4.79	ug/L	96	(70-130)		
LCS2	Carbon Tetrachloride		5	4.85	ug/L	97	(70-130)	20	1.2
MBLK	Carbon Tetrachloride			<0.5	ug/L				
MRL_CHK	Carbon Tetrachloride		0.5	0.430	ug/L	86	(50-150)		
LCS1	Chlorobenzene		5	4.89	ug/L	98	(70-130)		
LCS2	Chlorobenzene		5	4.82	ug/L	96	(70-130)	20	1.4
MBLK	Chlorobenzene			<0.5	ug/L				
MRL_CHK	Chlorobenzene		0.5	0.480	ug/L	96	(50-150)		
LCS1	Chlorodibromomethane		5	5.34	ug/L	107	(70-130)		
LCS2	Chlorodibromomethane		5	5.37	ug/L	107	(70-130)	20	0.56
MBLK	Chlorodibromomethane			<0.5	ug/L				
MRL_CHK	Chlorodibromomethane		0.5	0.560	ug/L	112	(50-150)		
LCS1	Chloroethane		5	4.24	ug/L	85	(70-130)		
LCS2	Chloroethane		5	4.13	ug/L	83	(70-130)	20	2.6
MBLK	Chloroethane			<0.5	ug/L				
MRL_CHK	Chloroethane		0.5	0.490	ug/L	98	(50-150)		
LCS1	Chloroform (Trichloromethane)		5	4.98	ug/L	100	(70-130)		

Spike recovery is already corrected for native results.

Spikes which exceed Limits and Method Blanks with positive results are highlighted by Underlining.

Criteria for MS and Dup are advisory only, batch control is based on LCS. Criteria for duplicates are advisory only, unless otherwise specified in the method.

RPD not calculated for LCS2 when different a concentration than LCS1 is used.

RPD not calculated for Duplicates when the result is not five times the MRL (Minimum Reporting Level).

(S) - Indicates surrogate compound.

(I) - Indicates internal standard compound.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

QC Type	Analyte	Native	Spiked	Recovered	Units	Yield(%)	Limits (%)	RPD Limit(%)	RPD%
LCS2	Chloroform (Trichloromethane)		5	4.95	ug/L	99	(70-130)	20	0.60
MBLK	Chloroform (Trichloromethane)			<0.5	ug/L				
MRL_CHK	Chloroform (Trichloromethane)		0.5	0.540	ug/L	108	(50-150)		
LCS1	Chloromethane(Methyl Chloride)		5	4.27	ug/L	85	(70-130)		
LCS2	Chloromethane(Methyl Chloride)		5	4.16	ug/L	83	(70-130)	20	2.6
MBLK	Chloromethane(Methyl Chloride)			<0.5	ug/L				
MRL_CHK	Chloromethane(Methyl Chloride)		0.5	0.290	ug/L	58	(50-150)		
LCS1	cis-1,2-Dichloroethylene		5	4.84	ug/L	97	(70-130)		
LCS2	cis-1,2-Dichloroethylene		5	4.81	ug/L	96	(70-130)	20	0.62
MBLK	cis-1,2-Dichloroethylene			<0.5	ug/L				
MRL_CHK	cis-1,2-Dichloroethylene		0.5	0.530	ug/L	106	(50-150)		
LCS1	cis-1,3-Dichloropropene		5	4.85	ug/L	97	(70-130)		
LCS2	cis-1,3-Dichloropropene		5	4.89	ug/L	98	(70-130)	20	0.82
MBLK	cis-1,3-Dichloropropene			<0.5	ug/L				
MRL_CHK	cis-1,3-Dichloropropene		0.5	0.480	ug/L	96	(50-150)		
LCS1	Dibromomethane		5	5.06	ug/L	101	(70-130)		
LCS2	Dibromomethane		5	4.97	ug/L	99	(70-130)	20	1.8
MBLK	Dibromomethane			<0.5	ug/L				
MRL_CHK	Dibromomethane		0.5	0.550	ug/L	110	(50-150)		
LCS1	Dichlorodifluoromethane		5	4.33	ug/L	87	(70-130)		
LCS2	Dichlorodifluoromethane		5	4.16	ug/L	83	(70-130)	20	4.0
MBLK	Dichlorodifluoromethane			<0.5	ug/L				
MRL_CHK	Dichlorodifluoromethane		0.5	0.480	ug/L	96	(50-150)		
LCS1	Dichloromethane		5	4.45	ug/L	89	(70-130)		
LCS2	Dichloromethane		5	4.53	ug/L	91	(70-130)	20	1.8
MBLK	Dichloromethane			<0.5	ug/L				
MRL_CHK	Dichloromethane		0.5	0.530	ug/L	106	(50-150)		
LCS1	Di-isopropyl ether		5	4.09	ug/L	82	(70-130)		
LCS2	Di-isopropyl ether		5	4.04	ug/L	81	(70-130)	20	1.2
MBLK	Di-isopropyl ether			<3.0	ug/L				
MRL_CHK	Di-isopropyl ether		0.5	0.460	ug/L	92	(50-150)		
LCS1	Ethyl benzene		5	4.70	ug/L	94	(70-130)		
LCS2	Ethyl benzene		5	4.73	ug/L	95	(70-130)	20	0.64
MBLK	Ethyl benzene			<0.5	ug/L				
MRL_CHK	Ethyl benzene		0.5	0.400	ug/L	80	(50-150)		
LCS1	Hexachlorobutadiene		5	4.87	ug/L	97	(70-130)		
LCS2	Hexachlorobutadiene		5	4.71	ug/L	94	(70-130)	20	3.3
MBLK	Hexachlorobutadiene			<0.5	ug/L				

Spike recovery is already corrected for native results.

Spikes which exceed Limits and Method Blanks with positive results are highlighted by Underlining.

Criteria for MS and Dup are advisory only, batch control is based on LCS. Criteria for duplicates are advisory only, unless otherwise specified in the method.

RPD not calculated for LCS2 when different a concentration than LCS1 is used.

RPD not calculated for Duplicates when the result is not five times the MRL (Minimum Reporting Level).

(S) - Indicates surrogate compound.

(I) - Indicates internal standard compound.

Tel: (626) 386-1100
Fax: (626) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

QC Type	Analyte	Native	Spiked	Recovered	Units	Yield(%)	Limits (%)	RPD Limit(%)	RPD%
MRL_CHK	Hexachlorobutadiene		0.5	0.520	ug/L	104	(50-150)		
LCS1	Isopropylbenzene		5	4.64	ug/L	93	(70-130)		
LCS2	Isopropylbenzene		5	4.45	ug/L	89	(70-130)	20	4.2
MBLK	Isopropylbenzene			<0.5	ug/L				
MRL_CHK	Isopropylbenzene		0.5	0.390	ug/L	78	(50-150)		
LCS1	m,p-Xylenes		10	10.2	ug/L	102	(70-130)		
LCS2	m,p-Xylenes		10	10.2	ug/L	102	(70-130)	20	0.0
MBLK	m,p-Xylenes			<0.5	ug/L				
MRL_CHK	m,p-Xylenes		1	0.750	ug/L	75	(50-150)		
MRLWL	m,p-Xylenes		0.5	0.410	ug/L	82	(50-150)		
LCS1	m-Dichlorobenzene (1,3-DCB)		5	4.71	ug/L	94	(70-130)		
LCS2	m-Dichlorobenzene (1,3-DCB)		5	4.54	ug/L	91	(70-130)	20	3.7
MBLK	m-Dichlorobenzene (1,3-DCB)			<0.5	ug/L				
MRL_CHK	m-Dichlorobenzene (1,3-DCB)		0.5	0.510	ug/L	102	(50-150)		
LCS1	Methyl Tert-butyl ether (MTBE)		5	4.44	ug/L	89	(70-130)		
LCS2	Methyl Tert-butyl ether (MTBE)		5	4.53	ug/L	91	(70-130)	20	2.0
MBLK	Methyl Tert-butyl ether (MTBE)			<0.5	ug/L				
MRL_CHK	Methyl Tert-butyl ether (MTBE)		0.5	0.510	ug/L	102	(50-150)		
LCS1	Naphthalene		5	4.55	ug/L	91	(70-130)		
LCS2	Naphthalene		5	4.49	ug/L	90	(70-130)	20	1.3
MBLK	Naphthalene			<0.5	ug/L				
MRL_CHK	Naphthalene		0.5	0.420	ug/L	84	(50-150)		
LCS1	n-Butylbenzene		5	4.97	ug/L	99	(70-130)		
LCS2	n-Butylbenzene		5	4.81	ug/L	96	(70-130)	20	3.3
MBLK	n-Butylbenzene			<0.5	ug/L				
MRL_CHK	n-Butylbenzene		0.5	0.400	ug/L	80	(50-150)		
LCS1	n-Propylbenzene		5	4.71	ug/L	94	(70-130)		
LCS2	n-Propylbenzene		5	4.46	ug/L	89	(70-130)	20	5.5
MBLK	n-Propylbenzene			<0.5	ug/L				
MRL_CHK	n-Propylbenzene		0.5	0.430	ug/L	86	(50-150)		
LCS1	o-Chlorotoluene		5	4.73	ug/L	95	(70-130)		
LCS2	o-Chlorotoluene		5	4.52	ug/L	90	(70-130)	20	4.5
MBLK	o-Chlorotoluene			<0.5	ug/L				
MRL_CHK	o-Chlorotoluene		0.5	0.430	ug/L	86	(50-150)		
LCS1	o-Dichlorobenzene (1,2-DCB)		5	4.83	ug/L	97	(70-130)		
LCS2	o-Dichlorobenzene (1,2-DCB)		5	4.67	ug/L	93	(70-130)	20	3.4
MBLK	o-Dichlorobenzene (1,2-DCB)			<0.5	ug/L				
MRL_CHK	o-Dichlorobenzene (1,2-DCB)		0.5	0.500	ug/L	100	(50-150)		

Spike recovery is already corrected for native results.

Spikes which exceed Limits and Method Blanks with positive results are highlighted by Underlining.

Criteria for MS and Dup are advisory only, batch control is based on LCS. Criteria for duplicates are advisory only, unless otherwise specified in the method.

RPD not calculated for LCS2 when different a concentration than LCS1 is used.

RPD not calculated for Duplicates when the result is not five times the MRL (Minimum Reporting Level).

(S) - Indicates surrogate compound.

(I) - Indicates internal standard compound.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

QC Type	Analyte	Native	Spiked	Recovered	Units	Yield(%)	Limits (%)	RPD Limit(%)	RPD%
LCS1	o-Xylene		5	4.72	ug/L	94	(70-130)		
LCS2	o-Xylene		5	4.72	ug/L	94	(70-130)	20	0.0
MBLK	o-Xylene			<0.5	ug/L				
MRL_CHK	o-Xylene		0.5	0.390	ug/L	78	(50-150)		
LCS1	p-Chlorotoluene		5	4.87	ug/L	97	(70-130)		
LCS2	p-Chlorotoluene		5	4.72	ug/L	94	(70-130)	20	3.1
MBLK	p-Chlorotoluene			<0.5	ug/L				
MRL_CHK	p-Chlorotoluene		0.5	0.440	ug/L	88	(50-150)		
LCS1	p-Dichlorobenzene (1,4-DCB)		5	4.78	ug/L	96	(70-130)		
LCS2	p-Dichlorobenzene (1,4-DCB)		5	4.60	ug/L	92	(70-130)	20	3.8
MBLK	p-Dichlorobenzene (1,4-DCB)			<0.5	ug/L				
MRL_CHK	p-Dichlorobenzene (1,4-DCB)		0.5	0.500	ug/L	100	(50-150)		
LCS1	p-Isopropyltoluene		5	4.78	ug/L	96	(70-130)		
LCS2	p-Isopropyltoluene		5	4.67	ug/L	93	(70-130)	20	2.3
MBLK	p-Isopropyltoluene			<0.5	ug/L				
MRL_CHK	p-Isopropyltoluene		0.5	0.380	ug/L	76	(50-150)		
LCS1	sec-Butylbenzene		5	4.78	ug/L	96	(70-130)		
LCS2	sec-Butylbenzene		5	4.60	ug/L	92	(70-130)	20	3.8
MBLK	sec-Butylbenzene			<0.5	ug/L				
MRL_CHK	sec-Butylbenzene		0.5	0.380	ug/L	76	(50-150)		
LCS1	Styrene		5	5.19	ug/L	104	(70-130)		
LCS2	Styrene		5	5.16	ug/L	103	(70-130)	20	0.58
MBLK	Styrene			<0.5	ug/L				
MRL_CHK	Styrene		0.5	0.390	ug/L	78	(50-150)		
LCS1	tert-amyl Methyl Ether		5	4.39	ug/L	88	(70-130)		
LCS2	tert-amyl Methyl Ether		5	4.46	ug/L	89	(70-130)	20	1.6
MBLK	tert-amyl Methyl Ether			<3.0	ug/L				
MRL_CHK	tert-amyl Methyl Ether		0.5	0.450	ug/L	90	(50-150)		
LCS1	tert-Butyl Ethyl Ether		5	4.35	ug/L	87	(70-130)		
LCS2	tert-Butyl Ethyl Ether		5	4.61	ug/L	92	(70-130)	20	5.8
MBLK	tert-Butyl Ethyl Ether			<3.0	ug/L				
MRL_CHK	tert-Butyl Ethyl Ether		0.5	0.500	ug/L	100	(50-150)		
LCS1	tert-Butylbenzene		5	4.65	ug/L	93	(70-130)		
LCS2	tert-Butylbenzene		5	4.53	ug/L	91	(70-130)	20	2.6
MBLK	tert-Butylbenzene			<0.5	ug/L				
MRL_CHK	tert-Butylbenzene		0.5	0.380	ug/L	76	(50-150)		
LCS1	Tetrachloroethylene (PCE)		5	5.08	ug/L	102	(70-130)		
LCS2	Tetrachloroethylene (PCE)		5	4.96	ug/L	99	(70-130)	20	2.4

Spike recovery is already corrected for native results.

Spikes which exceed Limits and Method Blanks with positive results are highlighted by Underlining.

Criteria for MS and Dup are advisory only, batch control is based on LCS. Criteria for duplicates are advisory only, unless otherwise specified in the method.

RPD not calculated for LCS2 when different a concentration than LCS1 is used.

RPD not calculated for Duplicates when the result is not five times the MRL (Minimum Reporting Level).

(S) - Indicates surrogate compound.

(I) - Indicates internal standard compound.

Tel: (626) 386-1100
Fax: (866) 988-3757
1 800 566 LABS (1 800 566 5227)

Report: 935099
Project: SPECIAL
Group: Fire Investigation

San Lorenzo Valley Water District

QC Type	Analyte	Native	Spiked	Recovered	Units	Yield(%)	Limits (%)	RPD Limit(%)	RPD%
MBLK	Tetrachloroethylene (PCE)			<0.5	ug/L				
MRL_CHK	Tetrachloroethylene (PCE)		0.5	0.500	ug/L	100	(50-150)		
LCS1	Toluene		5	5.03	ug/L	101	(70-130)		
LCS2	Toluene		5	5.03	ug/L	101	(70-130)	20	0.0
MBLK	Toluene			<0.5	ug/L				
MRL_CHK	Toluene		0.5	0.500	ug/L	100	(50-150)		
LCS1	Toluene-d8 (S)		5	107	%	107	(70-130)		
LCS2	Toluene-d8 (S)		5	106	%	106	(70-130)		
MBLK	Toluene-d8 (S)			91.0	%	91	(70-130)		
MRL_CHK	Toluene-d8 (S)		5	96.8	%	97	(70-130)		
MRLLW	Toluene-d8 (S)		5	94.8	%	95	(70-130)		
LCS1	trans-1,2-Dichloroethylene		5	4.60	ug/L	92	(70-130)		
LCS2	trans-1,2-Dichloroethylene		5	4.56	ug/L	91	(70-130)	20	0.87
MBLK	trans-1,2-Dichloroethylene			<0.5	ug/L				
MRL_CHK	trans-1,2-Dichloroethylene		0.5	0.550	ug/L	110	(50-150)		
LCS1	trans-1,3-Dichloropropene		5	5.02	ug/L	100	(70-130)		
LCS2	trans-1,3-Dichloropropene		5	5.00	ug/L	100	(70-130)	20	0.40
MBLK	trans-1,3-Dichloropropene			<0.5	ug/L				
MRL_CHK	trans-1,3-Dichloropropene		0.5	0.440	ug/L	88	(50-150)		
LCS1	Trichloroethylene (TCE)		5	4.80	ug/L	96	(70-130)		
LCS2	Trichloroethylene (TCE)		5	4.77	ug/L	95	(70-130)	20	0.63
MBLK	Trichloroethylene (TCE)			<0.5	ug/L				
MRL_CHK	Trichloroethylene (TCE)		0.5	0.500	ug/L	100	(50-150)		
LCS1	Trichlorofluoromethane		5	4.66	ug/L	93	(70-130)		
LCS2	Trichlorofluoromethane		5	4.56	ug/L	91	(70-130)	20	2.2
MBLK	Trichlorofluoromethane			<0.5	ug/L				
MRL_CHK	Trichlorofluoromethane		0.5	0.450	ug/L	90	(50-150)		
LCS1	Trichlorotrifluoroethane(Freon		5	4.64	ug/L	93	(70-130)		
LCS2	Trichlorotrifluoroethane(Freon		5	4.53	ug/L	91	(70-130)	20	2.4
MBLK	Trichlorotrifluoroethane(Freon			<0.5	ug/L				
MRL_CHK	Trichlorotrifluoroethane(Freon		0.5	0.470	ug/L	94	(50-150)		
LCS1	Vinyl chloride (VC)		5	4.24	ug/L	85	(70-130)		
LCS2	Vinyl chloride (VC)		5	4.17	ug/L	83	(70-130)	20	1.7
MBLK	Vinyl chloride (VC)			<0.3	ug/L				
MRL_CHK	Vinyl chloride (VC)		0.5	0.460	ug/L	92	(50-150)		
MRLLW	Vinyl chloride (VC)		0.25	0.260	ug/L	104	(50-150)		

Spike recovery is already corrected for native results.

Spikes which exceed Limits and Method Blanks with positive results are highlighted by Underlining.

Criteria for MS and Dup are advisory only, batch control is based on LCS. Criteria for duplicates are advisory only, unless otherwise specified in the method.

RPD not calculated for LCS2 when different a concentration than LCS1 is used.

RPD not calculated for Duplicates when the result is not five times the MRL (Minimum Reporting Level).

(S) - Indicates surrogate compound.

(I) - Indicates internal standard compound.